



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
SY8021	5.6	Pendent	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
SY8022	5.6	Pendent	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

Sentry Sprinklers by GLC Fire Systems Inc.
10967 Lake Underhill Road Unit 102
Orlando, FL 32825, USA

FM Approvals Class: 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR459242

Approval Granted: January 20, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

January 27, 2021

Date



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
SY8011	5.6	Upright	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
SY8012	5.6	Upright	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for:

Sentry Sprinklers by GLC Fire Systems Inc.
10967 Lake Underhill Road Unit 102
Orlando, FL 32825, USA

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR459242

Approval Granted: January 20, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

January 27, 2021

Date



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
SY8031	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
SY8032	5.6	Horizontal Sidewall	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: Sentry Sprinklers by GLC Fire Systems Inc.
10967 Lake Underhill Road Unit 102
Orlando, FL 32825, USA

FM Approvals Class: 2012
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR459242 Approval Granted: January 20, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in dark ink, appearing to read 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

January 27, 2021
Date



Certificate of Compliance

This certificate is issued for the following:

Fire Service Water Control Valves
Models NRSP-6000, OSY-6000

Swing Check Valves
Models 7000, 7100, 7200

Air Release Valves
Model ARV-2000

Indicating Valves
Models L-3000, G-3000, W-3000, TD-3000, GD-3000,
TB-3100, GB-3100

Indicator Posts
Models PI-6012, PI-6030, PI-6024

Dry Barrel Fire Hydrants for Private Fire Service
Model DH68

Wet Barrel Fire Hydrants for Private Fire Service
Model WH68

Prepared for:
Sentry Sprinklers by GLC Fire Systems Inc.
10967 Lake Underhill Road, Unit 102
Orlando, Florida 32825 USA

FM Approvals Class: 1120, 1210, 1344, 1112, 1110, 1510, 1511

Approval Identification: PR459991

Approval Granted: May 13, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

May 18, 2021
Date



Member of the FM Global Group

