

Date 12/6/2023 9:36:13 AM Type Routine

Owner Information

Owner Name Cushing Chamber Foundation for Progress, Inc.
 Owner Address 1301 E Main St
 City Cushing State OK Zip 74023

Facility Information

Location Name Brazee's Tire Service
 Location Address 903 N Lynn
 City Pawhuska State OK Zip 74056
 Facility Type Gas Station Facility # 5706387

Compartment Information

TANK #	COMPARTMENT #	INSTALLED DATE	TYPE	USE	STATUS	SUBSTANCE	MATERIAL	CAPACITY	PIPE MATERIAL
1	1	12/01/1990	UST	Retail	TOU	Gasoline 100%	Steel With Fiberglass	8000	Fiberglass
2	1	12/01/1990	UST	Retail	TOU	Diesel	Steel With Fiberglass	8000	Fiberglass

Facility Questions

Equipment Installation

- Yes No N/A Electrical Installation complies with NFPA and National Electric Code
- Yes No N/A Approved Nozzles with Breakaways

Vent Pipes

- Yes No N/A 12 feet above ground, vented upward, vent caps, and extends 3 to 5 feet above canopy (NFPA 30A)

Impact Shear Valve(s)

- Yes No N/A Installed on pressure piping and anchored (NFPA 30A 6.3.9)

Unattended Self-Service Stations

- Yes No N/A Instructions Conspicuously Posted (NFPA 30A 9.5)
- Yes No N/A Emergency Shutoff Accessible and Visible
- Yes No N/A Emergency shutoff device more than 20 feet but less than 100 feet from dispensers (NFPA 30A 6.7)

TOU Tanks

Tank # 1 Compartment # 1

- Yes No N/A All Tanks drained. (No more than 1" of fluid)
- Yes No N/A All vent lines left open and functioning
- Yes No N/A All other lines, pumps, manways, and ancillary equipment capped and secured.
- Yes No N/A Corrosion Protection properly maintained.

Tank # 2 Compartment # 1

- Yes No N/A All Tanks drained. (No more than 1" of fluid)
- Yes No N/A All vent lines left open and functioning
- Yes No N/A All other lines, pumps, manways, and ancillary equipment capped and secured.
- Yes No N/A Corrosion Protection properly maintained.

Release Detection

Compliance Performance Measures

Overfill Prevention (165:25-2-39)

- Yes No N/A Overfill Prevention Device present
- Yes No N/A Overfill Prevention Device operational
- Yes No N/A Drop Tube w/flapper tested
Date of last test
- Yes No N/A Ball Float tested
Date of last test
- Yes No N/A Drop Tube installed if using ball floats

Corrosion Protection (165:25-2-53)

- Yes No N/A CP System is properly operated/maintained
- Yes No N/A CP System tested within six months of repair
- Yes No N/A Galvanic System Recertified
10/6/22 Date of recertification
- Yes No N/A Impressed Current System Recertified
Date of recertification
- Yes No N/A 60 Day Rectifier Readings present
- Yes No N/A All buried metal that routinely contains product is Cathodically Protected

Spill Prevention (165:25-2-39)

- Yes No N/A Spill Prevention Present
- Yes No N/A Spill Prevention Functional
- Yes No N/A Spill Prevention Tested (3 years)
Date of last test
- Yes No N/A DW Spill Bucket monitored every 30 days

Release Detection (165:25-3-6.20; 165:25-3-6.21)

- Yes No N/A Release Detection is present
- Yes No N/A Release Detection is operating properly
- Yes No N/A Release Detection components tested (annually / per 165:25-3-6.21d)
Date of last test
- Yes No N/A OCC has been notified of suspected release as required (165:25-3-7)
- Yes No N/A Tanks are monitored at least every 30 Days for releases (165:25-3-6.20)
- Yes No N/A Piping is monitored at least every 30 Days for releases or annual testing performed. (165:25-3-6.29)
- Yes No N/A Release Detection Requirements are complied with for TOU Systems (165:25-2-133 , 165:25-3-134)
- Yes No N/A Containment Sumps used for Interstitial Monitoring tested (3 years)
Date of last test
- Yes No N/A Containment Sumps used for Interstitial Monitoring functional

Operator Training

- Yes No N/A Operator Training

Financial Responsibility

- Yes No N/A Financial Responsibility

Walkthrough Inspection


- Yes No N/A On OCC Forms
- Yes No N/A Spill Prevention/Overfill Prevention inspected at least every 30 days
- Yes No N/A Release Detection Equipment inspected at least every 30 days
- Yes No N/A Sumps and Hand Held Release Detection Equipment Inspected annually

Remarks/Comments

Did this facility pass all inspections? Yes No
Facility is in good standing.

Phone # (918) 225-2400


I, the undersigned, certify that the gasoline used by the fuel specialist for the calibration of pumps, as stated above was returned to the proper storage tanks.



Signed By: Nicholas Tucker

12/6/2023 10:02:04 AM

Fuel Specialist, Fuel Division (Signature)



Signed By: TRACY CAULFIELD

12/6/2023 10:02:43 AM

Clear Signature

Owner, Operator or Employee (Signature)

Time Arrived: 12/6/2023 9:36 AM **Time Departed:** 12/6/2023 10:02 AM