



Novec™

Brand

Protecting the Power Grid

Effective fire suppression for gas turbines

Gas turbines in power plants serve a critical role in keeping the lights on, data centers running and machines operating in millions of homes and businesses across the United States. Some plants use them as the sole power source, while others primarily use coal but rely on gas turbines to surge their generating capacity during periods of peak demand. The turbines are essential to the utility's ability to meet its customers' demands, and help to prevent operational interruptions, which are unacceptable.

Decades ago, power plants used both CO₂ and halon fire suppression systems to protect their critical operations. When the Montreal Protocol was adopted in 1987, halon was designated for a complete global phase out because of its high ozone depletion potential, and CO₂ became the only major gaseous fire protection agent used in power generation. Yet during that time the risks of CO₂ also became increasingly apparent: because it extinguishes fires by displacing oxygen from the protected space, CO₂ is lethal at design concentration. A 2003 report sponsored by the U.S. Environmental Protection Agency found that between 1975 and 1999, there were more than 100 deaths and 150 injuries from CO₂ fire suppression systems, mostly resulting from accidental or false alarms.¹

A safer future without CO₂

When a major western US public power utility contacted Tech Electronics of Colorado to replace the CO₂ fire suppression system control panels in one of its generating stations, those panels and the CO₂ compressors had been experiencing daily fault conditions. Tech Electronics and generating station staff were concerned: a false discharge of CO₂ could endanger workers' lives.

A thorough review by Tech Electronics determined that the maintenance needs of the aging CO₂ systems protecting the generating station's five gas turbines had increased to the point where the entire system needed to be replaced. Additionally, due to CO₂'s safety risks, the current National Fire Protection Association Standard on Carbon Dioxide Extinguishing Systems (NFPA 12) states that CO₂ shall not be used in occupiable spaces unless no other technically viable alternative is available from a safety standpoint.² New CO₂ systems must also include numerous complex and expensive safety upgrades. Knowing that there had been many advancements in clean agent technology since the original system had been installed, Tech Electronics and the utility decided to explore CO₂ alternatives that could reliably protect



their highly sensitive equipment for decades to come while providing a higher margin of safety for their employees.

When considering new systems, one requirement was clear – performance could not be compromised. So when the utility asked Rich Vance, director and sales manager at Tech Electronics, about alternatives to CO₂ fire suppression, [3M™ Novec™ 1230 Fire Protection Fluid](#) immediately came to mind as a potential solution. 3M Novec 1230 fluid has a high margin of safety, has environmentally sustainable properties including zero ozone depletion potential and extremely low global warming potential, and is highly effective at extinguishing fires.

The key question remaining was whether it could meet the electric utility's requirements for hold time in the protected space. In the event of a fire, stopping a turbine too quickly will cause overheating and permanent damage to the turbine itself, so a fire suppression system must maintain its extinguishing concentration for 20 minutes or more after the initial discharge while the turbines wind down and dissipate heat. The NFPA 850 standard's recommended practice for electric generating plants calls for a total flooding fire suppression system to be able to accommodate the needed air outflow for cooling hot components while maintaining extinguishing concentration long enough for that cooling to take place, and therefore hold time must be considered in the extinguishing system design.³ Plus, while the NFPA 37 standard for gas turbines only mandates a minimum 20-minute hold time, the utility specified a 60-minute minimum to ensure a 300% margin of protection.⁴

¹ Review of the Use of Carbon Dioxide Total Flooding Fire Suppression Systems, Tables 4 and 5, <https://www.epa.gov/sites/production/files/2018-10/documents/review-of-the-use-of-carbon-dioxide-total-flooding-fire-extinguishing-systems.pdf>, accessed 10/29/19.

² NFPA 12, Standard on Carbon Dioxide Extinguishing Systems, 4.1, 4.1.1, 2018 Edition

³ NFPA 850, Recommended Practice for Fire Protection for Electric Generating Plants and High Voltage Direct Current Converter Stations, 7.6.6*, 7.6.6.1, A.7.6.6, 2020 Edition

⁴ NFPA 37, Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines, 11.4.4.1, 2018 Edition

3M™ Novec™ 1230 Fire Protection Fluid exceeds performance expectations

The electric utility collaborated with Tech Electronics, 3M, and fire protection systems distributor XDS FIRE to develop an extended discharge system using 3M Novec 1230 fluid that would meet all of their requirements. Based on a preliminary design by Chris Vanderstokker, owner of XDS FIRE, the team constructed a scaled test enclosure with the same leakage rate as the actual protected space. Then they developed a new system design using a two-cylinder model, with one cylinder immediately flooding the space with 3M Novec 1230 fluid while the other was equipped with an engineered restricted orifice to control the flow of agent and maintain the extinguishing concentration throughout the extended hold time. It was also designed to enable the extended discharge flow rate to be customized based on the leakage rate of the enclosure, so it could accommodate a range of protected spaces.

The team constructed a scaled down test enclosure and conducted an extensive system validation and optimization process, comparing predicted results against recorded data to ensure that the system

consistently reached and maintained design concentration in alignment with NFPA 850.⁵ More than a dozen potential extended discharge nozzles were developed and tested to ensure that the 3M Novec 1230 fluid would effectively atomize as it slowly discharged into the enclosure.

Finally, 3M and XDS FIRE conducted a full-scale discharge test at the fully operational generating station. The test was witnessed and accepted by the local authority having jurisdiction, validating the effectiveness of a system using 3M Novec 1230 fluid for protecting gas turbines from fire. This real-world test exceeded expectations, with a demonstrated hold time of over 90 minutes – 50% over specifications and 450% over NFPA 37 requirements – effectively protecting the equipment and the company's power generation operations without the worker safety risks of CO₂. It also demonstrated the system's compliance with NFPA 2001⁶ and ISO 14520⁷ standards for testing and fire extinguishing performance. After the test, the electric utility immediately began installing new systems using 3M Novec 1230 fluid to protect its facilities. They had found their smart, safe, sustainable CO₂ replacement and fire suppression solution for the future of power generation.

⁵ NFPA 850, Recommended Practice for Fire Protection for Electric Generating Plants and High Voltage Direct Current Converter Stations, A.7.6.6, 2020 Edition

⁶ NFPA 2001, Standard on Clean Agent Fire Extinguishing Systems, 5.7.2, 2018 Edition

⁷ ISO 14520-1, 7.8.2, 8.2.3.10, 2015 Edition

Smart. Safe. Sustainable.

The 3M™ Novec™ Brand Family

The Novec brand is the hallmark for a variety of proprietary 3M products. Although each has its own unique formula and performance properties, all Novec products are designed in common to address the need for smart, safe and sustainable solutions in industry-specific applications. These include precision and electronics cleaning, heat transfer, fire protection, protective coatings, immersion cooling, advanced insulation media replacement solutions and several specialty chemical applications.

3M™ Novec™ Engineered Fluids · 3M™ Novec™ Aerosol Cleaners · 3M™ Novec™ 1230 Fire Protection Fluid · 3M™ Novec™ Electronic Grade Coatings · 3M™ Novec™ Insulating Gases

Safety Data Sheet: Consult Safety Data Sheet before use.

Regulatory: For regulatory information about this product, contact your 3M representative.

Technical Information: The technical information, recommendations and other statements contained in this document are based upon tests or experience that 3M believes are reliable, but the accuracy or completeness of such information is not guaranteed.

Product Use: Many factors beyond 3M's control and uniquely within user's control can affect the use and performance of a 3M product in a particular application. Given the variety of factors that can affect the use and performance of a 3M product, user is solely responsible for evaluating the 3M product and determining whether it is fit for a particular purpose and suitable for user's method of application.

Warranty, Limited Remedy, and Disclaimer: Unless an additional warranty is specifically stated on the applicable 3M product packaging or product literature, 3M warrants that each 3M product meets the applicable 3M product specification at the time 3M ships the product. **3M MAKES NO OTHER WARRANTIES OR CONDITIONS, EXPRESS OR IMPLIED, INCLUDING, BUT NOT LIMITED TO, ANY IMPLIED WARRANTY OR CONDITION OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OR ANY IMPLIED WARRANTY OR CONDITION ARISING OUT OF A COURSE OF DEALING, CUSTOM OR USAGE OR TRADE.** If the 3M product does not conform to this warranty, then the sole and exclusive remedy is, at 3M's option, replacement of the 3M product or refund of the purchase price.

Limitation of Liability: Except where prohibited by law, 3M will not be liable for any loss or damage arising from the 3M product, whether direct, indirect, special, incidental or consequential, regardless of the legal theory asserted, including warranty, contract, negligence or strict liability.



Electronics Materials Solutions Division

3M Center, Building 224-3N-11
St. Paul, MN 55144-1000 USA

Web 3M.com/Novec
Phone 1-800-810-8513

Please recycle. Printed in USA.
©3M 2021. All rights reserved.
Issued: 2/2021 16622HB
60-5005-0197-2

3M and Novec are trademarks of
3M Company. Used under license
by 3M subsidiaries and affiliates.