

COOL RIDGE FLAT TOP PSD WV3304139 Consumer Confidence Report – 2024 Covering Calendar Year – 2023

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments or suggestions, please attend any regularly scheduled water board meeting held on the 4th Wednesday of each month at 5:00 pm in the office or call HAZEL R BURROUGHS at 304-763-4151.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from Surface water:

Source Name	Source Water Type
CC FROM WV3304104 BECKLEY WATER CO	Surface water

Buyer Name	Seller Name
WV3304139 - COOL RIDGE FLAT TOP PSD	BECKLEY WATER COMPANY

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 4190 and is required to test a minimum of 5 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2023 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1 - December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: COOL RIDGE FLAT TOP PSD

Disinfection Byproducts	Sample Point	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	190 WEATHER HILL LN, BENNETT BLOW OFF	2023	35	1 - 45	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	21629 BECKLEY RD, POST OFFICE	2023	35	25 - 48	ppb	60	0	By-product of drinking water disinfection
TTHM	190 WEATHER HILL LN, BENNETT BLOW OFF	2023	54	34 - 85	ppb	80	0	By-product of drinking water chlorination
TTHM	21629 BECKLEY RD, POST OFFICE	2023	43	19 - 74	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90TH Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.0626	0.0108 - 0.144	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	9.8	0.12 - 71.7	ppb	15	2	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

COOL RIDGE FLAT TOP PSD is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located at **the office**, if you have any questions about our inventory, please contact HAZEL R BURROUGHS at 304-763-4151.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
10/1/2023 - 10/31/2023	2.00000	MG/L	1.70000	MG/L

Unresolved Deficiency Date Identified	Facility	Comments	Cool Ridge-Flat Top PSD Comments
9/14/2022	DISTRIBUTION SYSTEM	System has an unaccounted water loss in excess of 15%. (WVPSC Regulation 150CSR7-5.6.a) Please maintain an unaccounted for water loss of less than 15%. System has a grossly unacceptable unaccounted water loss. (WVPSC Regulation 150CSR7-5.6.a) Please lower the system's excessive unaccounted for water loss with a ultimate goal of being less than 15%. Water loss is estimated to be approximately 41%	The district has hired L.A. Gates for a water loss study to help with the unaccounted for water loss. Funds are being secured to complete the study.
9/14/2022	NO 3 BOOSTER	Booster pump is not properly designed/maintained. (64CSR77-8.6) One of the two service pumps at this booster station is not functioning properly. It is suggested that the system work to replace this pump as soon as possible to ensure redundancy.	The booster pump has been installed, February 6, 2024.

During the 2023 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments	CRFTP SD Comment
9/2/2023	LT2ESWTR	Failed to address a deficiency	Resolved 2/2024 work will be completed with the Ellison Ridge Project.

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761).

There are no additional required health effects violation notices.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful waterborne pathogens may be present, or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify and correct any problems that were found during these assessments.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2023 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	2/6/2023	BECKLEY WATER COMPANY	0.111	0.0258 - 0.111	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CARBON, TOTAL	12/1/2023	BECKLEY WATER COMPANY	3.2	1.1 - 3.2	ppm	10000	0	Naturally present in the environment
FLUORIDE	2/6/2023	BECKLEY WATER COMPANY	0.627	0.611 - 0.627	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	2/6/2023	BECKLEY WATER COMPANY	0.219	0 - 0.219	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	2/6/2023	BECKLEY WATER COMPANY	0.219	0 - 0.219	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Water System	Highest RAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2023	BECKLEY WATER COMPANY	36	17 - 49	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	2023	BECKLEY WATER COMPANY	28	16 - 32	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	2023	BECKLEY WATER COMPANY	23	11 - 33	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	2023	BECKLEY WATER COMPANY	35	18 - 36	ppb	60	0	By-product of drinking water disinfection
TTHM	2023	BECKLEY WATER COMPANY	35	10 - 72	ppb	80	0	By-product of drinking water chlorination

TTHM	2023	BECKLEY WATER COMPANY	24	8 - 47	ppb	80	0	By-product of drinking water chlorination
TTHM	2023	BECKLEY WATER COMPANY	18	7 - 34	ppb	80	0	By-product of drinking water chlorination
TTHM	2023	BECKLEY WATER COMPANY	32	7 - 61	ppb	80	0	By-product of drinking water chlorination

Secondary Contaminants.	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
SODIUM	2/6/2023	BECKLEY WATER COMPANY	139	18.8 - 139	MG/L	1000

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2023 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
WV3304104	MONITORING, ROUTINE (DBP), MAJOR	MON	ALKALINITY, TOTAL	7/1/2023 - 9/30/2023

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Your CCR is available at www://coolridgedccr.org. To receive a paper copy in the mail, please contact us at the phone number above.