



ARC PlasPlus TM

Invented By : Chandrasekhar Chawan PhD

Producer Company : ARC Energy LLC USA

Imported By : M/S. ARC Energy (India)

Official Distributor :

Official Trade Partner :



Chandrashekhar Chawan

- **Chandrashekhar Chawan**, PhD in Physics from University of Bombay,
- Fellow of Scleral Lens Education Society USA.
- Inventor of Patented Diamond studded Eye Jewelry.
- Inventor of Cosmetic/Prosthetic RGP Scleral Lenses patent applied for.
- Inventor of Plastic Cornea
- Inventor of VyasChawan CXL ring
- Inventor of Coal Catalyst for Pollution Control and Coal reduction
- Advisor and Associat Research Scientist with international projects.
- Involved with NASA as public partner scientist.
- Scleral lens Consultant, Myopia Control practitioner, Orthokeratologist, Optometrist & Ocularist.
- Member of American Society of Ocularist, Practicing in Mumbai India, Orlando & Oviedo Florida USA.
- Offers Special effect lenses for Bollywood and Hollywood Movies and Television industries around the world.
- His name is listed in Worlds Who's Who directory in USA





Team at ARC Energy LLC USA

- Chandrashekhar Chawan Chairman
- Tom Lambart Director
- Charley Weaver— Director
- Jim Norton Director
- Mark Cohen Director
- Andrew K. Tay Consultant
- RichardC. Parsons Consultant
- DAN L. SNYDER Consultant



ARC Energy LLC USA

Registered office 10 S. Bumby Ave. Orlando, FL, 32803 USA

- Liquid Coal Catalyst for Energy enhancement and pollution control.
- Powder Coal Catalyst for Pollution Control
- Additives for Natural Gas for energy enhancement
- Petrol and Diesel additives for mileage improvement
- Energy Savings consultation, Power Plants efficiency improvement consultation,
- Flue Gas Desulfurization installation.
- Solar panels for Satellite with higher efficiency
- Solar Power Walls for home / office / industries.
- Solar Panel automatic cleaning system
- Wind mills for home and individual use.
- Micro Hydro Electricity
- Water panels for water from thin air.



What is ARC™ Energy PlasPlus ™

- It is a Liquid Combustion Catalyst to increase heat output of coal using plasma technology
- Sulfur molecule is broken in to O4 and Barium releasing extra energy in most safe and controlled way for coal fired power plants. Extra 4 molecules of Oxygen again helps in better combustion reducing NOx output.
- Saving on coal usage
- Reduce production cost, reduce emission and preserve natural resources.

India lost 1.4m lives due to air pollution in 2013: Study

Ranked 6th Worst, China In 4th place

Atul.Thakur @timesgroup.com

ndia lost 1.4 million lives to air pollution in 2013. while in China the toll was 1.6 million, estimates a World Bank report released on Thursday.

The report, released by the World Bank and the Institute for Health Metrics and Evaluation, shows that in 2013 more than 5 million deaths worldwide were attributed to health conditions caused by air pollution. About 60% of them were in the world's two most populous countries. Exposure to air pollution increases a person's risk of contracting ailments such as lung cancer, stroke, heart disease and chronic bronchitis.

China and India aren't absolute terms because of the sheer size of their respective population. Even after adjusting for population, these two countries along with Bangladesh, Sri Lanka and Pakistan were among the 15 nations with the highest toll per million population. China and India ranked 4th and 6th worst in the world respectively. Bangladesh. Sri Lanka and Pakistan were ranked 11th, 12th 34 per million.

MOST AIR POLLUTION DEATHS IN CHINA



and 15th on this count.

The bank estimates that among the worst hit in in 2013 Georgia saw the highest rate of air pollution deaths per million of its population at 2,117. It was followed by Cambodia with a death rate of 1,300 per million. Among the 142 countries for which the bank complied this data, there were 10 where the rate was higher than 1,000 deaths per million. Australia fared best on this parameter with an estimated death rate of

The report also estimated that air pollution cost the world economy more than \$5 trillion (purchasing Power Parities PPP at 2011 prices) in welfare losses and an additional \$66 billion worth of manpower loss.

China's overall welfare and manpower loss was \$1.6 trillion while India lost more than \$560 billion. which was equivalent to over 10% of China's and 8.5% of India's GDP. Air pollution is estimated to be the fourth leading fatal health risk

worldvide after metabolic risks, lietary risks and tobacco-moke.

The estimates are based on exosure to PM2.5 pollutantsIt is noticeable that the risksare much higher in the develping world. By damaging jeople's health and causing atal diseases, air pollutior can have a lasting effect on a person's economic productivity. Experts argue that tyrically the economically weakest section is the worst hi because of limitel access tchealth care facilities.



10-20% rise in ozone levels in India, harmful for lungs and crops: Report


Jayashree Nandi @timesgroup.com

New Delhi: While Indian cities are still grappling with the impacts of severe particulate matter (PM) pollution, a new report has raised the flagon ozone levels (O3) too.

'The Cost of Air Pollution', a report by the World Bank and Institute of Health Metrics and Evaluation (IHME) released on Thursday, estimates that the concentrations of O3 has increased by 10 to 20% in India between 1990 and 2013. The trend is similar in neighboring countries and in Brazil, while a declining course was seen in the US and Indonesia, among others.

High ozone levels are not only associated with serious health impacts like reduced lung function, chronic obstructive pulmonary disorder (COPD), aggravating asthma and respiratory conditions, but also with widespread crop loss.

The study also estimates that total deaths due to increase in exposure to O3 increased by 50% between 1990 and 2013 in South Asia. For this report, the health and



Sources: World Bank and IHME, using data from IHME, GBD 2013

economic burden of O3 is only based on COPD incidence from it. Total deaths due to exposure to PM2.5 have also increased in South Asia during the same phase, but not as steeply as with O3.

Interestingly, even though the cost of O3-related premature deaths are far lower than that of PM2.5 (both household and outdoor), O3 associated economic or welfare losses for South Asia are equivalent to that of North America. The welfare losses due to O3 exposure are to the tune of 0.4% of gross domestic product (GDP) equivalent, the report states. If you consider man days

lost, it's about 0.09% of GDP equivalent, it says.

Air quality experts said O3 could be a serious concern soon, "Ever before we could deal with health damage from particulate pollution we are falling into the pincer grip of ozone pollution that damages both lungs and crops. This is also the sign that emissions of toxic gases are increasing rapidly in our country. Keep in mind that for estimating health damage from ozone this report has only considered chronic obstructive pulmonary diseases. The actual cost of health damage could be way higher," said AnumiEven before we could dea with health damage fom particulate polltion, we are falling into the incer grip of ozone pollutiorthat damages bothungs and crops. This is as the sign that emission of toxic gases are increasing rapidly in our countril

Anumita Roy howdhury
CSE CLEAN AIR PJGRAMME HEAD

ta Roy Chodhury, head of Centre for Sience and Environment's lean air programme. One is not directly emitted from any source, it is created by chemical reactions betwen oxides of nitrogen and volatile organic compound in the presence of sunlight. It's mainly released from combustion sources wich includes vehicles and injustries.

A 2014 tudy by scientists at Indiannstitute of Tropical Metorology estimated that ozoe-induced damage to whea and rice is enough to feed oughly 35% of 270 millionoelow poverty line (BPL) ppulation in India.



TIMES TRENDS

Now, pollution linked to diabetes too

Study: Prolonged Exposure Leads To Insulin Resistance

Berlin: Long-term exposure to air pollution may increase the risk of developing type 2 diabetes—especially for people with impaired glucose metabolism, a new study has warned. Air pollution exposure at the place of residence increases the risk of developing insulin resistance as a pre-diabetic state of type 2 diabetes, researchers said.

"Whether the disease becomes manifest and when this occurs is not only due to lifestyle or genetic factors, but also due to traffic-related air pollution," said professor Annette Peters, director of the Institute of Epidemiology II at Helm-

holtz Zentrum Munchen in Germany. For the current study, Peters and her colleagues from the German Centre for Diabetes Research (DZD) analysed the data of nearly 3,000 participants of the Cooperative Health Research in the Region of Augsburg (KORA) study who live in the city of Augsburg and two adjacent rural counties.

All individuals were interviewed and physically examined. The researchers took fasting blood samples, in which they determined various markers for insulin resistance and inflammation.

In addition, leptin was examined as adipokine which has been suggested to be associated with insulin resistance. Non-diabetic individuals underwent an oral glucose tolerance test to detect whether their glucose metabolism was impaired. The researchers compared these data with the concentrations of



GASPING FOR AIR

air pollutants at the place of residence of the participants, which they estimated using predictive models based on repeated measurements at 20 sites (for particle measurements) and at 40 sites (for nitrogen dioxide measurements) in the city and in the rural counties.


"The results revealed that people who already have an impaired glucose metabolism, so-called prediabetic individuals, are particularly vulnerable to the effects of air pollution," said Dr Kathrin Wolf, lead author of the study.

"In these individuals, the association between increases in their blood marker levels and increases in air pollutant concentrations is particularly significant. Thus, over the long term—especially for people with impaired glucose metabolism—air pollution is a risk factor for type 2 diabetes," said Wolf. The research was published in the journal Diabetes. PTI

Thous will be

- Plasma Technology based on Matter physics
- Matter behaves differently at different temperatures

- Temp above 900°C
- Temp above 700°C
- Temp above 500°C



Plasma Technology based on Matter Physics

- Matter behaves differently in plasma state in presence of our ARC™ Energy PlasPlus™ Coal catalyst
- Giving out different chemical reactions helping expatiate coal combustion.
- What ever catalyst present in center core where Temp are more than 700°C, reaction taking place will be altered to our benefit i.e. reduce PPM, SOx & NOx and CO and maximum coal combustion.



- ARC™ Energy PlasPlus™ is a coal additive combustion catalyst in liquid form to reduce harmful emissions in Coal fired power plants & reduce your carbon footprint.
- Due to presence of **PlasPlus™** extra heat is generated and that reduces the amount of coal required for the same operations.
- Around 6% to 10% of coal can be saved in ideal condition.



- It improves combustion and provide fuel savings reducing harmful SPM, CO2, CO, SOx and NOx gases.
- If boiler/ Furness is operated optimally **ARC™ Energy PlasPlus™** can reduce coal consumption by about 6% to 10% or more in long run.
- Due to coal savings product pays for itself and can save environment as well.



- It will reduces clinker formation
- ARC™ Energy PlasPlus™ will also reduces unburnt carbon in bottom ash and fly ash.
- ARC™ Energy PlasPlus™ reduces black smoke & deposit formation on heat transfer surfaces.
- Prolonging the life of coal reserves and resources by reducing consumption.



- Increasing the power output from a given size of unit, potentially reducing operating costs.
- Reduce coal handling, shoot blowing, transportation etc.
- ARC™ Energy PlasPlus™ helps coal to burn completely and extract maximum heat energy during combustion, reducing harmful pollution and CO2 at the same time.



Reduced load on FGD

- It will reduce the load on FGD plant as less SOx is formed in presence of PlasPlus.
- It will also reduce the need for anti-slaging and other coal additives for better performance thus saving on running expenses.



Application & Dosage

It is mixed with coal, in normal dosage of 1 Lt of ARC™ Energy
 PlasPlus™

To treat 1000 kg of coal.

• Depending on GCV of coal used, size of pulverized coal and air inflow fine tuned, **ARC™ Energy PlasPlus™** additive quantity will differ to get maximum out put.



No changes are necessary in furnace

 The described compositions are simply added to the fuel supply at precise ratios (1Lt Catalyst to 1 MT of Coal).

 The catalysts are largely benign, non-poisons, non-heavy metals which are non-toxic and non-radioactive safe formulations.

Safety Precautions

 Product is safe to handle and is non-hazardous and nonflammable.

Avoid contact with eyes.

• In case of contact, wash the affected area with water. Treat the product as inorganic chemical.




Packaging

Come in 200 liter plastic barrels.



8 MWH Captive Plant, Indian Coal Before ARC™ Energy PlasPlus™





8 MWH Captive Plant, Indian Coal Before ARC™ Energy PlasPlus™

| Steam Pressure | € 09.00 | 4.7 | mondo | <u>y</u> | | Rabak Executiv | e: 1< | Evin B | Bhemo | byi. | | 9" | |
|--|---------|---------|----------|----------|---------|-------------------|-------|----------|-------|---------|-------|---------|-----|
| | E 03.00 | 10.50 | 11.00 | 12.00 | 13.00 | 14.00 | 15.00 | 16.00 | 17.00 | 18.00 | 19.00 | 1 20.00 | Τ, |
| The state of the s | 3.2 | 37.9 | 37 | 37 | 37 | 37 | 38 | 38.8 | 367 | 38.6 | | 20.00 | 5 |
| Steam Flow | 35 | 3-1 | 33 | 34 | 33 | 34 | 34 | 3.5 | 34 | 34 | 37.6 | 37.5 | - |
| Furnace Bed Temp | 834/883 | 8901833 | 880189 | 801 1858 | 8981895 | 824/224 | - | 888 1877 | | 889 879 | 33 | 34 | |
| Before HRU Flue Gas Temp | 183 | 179 | 177 | 175 | 177 | 169 | 175 | 181 | 179 | * | | 885/878 | |
| after HRU | 142 | 140 | 132 | 134 | 134 | 133 | 137 | 13 9 | 137 | 177 | 180 | 185 | F |
| Feed Water Temp before Economiser | 112 | 110 | 109 | 105 | 104 | 104 | 105 | | 103 | 145 | 147 | 150 | - |
| Feed Water Temp after Economiser | 216 | 213 | 211 | 207 | 210 | 210 | | 104 | | 107 | 112 | 116 | |
| Steam Super Heat Temp | 376 | 37.2 | 372 | 388 | 381 | | 510 | 510 | 508 | 213 | 215 | 155 | St |
| Screw Feeder Totaliser | | | | 000 | 311 | 382 | 385 | 374 | 371 | 372 | 388 | 395 | 1 |
| Fuel Consumption | | | 100 | | - | | | | 67.50 | | | | |
| Surface Temp. of Insulated Boiler Parts | 46140 | 48141 | 47142 | 53/43 | 46/40 | 1 = 3 - | | | | | W. | | |
| Ash Refuse Loss | | | | 33/43 | 46/40 | 45 39 | 45/40 | 45 141 | 46/42 | 45/42 | 48/39 | 45139 | St |
| 02 | 42 | 7.6 | 2:3 | 2.4 | a a | 0.5 | 0.1 | | | | | | |
| Sisk Co2 | 13.9 | 17.6 | LITTES I | 2.7 | .5.8 | 2.5 | 3.1. | 3.5 | 8.5 | 7.5 | 3,8 | 3.2 | |
| Co Co Co | 407 | 337 | 16.1 | 1508 | 15.6 | 15,6 | 15.2 | 15.4 | 15.7 | 15.9 | 15.0 | 15.1 | |
| Sox | 578 | 390 | 2000 | 7600 | 423 | 483 | 142 | 330 | 430 | 412 | 167 | . 189 | |
| Nox | 460 | 365 | 569 | 531 | 632 | .591 | 538 | 547 | 611 | 579 | 457 | 480 | 8 |
| Efficiency BS-845 (Calculated) | -160 | 365 | 390. | 258 | 438 | 422 | 504 | 511 | 477 | 430 | 306 | 317 | |
| Feed rate | 25 | 22 | 22 | 2.0 | 2.2 | 4 | | | | KI F | te. | | |
| Air How | 37 | 1 | 37 | 53 | | 22 | 22 | 25 | 22 | 22 | 22 | 22 - | 22: |
| 10 W | OT | 37 | 34 | 37 | 37 | 37 | 37 | 37.3 | 37 | 37./ | 37.4 | 37.4 | m. |



| Test Data of A | ADIK | | | | | | | |
|----------------------|----------------|----------------|----------------|----------|-----------|---|---|---|
| Date | Coal used | GCV Mois. | GCV Dry N | loisture | | | | |
| 07/06/2015 | 181 | Coal | vecue 1 | to 11 | . 70 | | | |
| 08/06/2015 | 185 | (0) | 0 " | 36.4 | 370 | | | |
| 09/06/2015 | 217 | | | 61.3 | | | | |
| 10/06/2015 | 179 | Son | . + | | , | | | |
| 11/06/2015 | 200 | No | × 4 | 73 .1 | 90 | | | |
| 12/06/2015 | 217 | | | | | | | |
| 13-Jun | 201 | 3285 | 4963 | 33.5 | | | | |
| 14/06/2015 | 204 | 3839 | 5267 | 27.1 | | | | |
| 15/06/2015 | 190 | 3586 | 5115 | 29.88 | | | | |
| 16/06/2015 | 215 | 3722 | 5181 | 28.16 | | | | |
| | 198.9 Ton | 3608 | | 29.66 | | | | |
| Doping Starte | ed on 16/06 it | takes 18 hours | to get the do | | n boiler | | | |
| 17/06/2015 | 191 | | | 37.1 | | | | |
| 18/06/2015 | 196 | 3377 | | 29.8 | | | | |
| 19/06/2015 | 183 | 3866 | 5260 | 26.5 | | | | |
| 20/06/2015 | 162 | * 3822 | 5361 | 28 | | | | |
| 21/06/2015 | 196 | | | 28.1 | | | | |
| 22/06/2015 | 190 | 3747 | 5181 | 27.7 | | | | |
| 23/06/2015 | 120 | Excluded | | | | | | |
| 24/06/2015 | 190 | 3576 | | 28.9 | | | | |
| 25/06/2015 | 160 | | | 30.11 | | | | |
| 26/06/2015 | 181 | | | - 25.62 | | | | |
| Average | 183 Ton | 3643 | | 29.09 | | | | |
| | | 16 Ton Coal sa | | | | | | |
| 27/06/2015 | 214 | Excluded Mach | | | 1 25 & 26 | | | |
| | | Machine starte | ed in night on | 27th | , | | | 1 |
| 28/06/2015 | 190 | | | | | | | |
| 29/06/2015 | 189 | | | 29.1 | | | | |
| 30/06/2015 | 195 | | | 27.14 | | | | |
| 01/07/2015 | 195 | | | 29.33 | | | | |
| 02/07/2015 | 207 | | | 27.3 | | | | |
| 03/07/2015 | 111 | | | | Excluded | | | |
| 04/07/2015 | 75 | | 5210 | 29.33 | Excluded | | | |
| 05/07/2015 | 175 | | | | | | | |
| 06/07/2015 | 191 | 3575 | 5015 | 28.7 | | | | |
| 07/07/2015 | 187 | | | | | | | |
| 08/07/2015 | 181 | | | 29.3 | | | | |
| 09/07/2015 | 179 | | | 27.1 | | - | | |
| Average | 188.9 Ton | 3648 | | 28.28 | | | • | |
| | | 10 Ton Coal is | | | , | | | |
| 10/07/2015 | 167 | | 5136 | 30.2 | | | | |
| 11/07/2015 | 183 | | | | | | | |
| 12/07/2015 | 176 | | | | | | | |
| 13/07/2015 | 177 | | | | | | | |
| 14/07/2015 | 180 | | | | | | | |
| 15/07/2015 | 178 | 3 | | | | | | |
| Average | 176.83 Ton | 22 07 Tan Car | Leaved to 6 d | | | | | |
| | | | | | | | | |

22.07 Ton Coal saved in 6 days



Test conducted at 8 MWH Coal fired power plant at Shah Paper Mills Vapi, Gujrat.

Reduction in coal usage: from 199 tons/day to 177: 11.0%

• Reduction in CO: from 993 ppm to 632 ppm : 36.4%

• Reduction in SOx: from 987 ppm to 378 ppm : 61.7%

• Reduction in NOx: from 944 ppm to 254 ppm : 73.1%



Adani Power plant Mundra 630 MWH

| ADANI POWER LTD Mundra power plant 12 | hour test res | ults | | |
|---------------------------------------|---------------|-----------|-----------|------------------|
| Parameters | Unit | 18-Jan-16 | 19-Jan-16 | Difference |
| | | Before | After | (After - Before) |
| Test Start Time | | 9.00 AM | 9.00 Am | |
| Test End Time | | 9.00 PM | 9.00 PM | |
| Generation Average | MW | 660.4 | 660.88 | 0.48 |
| Coal Flow-Average | TPH | 299.56 | 283.38 | -16.18 |
| Coal GCV Assumed | kcal/kg | 5000 | 5000 | 0 |
| Heat Rate-Calculated | kcal/kWh | 2268 | 2143.95 | -124.05 |
| Specific coal consumtion-calculated | kg/kWh | 0.4536 | 0.4287 | -0.0249 |
| Total Air Flow-Average | TPH | 2168 | 2125 | -43 |
| MS Flow-DCS | TPH | 2036.69 | 2052.7 | 16.01 |
| HPT Intel Pressure @TV (MS) INDICATOR | (MPA)g | 23.85 | 24.05 | 0.2 |
| MS Temp- Average | °C | 555.47 | 556.07 | 0.6 |
| HRH Temp-Average | °C | 560.19 | 561.53 | 1.34 |
| Condenser Vaccum- Average | (kph)g | -88.29 | -88.29 | 0 |
| LPT Exht Temp | °C | 48.13 | 49.41 | 1.28 |
| CW Inlet Temp - Average | °C | 33.11 | 34.45 | 1.34 |
| APH Inlet Temp-Average | °C | 421.4 | 420.8 | -0.6 |
| APH Outlet Temp-Average | °C | 166 | 168.8 | 2.8 |
| APH inlet Oxygen-Average | % | 2.65 | 2.5 | -0.15 |
| Ambient air temp - SA Temp | °C | 42.6 | 43 | 0.4 |
| Average Emission Data | | | | |
| СО | ppm | 0 | 0 | |
| Flue Gags Temp | °C | 167.2 | 168.9 | 1.7 |
| Ambient Temp | °C | 35.6 | 33.9 | -1.7 |
| Nox | ppm | 217 | 160 | -57 |
| SO2 | ppm | 398.8 | 356.5 | -42.3 |



Adani Power Plant Mundra

- 24 hours trail was conducted with powder form catalyst in 2015
- Greta results on emission ware noted
- Coal saving was around 2% but detailed of the results ware not shared by the company.
- Its is advised that minimum 10 days of trail should be conducted to get the desired effect.



Before ARC™ Energy PlasPlus™ at Nasik Thermal Power Station 210 MWH





After ARC™ Energy PlasPlus™ at Nasik Thermal Power Station 210 MWH







MAHARASHTRA STATE POWER GENERATION CO. LTD. NASHIK THERMAL POWER STATION

Certified - ISO 9001: 2008, ISO 14001: 2004, OHSAS 18001: 2007 Office of the Chief Engineer (O& M), N. T.P.S., Eklahare, Dist. Nashik, PIN - 422105 Phone: 0253-2810291-99, Personal: 0253-2810071 E-mail:cegennashik@mahagenco.in

NTPS / CE / POG / FL02/

No 0 3 8 0 5. Date: 25 MAY 2017

M/S Arc Energy, Hari Om Nagar, Mulund (E), Mumbai, 400081

Sub: - Grant of permission to use Arc Energy Coal Catalyst.

Ref: - Your letter No. ARCE/MGC-NSK/006/MUM 041617 dated 27/04/2017

With reference to the above subject matter, Nashik TPS grants permission to use Arc Energy Coal Catalyst for 30 days free trial. Please note down the following points which needs special attention while utilizing Coal Catalyst while referring to your terms and conditions.

- 1. It is your responsibility to note down / collect data from Plant Control Room/ Local - Specific instruction will be given to the PCR staff.
- 2. NTPS will try to provide all the necessary data (pre trial) as far as possible & subsequently will be mailed to you.
- 3. Emission data will be available on weekly basis.
- 4. Spraying of Coal Catalyst directly in coal mill is not possible. It can be spray on conveyor 17A & 17B.
- 5. It will be your responsibility to transport Coal Catalyst up to the point of spray; necessary precaution should be taken, so that no any mishap should be happen.
- 6. Permission to your personnel will be granted with prior submission of the list of the persons visiting to Plant, so that concern staff would arrange the Gate Pass for those persons.
- 7. You will be allowed to bring measuring instrument for emission measurement with prior submission of list of the instrument, so that concern staff would arrange the Gate Pass for instruments.
- 8. NTPS will not bear any type of cost for carrying out the trial.

Coreikaan Chief Engineer NTPS, Nashik



Coal Handling Plant Sub: Daily Status of coal Bunkered of State -II

| | | | CHP - 11 & 111 | | | | | | | | | | |
|-------------|---------------|----------------------|--|---------------------------|--|---------------------------------|--|--|--|--|--|--|--|
| Date | Daily Gen. | ption as per coal | Coal consumpt ion as per Belt weigher in MT | Current coal factor | as per belt weigher 6 9,761 5 0,815 6 0,815 6 0,890 6 0,795 6 0,890 6 0,795 6 0,796 6 0,796 7 | Avg. Bunker level in % | | | | | | | |
| | 2 | 3 | 4 | 5 | 6 | 7 | | | | | | | |
| 01-Aug-17 | 4.289 | 3410 | 3263 | 0.795 | 0.761 | 80% | | | | | | | |
| 02-Aug-17 | 4.148 | 3298 | 3380 | 0.795 | 0.815 | 80% | | | | | | | |
| 03-Aug-17 | 4.137 | 3289 | 3354 | 0.795 | 0.811 | 85% | | | | | | | |
| 04-Aug-17 | 4.155 | 3303 | 3804 | 0.795 | | 95% | | | | | | | |
| 05-Aug-17 | 4.255 | 3383 | 3785 | 0.795 | | 85% | | | | | | | |
| 06-Aug-17 | 4.239 | 3370 | 3370 | 0.795 | | 80% | | | | | | | |
| 07-Aug-17 | 4.506 | 3582 | 3756 | 0.795 | 0.834 | 95% | | | | | | | |
| 08-Aug-17 | 5.915 | 4702 | 4048 | 0.795 | 0.684 | 80%, | | | | | | | |
| 09-Aug-17 | 5.996 | 4766 | 4563 | 0.795 | 0.761 | 70% | | | | | | | |
| 10-Aug-17 | 4.485 | 3566 | 3299 | 0.795 | 0.736 | 60% | | | | | | | |
| TOTAL | 46.125 | 36669 | 36622 | 0.795 | 0.794 | | | | | | | | |
| 11-Aug-17 | 4.851 | 4185 | 3093 | 0.900 | 0.665 | 70% | | | | | | | |
| 12-Aug-17 | 4.466 | 4019 | 3539 | 0.900 | 0.792 | 70% | | | | | | | |
| 13-Aug-17 | 4 253 | 3828 | 3026 | 0.900 | 0.711 | 70% | | | | | | | |
| 14-Aug-17 | 4.387 | 3948 | 4427 | 0.900 | 1.009 | 75% | | | | | | | |
| 15-Aug-17 | 3.943 | 3549 | 3714 | 0,900 | 0.942 | 80% | | | | | | | |
| 16-Aug-17 | 4.122 | 3710 | 3804 | 0.900 | 0.874 | 75% | | | | | | | |
| 17-Aug-17 | 4.222 | 3800 | 3159 | 0.900 | 0.748 | 85% | | | | | | | |
| 18-Aug-17 | 4,103 | 3693 | 3181 | 0.900 | Access to the second se | 75% | | | | | | | |
| 19-Aug-17 | 4.404 | 3964 | 3593 | 0.900 | 0.816 | 80% | | | | | | | |
| 20-Aug-17 | 4.135 | 3722 | 3535 | 0.900 | 0.855 | 90% | | | | | | | |
| TOTAL | 42.686 | 38419 | 34872 | 0.900 | 0.817 | | | | | | | | |
| 21-Aug-17 | 4.037 | 3532 | 3293 | 0.875 | 0.816 | 95% | | | | | | | |
| 22-469-17 | 4.376 | 3829 | 3188 | 0.875 | 0.729 | 75% | | | | | | | |
| 23-AU9-17 | 4.524 | 3959 | 3621 | 0.875 | 0.600 | 90% | | | | | | | |
| · 24-Aug-17 | 4.367 | 3821 | 3241 | 0.875 | 0.742 | 95% | | | | | | | |
| 25-Aug-17 | 3.987 | 3489 | 3373 | 0.875 | 0.846 | 90% | | | | | | | |
| 26-Aug-17 | 4.387 | 3839 | 3246 | 0.875 | 0.740 | 80% | | | | | | | |
| 27-Aug-17 | 4.273 | 3739 | 3305 | 0.875 | 0.773 | 90% | | | | | | | |
| 28-Aug-17 | 4 258 | 3300 | 4007 | 0.775 | 0.941 | 80% | | | | | | | |
| 29-Aug-17 | 4.102 | 3179 | 2901 | 0.775 | 0 707, | 80% | | | | | | | |
| 30-Aug-17 | 4.088 | 3167 | 3740 | 0.775 | 0.915 | 80% | | | | | | | |
| 31-Aug-17 | 4.318 | 3346 | 2740 | 0.775 | 0.635 | 80% | | | | | | | |
| TOTAL | 46.715 | 39200 | 36655 | 0.839 | 0.785 | | | | | | | | |





| 5000 | an institution | | | | | 11. | nd Week t | Jnit IV | | 1000 | | 111 | 1.00 | -41544 | dist. |
|-----------|----------------|--------|------------|-------|-------|---------------|---------------|---------|-------|-------|---------|---------------|----------|-----------|---------------|
| DATE | CONS. | SAOM | SASH . | NVM | NE. | CV KonVkg | ADB Bomb | SIM | %ASH | 16VM | % FC | CV Kcalikg | AFB bomb | ly Ash N | Slag Ash's |
| 08/08/17 | 0 | 0.00 | 0.00 | 0.00 | 0.00 | 0 | . 0 | 0.00 | 0.00 | 0.00 | 0.00 | 0 | 0 | 0.00 | 0.00 |
| 9/08/12 | 1363 | 9.87 | 40.66 | 21.15 | 28.32 | 3292 | 3365 | 16.82 | 37.52 | 19.52 | 26.14 | 3038 | 3106 | 0.64 | 2.45 |
| 0/08/17 | 3566 | 10.52 | 37.67 | 23.62 | 28.19 | 3479 | 3629 | 18.46 | 34.33 | 21.52 | 25.69 | 3170 | 3307 | 0.71 | 2.83 |
| 11/08/17 | 4186 | 10.30 | 38.04 | 22.64 | 29.02 | 3476 | 3584 | 19.18 | 34.27 | 20.40 | 26.15 | 3132 | 3229 | 0.59 | 2.79 |
| 12/08/17 | 4019 | 10.57 | 38.29 | 22.88 | 28.26 | 3414 | 3526 | 17.49 | 35,33 | 21.11 | 26.07 | 3149 | 3253 | 0.67 | 3.50 |
| 13/08/17 | 3828 | 11.60 | 36.95 | 21.83 | 29.32 | 3390 | 3649 | 17.75 | 34.38 | 20.31 | 27.56 | 3154 | 3395 | 0.61 | 1.88 |
| 14/08/17 | 3948 | 10.48 | 41.80 | 21.13 | 26.59 | 3096 | 3300 | 18.22 | 38.19 | 19.30 | 24.29 | 2829 | 3015 | 0.49 | 2.10 |
| 15/08/17 | 3549 | 9.70 | 41.99 | 22.73 | 25.58 | 3192 | 3404 | 18.63 | 37.84 | 20.48 | 23.05 | 2876 | 3067 | 0.95 | 2.50 |
| DVAGTY | 24459 | 10.50 | 39.18 | 22,38 | 27.34 | 3340 | 3507 | 18.21 | 35.80 | 20.45 | 25.54 | 3053 | 3205.45 | 0.67 | 2.58 |
| | | 1 | en sterije | | | u | rd Week | Unit IV | | | Zine en | | | | |
| DATE | CONS. | %ADM | %ASH | %VM | % C | CV Kcal/kg | ADB Bomb | NTM | MASH | *WVM | %FC | CV Kcallkg | AFB bomb | FOYAGE % | Sing Astro |
| 16/08/17 | 3710 | 10.44 | 38.06 | 22.05 | 29.45 | 3454 | 3512 | 17.37 | 35.11 | 20.34 | 27.17 | 3167 | 3240 | 0.89 | 3.20 |
| 17/08/17 | 3800 | 10.22 | 42.68 | 19.91 | 27 19 | 3051 | 3248 | 19.10 | 38.46 | 17.94 | 24.50 | 2750 | 2927 | 0.23 | 2.93 |
| 18/08/17 | 3693 | 9.33 | 43.91 | 21.96 | 2480 | 3065 | 3164 | 18.40 | 39.52 | 19.76 | 22.32 | 2759 | 2847 | 0.65 | 2.2 |
| 19/08/17 | 3964 | 9.18 | 45.64 | 19.51 | 2567 | 2924 | 3117 | 15.93 | 42.25 | 18.06 | 23.76 | 2707 | 2885 | 0.90 | 1.63 |
| 20/08/17 | 3722 | 9.49 | 40.81 | 21.92 | 2778 | 3334 | 3510 | 15.75 | 37.99 | 20.40 | 25.86 | 3103 | 3267 | 0.64 | 2.9 |
| 21/08/17 | 3532 | 11,47 | 34.73 | 22.00 | 31.60 | 3618 | 3777 | 18.04 | 32.15 | 20.37 | 29.44 | 3349 | 3497 | 0.85 | 2.1 |
| 22/08/17 | 3829 | 11.06 | 37.75 | 21.23 | 2996 | 3393 | 3591 | 16.14 | 35.59 | 20.02 | 28.25 | 3199 | 3386 | 0.40 | 0.9 |
| 23/08/17 | 3959 | 10.44 | 38.06 | 21.29 | 3C.21 | 3454 | 3659 | 16.91 | 35.31 | 19.75 | 28.03 | 3205 | 3395 | 0.36 | 1.5 |
| DVAGTV | 30209 | 10,19 | 40.26 | 21.21 | 2E 33 | 3283 | 3444 | 17.19 | 37.10 | 19.56 | 26.15 | 3029 | 3178.23 | 0.62 | 2,1 |
| SAME VICE | 1.00000000 | 1.0000 | - | | D.J. | | Vth Week | Unit IV | | | 1 | | | 11412 | |
| DATE | CONS. | %ADM | %ASH | %VM | SFC | CV Kest/kg | ADB BombCV | MTM | KASH | %VM | %FC | CV Kcal/kg | AFB bomb | Fly Ash N | Sta |
| 24/08/17 | 3821 | 10.97 | 41.03 | 20.35 | 27.65 | 3097 | 3295 | 17.69 | 37.93 | 18.81 | 25.56 | 2864 | 3046 | 0.22 | 2.9 |
| 25/08/17 | 3489 | 9.52 | 42.94 | 20.61 | 26.93 | 3129 | 3380 | 17.59 | 39.11 | 18.77 | 24.53 | 2850 | 3079 | 0.90 | 2.4 |
| 26/08/17 | 3839 | 10.65 | 42.22 | 20.37 | 26.76 | 3032 | 3242 | 18.15 | 38.68 | 18.66 | 24.51 | 2778 | 2970 | 0.60 | 1.5 |
| 27/08/17 | 3739 | 10.51 | 42.98 | 21.30 | 25.21 | 2981 | 3248 | 17.79 | 39.48 | 19.57 | 23.16 | 2738 | 2964 | 1.14 | 2.2 |
| 28/08/17 | 3300 | 9.72 | 44.56 | 20.22 | 25.50 | 2947 | 3138 | 17.38 | 40,78 | 18.50 | 23.34 | 2697 | 2872 | 0.71 | 2.3 |
| 29/08/17 | 3179 | 9.62 | 43.66 | 20.29 | 26.43 | 3046 | 3167 | 16.55 | 40.31 | 18.73 | 24.40 | 2813 | 2924 | 1.00 | 1.4 |
| 30/08/17 | 3167 | 9.74 | 43.62 | 21.61 | 25.03 | 3033 | 3258 | 16.28 | 40.46 | 20.04 | 23.22 | 2813 | 3022 | 0.94 | 2.0 |
| 31/08/17 | 3346 | 9.63 | 44.12 | 21.34 | 21.91 | 3002 | 3225 | 16.84 | 40.60 | 19.64 | 22.92 | 2762 | 2968 | 0.91 | 2.5 |
| WIDAVG | 27880 | 10.08 | 43.08 | 20.75 | 26.09 | 3034 | 3246 | 17.33 | 39.61 | 19.08 | 23.99 | 2790 | 2984.64 | 0.80 | 2 |
| MONTHA | 87548 | 10.25 | 40.89 | 21,40 | 27.46 | 3216 | 3396 | 17,54 | 37,56 | 19.66 | 25.24 | 2955 | 3120.91 | 0.69 | 2 |





MAHARASHTRA STATE POWER GENERATION CO. LTD. NASHIK THERMAL POWER STATION

Certified - ISO 9001: 2008, ISO 14001: 2004, OHSAS 18001: 2007 Office of the Chief Engineer [Ok M], N. T.P.S., Eldahare, Dist, Nashik, PIN - 422105 Phone: 0253-2810291- 99, Personal: 0253-2810071

NTPS/CE/POG/FL02/ NO 7 4 1

Date: 0 9 NO

To.

M/S Arc Energy, Hari Om Nagar, Mulund (E), Mumbai, 400081

Sub: - Coal Catalyst Trial Test in Unit-4 of Nashik TPS

As claimed by M/s ARC Energy Inc. Mumbai, the coal catalyst/ Chemical/ Compound is supposed to improve the combustion efficiency & also reduce the SPM emissions. Therefore, it was decided to have a trial test at Nashik TPS Unit-4 of 210 MW capacity.

The pretest emission related performance parameters were measured by Environment cell once in a day from 11th to 13th Aug-2017. M/S Arc Energy has used catalyst / Chemical/ Compound whose chemical composition, the level of concentration to be sprayed & other parameters were not submitted & hence not known to NTPS, MAHAGENCO.

The trial test was conducted from 14th to 23rd Aug-2017. The coal catalyst was sprayed on coal fed to bunkers through conveyor belt at bunker level.

During trial test, emission related performance parameters were measured by Environment cell once in a day on 17^{th} , 19^{th} , 21^{st} & 23^{rd} Aug-2017.

At Nashik TPS, the received coal quality changes hourly. There is variation in load on Unit-4 on account of coal quality/ system problem/ LD Backing down during pretest & trial test for performance comparison.

The SPM emission is depends on various factors such as coal quality, unit loading, ESP fields healthiness etc. due to which it is difficult to ascertain the exact effect of this test. However, from comparison of pretest & trial test data, it is observed that there is marginal reduction in SPM emission.

Chief Engineer NTPS, Nashik





Work Centre : B-15, Gr. Floor, Shree Datta Vihar C.H.S., Shivaji Nagar, B-Cabin, Thane (W) 400 602.Tel.: 022- 2538 4681, 2542 49 83 e-mail: yajna.fuel86@gmail.com, yajnafuel@vsnl.net web site: www.yajnafuelindia.com



TO WHOMSOEVER IT MAY CONCERN

Nasik NTPS conducted a trial of ARC Energy Plas Plus liquid coal catalyst for emission control and energy enhancer on unit no 4 starting from 15 August 2017 from 10 am. till 9 am of 23 August 2017.

Data used for comparison was Pretrial from $8 \text{ Aug} - 14^{th} \text{ Aug}$ to $15 \text{ Aug} - 23^{rd} \text{ Aug}$ when ARC Energy Plas Plus Coal Catalyst was sprayed on the coal at belt no 17 A & B

The performance of the product is as stated below:

A] Heat rate dropped by 10.3% (Maximum) showing less calories required for generation of power i.e. Kcal/kWh i.e. 10.3% less coal for similar power production..

B] Corresponding contributions to loss reduction were as below: -

1) Reduction in unburnt carbon

= 4 - 6.3%

2) Dry gas loss

= 1-1.2%

3) Stack emissions of Nox.

= 0.3 - 0.5%

4) SO₂ dropped by 13% probably due to oxidizing reaction of additive = 1.5-2%

Additional observation was lower SPM may be due to wetting of particles.

Overall, results of the additive are satisfactory and economics may be worked out at from efficiency and environmental quality improvement.

Thanking you, Yours faithfully, For Yajna Fuel Services

FOR YAJNA FUEL SERVICES

PROPRIÉTOR



MahaGenCo Nasik Thermal Power Station 210 MWH- Trial in August 2017

- SPM levels reduced
- Overall stack emissions reduced
- When average Electricity Generation was compared with GCV corrected coal usage -10.27 % less coal was required
- Fly Ash was reduced by 10.23%
- Slag Ash was reduced by 10.69%



Air pollutants damage blood vessels: Experts

▶From P1

The Lancet study found that the top five reasons for Indians getting stroke were high blood pressure, diet low in fruit, household air pollution, diet low in vegetables and high salt consumption.

The study's authors said such studies would help devise stroke prevention strategies at the local level. "Air pollution has emerged as a significant contributor to global stroke burden, especially in low-income and middle-inco-

The damaged blood vessels precipitate atherosclerosis, a disease in which plaque builds up inside arteries, further leading to stroke

Dr Ashok Mahasur | SPECIALIST

me countries, and therefore reducing exposure to air pollution should be one of the main priorities to reduce stroke burden in these countries," said the study funded by the Bill and Melinda Gates Foundation.

So how does air pollution cause stroke? The IHME study doesn't offer an etiological connection, but experts say air pollutants such as carbon monoxide are known to damage blood vessels. "These damaged blood vessels precipitate atherosclerosis, a disease in which plaque builds up inside arteries, further leawho formerly headed KEM

A MAJOR HEALTH HAZARD

What is a stroke?

➤ It's a disease affecting arteries leading to and within the brain. A stroke occurs when a blood vessel that carries oxygen and nutrients to the brain is either blocked by a clot or bursts. As that part of the brain doesn't get blood (and oxygen) it needs,

brain cells die

➤ Every year, 15 million people worldwide suffer a stroke (6 million die & 5 million are left with permanent disability such as loss of vision and/or speech, paralysis and confusion)

In India, nearly 1.5 million people suffer stroke annually

What the study says

- > It looks at the Global Burden of Diseases, 2013 and identifies 10 risk factors for stroke
- > Identifies air pollution, for the first time, as a risk factor
- ➤ About a third (29.2%) of global disability associated with stroke is linked to air pollution
- ➤ Air pollution-stroke link high in developing countries (33.7% vs 10.2% in developed countries)

Risk factors for Indians

- Diet low in fruit
- > Household air pollution
- > Diet low in vegetables
- > Diet high in sodium

What is DALYs?

WHO defines 1 DALY as loss of the equivalent of one year of full health. In terms of DALYs, the study said, air pollution accounted



Air pollution on Friday MUMBAI'S AQI

(MODERATE) DELHI'S AQI

171 (MODERATE)


dentally, stroke is one of the doctor with the 4.5-hour gollargest causes for disability in ding to stroke," said chest spe- India. "Roughly 1.5 million cialist Dr Ashok Mahasur, stroke cases are estimated across India every year. As Hospital's Environment Pol- 80% of the patients don't get

lution Research Centre. Inciany pain, they fail to go to the den period," said Dr Hastak. This delay makes stroke-related symptoms such as a paralysed hand or legor lost vision permanent.



GCV in Lab







GCV

• Typical GCV calculation of coal doped with our **ARC™ Energy PlasPlus™** in 1Lt to 1000kg do not show increased in GCV in lab test, as Our product start acting only in plasma lavel and that much temperature is not available in Bomb Calorimeter.



Minimum 10% Pollution Reduction

- 10% less Coal burnt = 10% less emission
- 10% Cost saving
- 10% reduction in Coal handling expenses
- 10% reduction in NOx, SOx, CO2, CO & SPM




- Our product can be implemented ASAP in all power plants
- Reduce Pollution, Earn Money on saved coal
- Reduce Carbon foot print on our mother Earth
- Reduce Global worming
- Save Environment Save Earth



ARC Energy to reduce NOx with our OxyRx technology

- Additional technology of Oxygen rich air input OxyRx to reduce NOx formation and better combustion is also available on request.
- Input Air is only 21% Oxygen and 78% Nitrogen
- Where as only Oxygen is required for combustion
- But 78% Nitrogen is also pushed in and comes out of exhaust with harmful oxides of Nitrogen, that can be reduced with our OxyRx technology
- Load on ID fan is also reduces with our OxyRx technology as only 21%
 Oxygen rich air to be pushed in, instead of 100% air combined with unwanted 78% nitrogen and other gasses.

Product Patent & Trade Mark



• Trade Mark No.: 3600072 in Class 4



Contact Us

Manufacturer

ARC Energy USA LLC.

10 South Bumby Ave. Orlando, FL 32803 (USA)

Tel: +1 909 999 6519

Contact Person: Dr. Chandrasekhar Chawan

<u>Importer</u>

M/s. ARC Energy (India)

109, Falcon Court, Hari Om Nagar, Mulund (E), Mumbai-400081

Tel:: +91-9920361631

Website

http://www.arcenergy.us

<u>Email</u>

chandrachawan@gmail.com arcenergyus@gmail.com

