



BPR CODE QUIZ

October 2025

1. Per Section 603.4.1 of the 2022 California Mechanical Code, for other than residential occupancies, flexible air ducts shall be not more than ____ feet in length and shall not be used in lieu of rigid elbows or fittings. Flexible air ducts shall be permitted to be used as an elbow at a terminal device.
 - a. 5 feet
 - b. 6 feet
 - c. 8 feet
 - d. 10 feet
2. Per Section 1404.2 of the 2022 California Plumbing Code, combustible piping installations penetrating a fire-resistance-rated wall, partition, floor, floor, floor-ceiling assembly, roof ceiling assembly, or shaft enclosure, the fire-resistance rating of the assembly shall be restored to its original rating?
 - a. True
 - b. False
3. Per Section 714.6.1 of the 2022 California Building Code, nonfire-resistance-rated assemblies, noncombustible penetrating items that connect not more than ____ stories are permitted, provided that the annular space is filled to resist the free passage of flame and the products of combustion with an approved noncombustible material or with a fill, void or cavity material that is tested and classified for use in through-penetration firestop systems
 - a. 2 stories
 - b. 3 stories
 - c. 4 stories
 - d. 5 stories
4. Per Section 1006.2.2.4 of the 2022 California Building Code, the location and number of exit or exit access doorways shall be provided for electrical rooms in accordance with Section 110.26 of NFPA 70 for electrical equipment rated ____ volts or less, and Section 110.33 of FPA 70 for electrical equipment over ____ volts. Panic hardware shall be provided where required in accordance with Section 1010.2.9.2.
 - a. 500 & 500 volts 90
 - b. 1,000 & 1,000 volts
 - c. 1,500 & 1,500 volts
5. Per Section 8-402.2 of the 2022 California Historical Code, upgrading an existing qualified historical building or property to one-hour fire-resistive construction and one-hour fire-resistive corridors shall not be required regardless of construction or occupancy when one of the following is provided:
 - a. An automatic sprinkler system throughout.
 - b. An approved life-safety evaluation. 4 feet
 - c. Other alternative measures as approved by the enforcing agency.
 - d. Either a, b, or c

Answer Key: 1: a 2: a 3: d 4: b 5: d

Please contact Ron Beehler by email at rbeehler@bpr-grp.com to discuss any questions.