

a. ASTM 148 b. UL 197

a. ½ inch. b. ¾ inch. c. 1 inch. d. 1 1/4 inch

accordance with the manufacturer's installation instructions.



BPR CODE QUIZ May 2025

1. Per the 2022 CA Mechanical Code, Section 921.1, commercial electric ranges shall comply with _____ and be installed in

	c. ASTM 162 d. UL 106
2.	Per the 2022 CA Building Code, Section 703.5, where there is an accessible concealed floor, floor-ceiling or attic space, fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in the concealed space. Such identification shall be located within feet of the end of each wall and at intervals not exceeding feet measured horizontally along the wall or partition.
	 a. 5 feet from each end and 20-foot intervals. b. 10 feet from each end and 25-foot intervals. c. 15 feet from each end and 30-foot intervals. d. 20 feet from each end and 35-foot intervals.
3.	Per the 2022 CA Building Code, Section 603.1, combustible materials may be used in buildings of Type I and Type II Construction for blocking for handrails, millwork, cabinets, and window and door frames.
	 a. False, combustible materials are not permitted in Type I or Type II buildings. b. True provided the combustible material is wood with a minimum 4x nominal dimension. c. True if the combustible material is enclosed within rated wall and floor assemblies. d. True
4.	Per the 2022 CA Building Code, Section 1205.3, for buildings two stories or less above grade plane, courts shall be not less than feet in width and courts having windows opening on opposite sides shall be not less than feet in width.
	 a. 3 feet and 6 feet. b. 5 feet and 8 feet. c. 5 feet and 10 feet. d. 6 feet and 12 feet.
5.	Per the 2022 CA Mechanical Code, Table 310.3, the minimum condensate pipe diameter for refrigeration equipment with a capacity of 21 to 40 tons is inches.