



BPR CODE QUIZ

December 2025

- 1. Per the 2022 California Electrical Code, Section 422.16, flexible cords shall be permitted as follows:
 - a. To connect appliances to facilitate their frequent interchange or to prevent the transmission of noise or vibration.
 - b. To facilitate the removal or disconnection of appliances that are fastened in place, where the fastening means and mechanical connections are specifically designed to permit ready removal for maintenance or repair and the appliance is intended or identified for flexible cord connection.
 - c. Both a and b
 - d. Either a or b
 - e. Neither a nor b
- 2. Per the 2022 California Historical Code, Section 8-902.1.2, existing mechanical systems which do not, in the opinion of the enforcing agency, constitute a safety hazard may remain in use.
 - a. True
 - b. False
- 3. Per the 2022 California Residential Code Appendix AH, Section AH103.1, Patio Cover enclosure walls shall be permitted to be of any configuration, provided that the open or glazed area of the longer wall and one additional wall is not less than 65% percent of the area below 6 feet 8 inches of each wall, measured from the floor. Openings shall be enclosed of any of the following:
 - a. Insect screening
 - b. Approved translucent or transparent plastic not more than 0.125 inch
 - c. Glass conforming to the provision of Section R308
 - d. Any Combination of the above
- 4. Per the 2022 California Mechanical Code, Section 502.1, exhaust openings terminating to the outdoors shall be covered with a corrosion-resistant screen having not less than ____ of an inch openings, and shall have not more than ____ of an inch openings.
 - a. 1/8" and 1/2"
 - b. 1/4" and 1/2"
 - c. 5/16" and 1"
- 5. Per the 2022 California Building Code, Section 1008.2, the means of egress serving a room or space shall be illuminated at all times that the room or space is occupied. Which of the following is <u>not</u> an exception?
 - a. Occupancies in Group U
 - b. Aisle accessways in Group A
 - c. Occupancies in Group S-2 low-hazard storage
 - d. Dwelling units and sleeping units in Groups R-1, R-2 and R-3
 - e. Sleeping units of Group I, R-2.1 and R-2 occupancies