

## 7<sup>th</sup> Annual Water Quality & Treatment Symposium

# Retrofitting a Surface Water Treatment Plant for PFAS Removal - Braintree, MA

Stephen C. Olson, P.E.

President, H2Olson Engineering, Inc.

November 30, 2021

# Presentation Outline

---

- **Town of Braintree & Great Pond WTP**
- **Existing Filtration System**
- **Filter Retrofit Design**
- **Construction**
- **Full Scale Demonstration Test**

# Braintree Water System Overview

## ■ Braintree, MA

- Population – 35,700
- Number of Customers (11,770)
- Average Demand – 3.4 MGD

## ■ Supply

- Great Pond Reservoir System
- Upper Pond, Lower Pond, Richardi Reservoir
- Shared Water Supply System
- Randolph and Holbrook


## ■ Great Pond WTP

- 6.5 MGD, Conventional Treatment
- Constructed: 1935
- Upgrades/Expansions: 1958, 1972, 2001, 2010, 2012




# Great Pond Water Treatment Plant

- **6.5 MGD, Conventional Treatment**
- **Constructed: 1935**
- **Upgrades/Expansions: 1958, 1972, 2001, 2010, 2012**




# Filtration System




# Existing Filtration System

Filter Size: 18' x 18' = 324 square feet  
 Underdrain: Flume Block with IMS Cap



Total Media Depth 33"



Media	Depth	Characteristics
Garnet Gravel	3"	3/16" x #14
Garnet Sand	4.5"	ES = 0.18-0.32 mm; UC = 2.2 or less
Silica Sand	9"	ES = 0.45-0.55 mm; UC = 1.6 or less
Anthracite	16.5"	ES = 1.00 mm; UC = 1.7 or less

# Filter Media Design

## Empty Bed Contact Time (GAC Media Depth 42"):

Peak (6.5 MGD), 5 Filters: 9.4 Minutes

Peak (6.5 MGD), 4 Filters: 7.5 Minutes

Maximum Daily Flow (4.61 MGD, past 10 years), 4 filters: 10.6 minutes

Average (3.4 MGD), 5 Filters: 18 Minutes

Average (3.4 MGD), 4 Filters: 14.4 Minutes

## Existing L/d ratio: 1,495

L/d - ratio of filter bed depth to effective media diameter

Typical L/d for dual media filters is between 1,000 and 2,000

<u>Media</u>	<u>Depth</u>	<u>Characteristics</u>
GAC (Calgon FS-300)	42"	ES = 0.8 - 1.0 mm; UC = 2.1 or less
Filter Sand	6"	ES = 0.45 - 0.55 mm; UC = 1.6 or less

L/d ratio: 1,490

## **Calgon Filtrasorb 300 (FS-300)\***

Apparent Density: 0.56 g/CC

Iodine Number: 900 mg/g

\*Successfully piloted in 2004 as filter media and compliance with SWTR/ESWTR

## Filter Loading Rate



Peak (6.5 MGD), 5 Filters: 2.6 gpm/sf

Peak (6.5 MGD), 4 Filters: 3.2 gpm/sf


Average (3.4 MGD), 5 Filters: 1.5 gpm/sf

Average (3.4 MGD), 4 Filters: 1.8 gpm/sf

# Filter Design



**EXISTING FILTER MEDIA**  
SCALE: NTS



**PROPOSED FILTER MEDIA**  
SCALE: NTS

# Project Implementation



---

1. Submit Design and Permitting to MA-DEP
  - Retrofit 1 filter with new media (sand/GAC)
  - Complete 30-Day full scale demonstration test
  - If the results are good, replace media in remaining 4 filters
2. Bid project with phased implementation
  - Phase 1 - replace media in test filter (Filter #1)
  - Wait up to 90 days for demonstration test and MA-DEP approval
  - Re-mobilize and replace media in remaining 4 filters
3. Bid Results
  - 2 bids received
  - \$299,000 for all 5 filters, \$1.32/cf for GAC
4. Demonstration Test: November 19, 2020 to December 19, 2020
5. Remaining 4 Filters: February 1, 2021 to February 24, 2021

# Media Replacement - Removal



# Media Replacement - Removal



# Media Replacement - Inspect Underdrain



# Media Replacement - Install Sand



# Media Replacement - Backwash Sand



# Media Replacement - Reinstall Sweepers



# Media Replacement - Install GAC



# Media Replacement - Backwash Fines



# Full Scale Demonstration Study

- 1 Filter (Filter #1)
- Replace Media and Operate for 30 days
- Review Operations and Water Quality

**Table 3**  
**Operation Monitoring Parameters**

Parameter	Test Equipment
WTP flow, gpm	On-line Instrumentation
Filter Headloss, feet	Manually Recorded
Filter Runtime	Manually Recorded
Filter Backwash Duration	Manually Recorded

**Table 2**  
**Water Quality Sampling Frequency – Test Filter**

Parameter	Sampling Interval
Turbidity	Filter #1 and CFE: continuous monitoring and grab samples every 2 hours
pH	Filter #1 and CFE: grab samples every 4 hours
Alkalinity	Filter #1 and CFE: daily grab sample (every 24 hours)
PFAS	Raw, Filter #1, and Finished Water: weekly (Test Days: 7, 14, 21, and 28)
UV-254	Settled Water, Filter #1, and CFE: daily grab sample (every 24 hours)
TOC	Settled Water, Filter #1, and CFE: weekly (Test Days: 7, 14, 21, and 28)

## **Test Conditions:**

November 19, 2020 to December 19, 2020

## **Average**

Flow: 462 gpm

Filter Loading Rate: 1.4 gpm/sf

EBCT: 18.4 minutes

## **Maximum**

Flow: 674 gpm


Filter Loading Rate: 2.1 gpm/sf

EBCT: 12.6 minutes

**Table 4**  
**Water Quality Goals, Demonstration Test Filter**

Water Quality Parameter	Goal
PFAS6	Less than 10.0 ppt
Turbidity	Less than 0.3 NTU

# Full Scale Demonstration Study - Filter Run Time




**Before Test**  
Filter Run Time: 22-62 hours

**During Test**  
Filter Run Time: 18-50 hours

Filter run time decreased ~11 hrs

# Full Scale Demonstration Study - Headloss



## Before Test

Average Headloss: 3.3 ft  
Maximum Headloss: 4.0 ft


## During Test

Average Headloss: 3.7 ft  
Maximum Headloss: 5.8 ft

## Same Filter Backwash Sequence

- 20 minutes
- Surface Wash
- Low Wash
- High Wash


# Full Scale Demonstration Study - Turbidity



Peak Turbidity after backwashing decreased from 0.29 NTU to < 0.1 NTU after 3 weeks of operation.

Average Effluent Turbidity  
Before Test: 0.09 NTU  
After 3 Weeks: 0.06 NTU


# Full Scale Demonstration Study - CFE Turbidity



Peak CFE Turbidity after backwashing Filter #1 not dramatically different after media replacement.

Average CFE Turbidity  
Before Test: 0.10 NTU  
After 3 Weeks: 0.07 NTU

# Full Scale Demonstration Study - UV-254



Steady Clarifier Effluent UV-254  
 Average: 0.031 1/cm  
 Range: 0.024 - 0.044 1/cm

**UV-254 Before Test**  
 Filter #1: 0.030 1/cm  
 CFE: 0.030

**UV-254 During Test**  
 Filter #1: 0.003 1/cm  
 CFE: 0.016 1/cm

44% reduction in CFE UV-254


# Full Scale Demonstration Study - TOC

**Table 6**  
**TOC Sampling Results (mg/L)**

	Raw Water	Settled Water	Filter #1	CFE	Total % Removal
<b>Pre-Test Conditions</b>					
11/9/2020	4.4	2.8	2.5	3	32%
<b>Demonstration Test</b>					
11/19/2020	3.8	1.8	<1.0	1.1	71%
11/25/2020	3.8	2.2	<1.0	1.2	68%
12/3/2020	4.5	3	<1.0	1.2	73%
12/9/2020	4.4	2.7	<1.0	1	77%
12/16/2020	4.5	2.6	<1.0	1.3	71%
<b>Average*</b>	<b>4.2</b>	<b>2.46</b>	<b>&lt;1.0</b>	<b>1.16</b>	<b>72%</b>

\*Average during the Demonstration Test

# Full Scale Demonstration Study - pH



Normal Filter Effluent pH: 7.2 - 7.5


Filter #1 pH after GAC: 10 - 10.3  
CFE pH after GAC: > 9.5 - 9.8

Normal pH levels after ~ 10 days

# Carbon Dioxide Treatment of GAC Media



# Filter Effluent pH after CO<sub>2</sub> Treatment



## pH Stabilization of Media

Without CO<sub>2</sub> Treatment: ~ 10 days

With CO<sub>2</sub> Treatment: ~ 3 days


# Full Scale Demonstration Study -PFAS

**Table 5**  
**PFAS6 Sampling Results (ppt)**

Sample Date	Raw Water	Filter #1 Effluent	Finished Water	Total % Removal
<b>Pre-Test Conditions</b>				
11/9/2020	19	21	20	<b>NA</b>
<b>Demonstration Test</b>				
11/19/2020	22	0	19	<b>14%</b>
11/24/2020	24	3	18	<b>25%</b>
12/2/2020	22	0	16	<b>27%</b>
12/8/2020	20	0	15	<b>25%</b>
12/15/2020	23	0	15	<b>35%</b>
<b>Average*</b>	<b>22.2</b>	<b>0.6</b>	<b>16.6</b>	<b>25%</b>

\*Average during the Demonstration Test, 4 filters on-line including Filter #1

# Full Scale Demonstration Study - PFAS



# Questions?

## Contact Information

**Stephen C. Olson**

**[sco@h2olsonengineering.com](mailto:sco@h2olsonengineering.com)**

**508-375-7007**

**[www.h2olsonengineering.com](http://www.h2olsonengineering.com)**