

MSW

FHA/VA/USDA Water Scan

Analytes	Results	Description	EPA Limits
<u>Bacteria</u>			
Total Coliform	Absent	There should be no Coliform bacteria in the sample.	0
E. Coli	Absent	Known to Cause Illness	0
<u>Mineral Chemistry</u>			
Iron	Absent	Brown Stains, Bitter Taste	0.30 mg/L
Lead	Absent	A Toxic Metal, From Plumbing Components	0.015 mg/L
pH	6.5	Acid/Basic Determination	6.5 - 8.5 SU
Nitrate as Nitrogen	0.93 mg/L	Indicator of Biological Waste	10.0 mg/L
Nitrite as Nitrogen	Absent	Indicator of Waste	1.0 mg/L
Total Nitrate/Nitrite Nitrogen	0.93 mg/L	Total Nitrate and Total Nitrite	10 mg/L

***These results meet EPA Standards for potability.**

This is a basic test for HUD requirements only. Contact us for a fully comprehensive test after closing.
 Experts recommend testing yearly since water results can change over time.



Georgia Home Pros.com, 6858 Yellow Creek Rd., Ball Ground, GA 30107. 770-893-2271 Office 470-526-2222 Direct

The results above only apply to the actual sample tested. Georgia Home Pros Home Inspections and Environmental Testing shall be held harmless from any liability arising out of the use of such results.
 All analyses were conducted using EPA approved materials and methods.