

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, LRAA/ TTHM**

The Texas Commission on Environmental Quality (TCEQ) has notified the **CITY OF STAR HARBOR , PWS 1070150** public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total haloacetic acids. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total haloacetic acids to be 0.060 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total haloacetic acids indicates a compliance value for:

- **1Q2026 of .069 mg/L for 54 SUNSET BLVD, STAR HARBOR (DBP2-02)**
- **1Q2026 of .070 mg/L for 14 DEER RUN, STAR HARBOR (DBP2-01)**
- **4Q2025 of .074 mg/L for 14 DEER RUN, STAR HARBOR (DBP2-01)**
- **4Q2025 of .077 mg/L for 54 SUNSET BLVD, STAR HARBOR (DBP2-02)**

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue (HAA5): _Additional Flushing of the water mains_

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: Jeremy Crocker

Area code + phone number: 903-275-9996 Posted /Delivered on: 6/30/2026

Instructions for preparing the required Public Notice:

Reply to this email with completed, signed and dated copies of all documents for our review.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than 30 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice. Refer to 30 TAC §290.122 for additional information on Public Notification.



Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: **CITY OF STAR HARBOR PWS ID 1070150**

Type violation: HAA5 MCL Compliance period: 1Q2026, 4Q2025

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

X Mail or direct delivery, to bill-paying customers as required by 30 TAC

§290.122(b)(2)(A) for community water systems; and

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122; **and**

Made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

_____ Posting the PN on the internet at www.ccwsc.myruralwater.com.

_____ Mailing the PN to postal patrons within the service area that do not receive a bill

_____ Advertising the PN in news media

_____ Publication of PN in local newspaper

X Posting the PN in public places

_____ Posting the PN in conspicuous places within the service area

_____ Delivery of multiple copies to single bill addresses serving several persons

_____ Delivery to community organizations

_____ Email notification

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print): Jeremy Crocker Title: Operator

Phone: 903-275-9996 Date of Delivery: 6/30/2026

Signature: _____ Date Signed: 6/29/2026

Reply to this email with completed, signed and dated copies of all documents for our review.