


9/6/2019 7:39:45 AM



8/3/2019 1:45:06 PM



DJI_0022.jpg

Qualitative Report
Equipment M210RTK
Camer XT2

Edward Rehnstrom
American Drone Solution, LLC
470-755-7372

A field inspection of Solar Panels.

At the time of inspection, the panel system has no internal performance issues. All panel subconnections temperatures were normal. Panel were clear of debris and dust. The inspection found no singular cells or multiple cells inop. Modules were inspected for cracks and string failures and none were found. Inspection was completed at 12:30 pm under full solar load with a temperature of 85°F and humidity 46%, and no foliage shadowing.