



# Oregon

Kate Brown, Governor

Early Learning Division  
Office of Child Care



July 21, 2022

000004

GRANDMA'S PLACE - ROSE QUARTER  
1730 N FLINT AVE  
PORTLAND OR 97227-1805

## RE: CC052323 Lead Testing Results Summary

The Facility must post the most recent lead test results summary provided by OCC in an area of the facility where the summary can be clearly viewed by parents. The facility must post the lead test results summary immediately after receiving the summary from OCC.

### Lead Test Results:

Faucet Name	Pass or Fail	Mitigation Strategy	Approved	Retest Date
Infant Bottle Sink	Pass			4/19/28
Kitchen Food Prep	Pass			4/19/28
Mobile Hand Washing	Pass			4/19/28
Preschool	Pass			4/19/28
Toddler Hand Washing	Pass			4/19/28
Wobbler Hand Sink	Pass			4/19/28

If test results show that water from any drinking water faucet or fixture has 15 parts per billion (ppb) or more of lead, the facility must:

- Prevent access to that drinking water faucet or fixture immediately after receiving the test results; and
- Continue to prevent access to that drinking water faucet or fixture until mitigation is completed and approved by the Office of Child Care

CC: Amber Bayker, Licensing Specialist  
File