

## ROUTINE SERVICE FREQUENCIES FOR EACH SECTION

AUSTRALIAN STANDARDS 1851-2012

AUSTRALIAN STANDARDS 2293.2

AUSTRALIAN STANDARD 1851-2012 SECTIONS		ROUTINE SERVICE SCHEDULE							
		MONTHLY	THREE MONTHLY	SIX MONTHLY	YEARLY	FIVE YEARLY	TEN YEARLY	TWENTY-FIVE YEARLY	THIRTY YEARLY
2	Automatic Fire Sprinkler Systems	✓		✓	✓	✓	✓	✓	✓
3	Fire Pumpsets	✓		✓	✓	✓			
4	Fire Hydrant Systems	✓*			✓	✓			
4	Hydrant Valves			✓	✓				
5	Water Storage Tanks for Fire Protection Systems	✓		✓	✓		✓		
6	Fire Detection and Alarm Systems	✓		✓	✓	✓			
7	Special Hazard Systems	✓		✓	✓		✓		
8	Delivery Lay Flat Fire Hose				✓				
9	Fire Hose Reels			✓	✓				
10	Portable and Wheeled Fire Extinguishers			✓	✓	✓			
11	Fire Blankets			✓					
12	Passive Fire and Smoke Systems		✓**	✓	✓				
13	Fire and Smoke Control Features of Mechanical Services	✓	✓	✓	✓	✓			
14	Emergency Planning in Facilities			✓	✓				
AUSTRALIAN STANDARD 2293.2		ROUTINE SERVICE SCHEDULE							
		MONTHLY	THREE MONTHLY	SIX MONTHLY	YEARLY	FIVE YEARLY	TEN YEARLY	TWENTY-FIVE YEARLY	THIRTY YEARLY
Exit and Emergency Light Testing				✓	✓				

\*Where Pumpsets are fitted

\*\*Where Horizontal Sliding Doors are fitted

FREQUENCY TOLERANCES	
Monthly	5 working days
Three Monthly	10 working days
Six Monthly	1 month
Yearly	2 months
Five Yearly	3 months
Ten Yearly	6 months
Twenty Five Yearly	6 months
Thirty Yearly	6 months

The tolerance schedule is not intended to require additional Routine Service Activities to be carried out  
EG Six Monthly Routines carried out at Five or Seven Monthly Intervals