

# Ballistic Test Form-a-Wall

Test Date Feb 11<sup>th</sup> 2005



# Sterling Ballistic Test



Test wall 114mm standard Form-a-Wall  
3,000 PSI concrete fill

# Sterling Ballistic Test



Test Distance 25mts

# Sterling Ballistic Test



Test Distance 25mts 9mm Handgun

# Sterling Ballistic Test



Test Distance 25mts 9mm Handgun Front View

# Sterling Ballistic Test



9mm slugs stopped and held by Concrete & cement sheet

# Sterling Ballistic Test



Rear of panel after 9mm test no damage

# Sterling Ballistic Test



Test shots 45 Handgun at 25mts



# Sterling Ballistic Test



Test shots 45 Handgun at 25mts

# Sterling Ballistic Test



Rear of panel after 9mm & 45 test no damage

# Sterling Ballistic Test



Test M16 at 25mts

# Sterling Ballistic Test



Test M16 at 25mts

# Sterling Ballistic Test



Test 9mm , 45 & M16 at 25mts Back of Panel

# Sterling Ballistic Test



Test Guns

# Sterling Ballistic Test

Test conducted at Philippine National Training Grounds Silang ,  
Philippines

Supervising Police Sergeant Joes Pebres PNP

Witness : Armed Forces Of The Philippines **Brigadier General  
Francisco Bravo** Office Of The Chief Of Engineers