

SAFE DRINKING WATER CERTIFICATE

No. 40

Dated: 13/05/2026

It is certified that an inspection team headed by **Satya Prakash Azad (Chemist)** (Name of Officers with designation) from **P.H.E.D. Investigation Office** (Name of Department/ Office) inspected the K. C MOUNT FORT SCHOOL, Dardha, Baikatpur, Jalalpur, Muzaffarpur, **Bihar 843132** (Name & Address of the school) on 11.05.2026 date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **One year**

Signature with Seal:

Name :

Designation:

CHEMIST
R.W.T.L; MUZAFFARPUR

To

The Principal,

K. C MOUNT FORT SCHOOL,

Dardha, Baikatpur, Jalalpur,

Muzaffarpur, **Bihar 843132**

Rajaneerayan Trivedi

School Manager
KC MOUNT FORT SCHOOL
Dardha, Baikatpur, Jalalpur
MUZAFFARPUR-19
Bihar

Shalini Pandey
Principal

KC MOUNT FORT SCHOOL
Dardha, Baikunthpur
Muzaffarpur-843119

PUBLIC HEALTH ENGINEERING DEPARTMENT
Regional Water Testing Laboratory

District Name : Muzaffarpur

Month -May 2026

Sl. No.	Block	Panchayat	Village	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	NO ₃	F	As	MPN	Remarks
1	Mushari	Madhopur	Baikatpur	14	K.C MOUNT FORT SCHOOL	7.12	1	410	289	196	10.4	12.12	24	142	0.15	15	5	0.2	BDL	NIL	
Acceptable Limit (IS 10500-2012)						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	45 mg/l	1.0 ppm	0.01 ppm	0.01 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)						NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	1.5 ppm	NR	0.1 mg/l	

[Signature]
Chemist
R.W.T.L. MUZAFFARPUR

Ryaneeswari Devi
 School Manager
 KC MOUNT FORT SCHOOL
 Dardha, Baikatpur, Jalalpur
 MUZAFFARPUR-19
 Bihar

Madhuri Pandey
 Principal
 KC MOUNT FORT SCHOOL
 Dardha, Baikatpur, Jalalpur
 MUZAFFARPUR-843101
 Bihar