

FORM OF APPLICATION UNDER SUB-SECTION (1) SUB SECTION (2)
OF SECTION 4 OF THE CHENNAI PUBLIC BUILDINGS ACT (LICENSING)
ACT 1965 (CHENNAI ACT 13 OF 1965) REFERED TO IN RULE 3 OF THE
CHENNAI PUBLIC BUILDINGS (LICENSING) RULES 1966.

Ref No.225/GMA

From: The Secretary,
SACRED HEART MATRIC.HR.SEC.SCHOOL
No.R-30, III Block, 61st Street, Muthamizh
Nagar, Kodungaiyur, Phase-II,
Chennai – 600 118.

To: The Collector of Chennai
Rajaji Salai, Chennai – 1.

1. I intend to use the buildings / to continue to use the existing public building to use the existing building not at present use at a public building which is situated in the site or plot of land, No.R-30, III Block, 61st Street, Muthamizh Nagar, Kodungaiyur, Phase-II, Chennai – 600 118. for the period of 01.05.2022 to 30.04.2025 (three) Years and
2. The year of construction and the present approximate construction and purpose for which it is to be used or is being used as public buildings are also furnished in the statement accompanying this application.
3. I enclose a challan for Rs.
4. I also enclose a certificate of structural soundness in the prescribed form furnished by the engineer
Mr.G.MOHANDAS

I have enclosed the certificate of structural soundness from an Engineer.

Dated: 22/04/22

R. Gnanambigai
Signature of the owner of the
Building

Enclosures:

- 1.Statement
 - 2.Challan For Rs
- towards the application.

STATEMENT ACCOMPANYING FORM -A

1. Door Number of the building : Door No.R-30
2. Location (Street No, ward No, Name Panchayat union/ Township/Cantonment) : III Block, 61st Street, Muthamizh Nagar, Kodungaiyur Phase II, Chennai – 600 118.
3. Year of construction : Block I: 1996 & 2000
Block II: 2005
4. Approximate cost of construction : Rs.24,00,000/-
5. Purpose for which the building is being used Or proposed to be used : School building
6. Purpose for which the building has hitherto Been used. : School building
7. Details of construction of the building (particulars) Of the foundation, soil, specification of the Various parts as under :
 - (a) Foundation : RCC Column Foundation
 - (b) Basement : RCC Beam and Brick Work with CM
 - (c) Superstructure..... floor and roof : RCC Framed Structure & Load Bearing in Masonry Cement Flooring.
8. Period for which the license is required : 01.05.2022 to 30.04.2025
(three years)
Carpet area :
Block I : 8573 sft
Block II : 1197 sft
Total : 9770 sft
9. Number of the persons to be accommodated : 977 Nos

Dated:

Signature of the owner of the building

Signature of the engineer

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India),
C.Eng., FIV, MIGS, MICA, MICI, MACCE,
Panel Engineer (Class-I), S.E.P.W.D.V2-57970 2006/08-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.

CERTIFIED that no thatched buildings are used for conducting any classes for school premises. If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that I /We are aware that our license will be cancelled.

R. Gnanambigai
Signature of the owner of the building

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICI, MACCE,
Chartered Valuation Surveyor

Flat No.FF1,G.M.T.Enclave,Plot No.1248,
Golden Colony, Anna Nagar West Extn,
Chennai - 600 050.
Ph : 2625 1022 Mobile: 9444407539
Email:mohandasgovindarajan@gmail.com

FORM B

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB-SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 1 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC (LICENCING) RULES, 1966.

I certify that the building of **SACRED HEART MATRIC.HR.SEC.SCHOOL, No.R-30, III Block, 61st Street, Muthamizh Nagar, Kodungalyur, Phase-II, Chonnal - 600 118.** was inspected on 01.04.2022 Mentioned in the Statement below. I Have Satisfied myself that the building structurally sound to be used as a public building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian standards IS: 895. The scope of this Stability Certificate is limited only to the structural soundness of the building as per IS:456 -1978; this does not include the eventualities caused by natural calamities like cyclone, earth quakes, high gales & Storm, lightening, floods, fire etc., A license may be granted for period from **01.05.2022 to 30.04.2025 (Throo Years)**. Certified that no thatched buildings are used for conducting and classes in the school Premises as on the date of inspection.


Signature of the engineer

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C.Eng., FIV, MIGS, MICA, MICI, MACCE,
Panel Engineer Class-I, S.E.P.W.D.V2 57970 2006/08-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.
E Mail : mohandasgovindarajan@gmail.com
Web : www.mohandasassociates.com

If any thatched building are constructed after the issue of this license, we are held responsible for any life accident that occurs later and that we are aware that out license will be cancelled.


Signature of the owner of the building

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICE, MACCE,
Chartered Valuation Surveyor

Flat No FF1/3 M.T Enclave, Plot No 1248,
Golden Colony, Anna Nagar West Extn,
Chennai - 600 072.
Ph : 2625 1022 Mobile: 9444407539
Email:mohandasgovindarajan@gmail.com

FORM G

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB-SECTION (4) OF SECTION 4 OF
THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1966 (TAMILNADU ACT 1 OF 1966)
REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC (LICENSING) RULES, 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation

- | | | |
|--|---|--------------------|
| (i) Depth below ground level | : | 1.83 M |
| (ii) Nature of the soil set out in the Foundation level | : | Gravel soil |
| (iii) Pressure at foundation | : | 15.0 Tonnes / Sq.m |
| (iv) Probable safe bearing capacity of the strata met with at foundation | : | 20.0 Tonnes /Sq.m |

2. Super structure

- | | | |
|---|---|-------------|
| (i) Maximum stress in the most Critical section of the masonry and concrete | : | 40 Kg/Sq.Cm |
| (ii) nature of masonry and concrete and its safe permissible stress | : | 60 Kg/Sqcm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 895 (latest version) and other relevant Indian Standard Code of Practices and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for a period from 01.05.2022 to 30.04.2025. (three years).

Dated

Signature of the engineer

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICE, MACCE,
Panel Engineer (Gr: I), SI PWD VT-579/02906/02-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.
Ph: 944-43867747 / 2625 1022 Mobile: 9444407539
E Mail : mohandasgovindarajan@gmail.com
Web : www.mohandasassociates.com

G. MOHANDAS. MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICI, MACCE,
Chartered Valuation Surveyor

Flat No.FF1,G.M.T.Enclave,Plot No.1248,
Golden Colony, Anna Nagar West Extn,
Chennai - 600 050.
Ph : 2625 1022 Mobile: 9444407539
EMail:mohandasgovindarajan@gmail.com

FORM C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB-SECTION (4) OF SECTION 4 OF
THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 1 OF 1965)
REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC (LICENCING) RULES, 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation

- | | | |
|--|---|--------------------|
| (i) Depth below ground level | : | 1.83 M |
| (ii) Nature of the soil set out in the Foundation level | : | Gravel soil |
| (iii) Pressure at foundation | : | 15.0 Tonnes / Sq.m |
| (iv) Probable safe bearing capacity of the strata met with at foundation | : | 20.0 Tonnes /Sq.m |

2. Super structure

- | | | |
|---|---|-------------|
| (i) Maximum stress in the most Critical section of the masonry and concrete | : | 40 Kg/Sq.Cm |
| ii) nature of masonry and concrete and its safe permissible stress | : | 60 Kg/Sqcm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 895 (latest version) and other relevant Indian Standard Code of Practices and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for a period from 01.05.2022 to 30.04.2025. (three years).

Dated

Signature of the engineer

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C.Eng., FIV, MIGS, MICA, MICI, MACCE,
Panel Engineer Class-I, S.E.PWD V2-57970 2006/08-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.
Ph: 044-43867747 / 2625 1022 Mobile: 9444407539
E Mail : mohandasgovindarajan@gmail.com
Web : www.mohandasassociates.com

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICI, MACCE,
Chartered Valuation Surveyor

Flat No.FF1,G.M.T.Enclave,Plot No.1248,
Golden Colony, Anna Nagar West Extn,
Chennai - 600 050.
Ph : 2625 1022 Mobile: 9444407539
EMail:mohandasgovindarajan@gmail.com

FORM E

**FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB-SECTION (4) OF SECTION 4 OF
THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 1 OF 1965)
REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC (LICENCING) RULES, 1966.**

1. Name and designation of inspecting authority : Mr.G.MOHANDAS, B.E. (Civil) M.I.E.
Or officer appointed or having jurisdiction under FIV, MIGS, MICA, MICI, MACCE
any other act or law. Panel Engineer - Class I
Flat No.FF1, GMT Enclave, Plot
No.1248, Golden Colony, Anna Nagar
West Extn, Chennai - 600 050.
Ph: 2625 1022/ 23 Mobile: 94444 07539
2. Location of the building inspected : Sacred Heart Matriculation
D.No., Street No. Name of the Place Hr.Sec School,
i.e, Municipal Corporation / Municipality No.R-30, III Block, 61st Street,
Panchayat / Panchayat Union / Township Muthamizh Nagar, Kodungaiyur,
Cantonment Phase -II, Chennai - 600 118.
3. Date of Inspection : 01.04.2022
4. Purpose for Which the building is used : Educational
5. Nature of Defects noticed : Nil
6. Suggestion for rectifying defects : Not Applicable
7. If in a dangerous condition Immediate action recommended to Be taken : Not applicable

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C.Eng., FIV, MIGS, MICA, MICI, MACCE,
Panel Engineer (Class I), SI PW D. 82 57570 2006/03-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.
Ph: 044-43867747 / 2625 1022 Mobile: 9444407539
E Mail : mohandasgovindarajan@gmail.com
Web : www.mohandasassociates.com

G. MOHANDAS . MRICS (London)
B.E.Civil , M.Sc (Real Estate Val),M.I.E. (India)
C. Eng., FIV, MIGS, MICA, MICI, MACCE,
Chartered Valuation Surveyor

Flat No.FF1,G.M.T.Enclave,Plot No.1248,
Golden Colony, Anna Nagar West Extn,
Chennai - 600 050.
Ph : 2625 1022 Mobile: 9444407539
EMailmohandasgovindarajan@gmail.com

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building -Door No. Street name & Name Of the place	Age of the building	Value of the the building	No. of story's	Short description of structure, steel RCC framed, or load bearing masonry
(1)	(2)	(3)	(4)	(5)
Sacred Heart Matric. Hr.Sec.School No.R-30, III Block, 61st Street, Muthamizh Nagar, Kodungaiyur, Chennai - 600 118	Block I : 26 Years & 22 Years Block II : 17 Years	Rs.24,00,000/-	G+1	RCC Column Foundation RCC Beam and Brick Work, With CM, RCC Framed & Load Bearing in Masonry , cement flooring
Purpose for which The building is Certified for use	The period for which the building will be structurally sound	No of persons to be accommodated	Remarks	
(6)	(7)	(8)	(9)	
School Building	01.05.2022 To 30.04.2025	977 Nos	Building is structurally sound	

Signature of the Engineer

G. MOHANDAS, MRICS (London)
B.E.Civil, M.Sc (Real Estate Val), M.I.E. (India)
C.Eng., FIV, MIGS, MICA, MICI, MACCE,
Panel Engineer Class-I, S E PWD V2-57970 2006/08-12-2001
Flat No. FF1, G.M.T. Enclave, Plot No. 1248,
Golden Colony, Anna Nagar West Extn, Chennai-50.
Ph: 044-43867747 / 2625 1022 Mobile: 9444407539
E Mail : mohandasgovindarajan@gmail.com
Web : www.mohandasassociates.com