

RP190403005

NH ELAP Accreditation #NH1005

Maine State Certification #NH01005

Vermont State Certification #VT1005

Maine Radon Certification #ME17500

NEELSON ANALYTICAL LAB

Eastside

490 East Industrial Park Drive

Manchester, NH 03109

www.nelsonanalytical.com

(603)622-0200

Report of Analysis

Customer: Alpha-Bits Learning Center- Lisa Schroder
 Client Sample ID: Alpha-Bits Learning Center
 Laboratory ID: 119032344.01
 Sample Matrix : Drinking Water
 Sample Location: Sample 01 - Powderpuff Room Food Prep Sink

Date Collected: 03/26/2019 06:00 AM
 Collected By: Customer
 Date Received: 03/26/2019 09:15 AM
 Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
 Client Sample ID: Alpha-Bits Learning Center
 Laboratory ID: 119032344.02
 Sample Matrix : Drinking Water
 Sample Location: Sample 02 - Huggable Room Food Prep Sink

Date Collected: 03/26/2019 06:05 AM
 Collected By: Customer
 Date Received: 03/26/2019 09:15 AM
 Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
 Client Sample ID: Alpha-Bits Learning Center
 Laboratory ID: 119032344.03
 Sample Matrix : Drinking Water
 Sample Location: Sample 03 - Gumbdrop Room Food Prep Sink

Date Collected: 03/26/2019 06:10 AM
 Collected By: Customer
 Date Received: 03/26/2019 09:15 AM
 Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
 Client Sample ID: Alpha-Bits Learning Center
 Laboratory ID: 119032344.04
 Sample Matrix : Drinking Water
 Sample Location: Sample 04 - Knee High Room Food Prep Sink

Date Collected: 03/26/2019 06:15 AM
 Collected By: Customer
 Date Received: 03/26/2019 09:15 AM
 Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
 Client Sample ID: Alpha-Bits Learning Center
 Laboratory ID: 119032344.05
 Sample Matrix : Drinking Water
 Sample Location: Sample 05 - Crumbcrunchers Room Food Prep Sink

Date Collected: 03/26/2019 06:20 AM
 Collected By: Customer
 Date Received: 03/26/2019 09:15 AM
 Temperature Rec'd °C: #20



Notes: mg/l=ppm; ug/l=pb; "<" denotes "less than"; "ND"= Not detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the website listed below. Sampling performed by the lab is according to the lab document "Water Sampling Procedures". EPA standards for pH & Chlorine as total parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. * Samples received at laboratory do not meet method specified temperature criteria. Subcontracting Laboratory: SUE2-NH2018(EPA-ME00015) SUE3-NH1004(EPA-NH00015) SUE4-NH1004(EPA-NH00015) SUE5-NH2018 SUE6-NH2018 SUE7-NH1007 SUE8-NH126 method specified temperature criteria. Subcontracting Laboratory: SUE2-NH2018(EPA-ME00015) SUE3-NH1004(EPA-NH00015) SUE4-NH1004(EPA-NH00015) SUE5-NH2018 SUE6-NH2018 SUE7-NH1007 SUE8-NH126



Notes: mg/l-ppm; ug/l-ppb; < denotes less than; ND= Non-detect. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the website listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Make samples may be analyzed the same day they are received. If sample(s) received at laboratory do not meet method specified temperature criteria. Subcooling information: SU82-MH2012/EPA-MH00015; SU83-MH2012/EPA-MH00015; SU84-MH2012/EPA-MH00015; SU85-MH2012/EPA-MH00015; SU86-MH2012/EPA-MH00015; SU87-MH2012/EPA-MH00015; SU88-MH2012/EPA-MH00015; SU89-MH2012/EPA-MH00015; SU90-MH2012/EPA-MH00015; SU91-MH2012/EPA-MH00015; SU92-MH2012/EPA-MH00015; SU93-MH2012/EPA-MH00015; SU94-MH2012/EPA-MH00015; SU95-MH2012/EPA-MH00015; SU96-MH2012/EPA-MH00015; SU97-MH2012/EPA-MH00015; SU98-MH2012/EPA-MH00015; SU99-MH2012/EPA-MH00015; SU00-MH2012/EPA-MH00015. <http://www.maine.gov/dhhs/mecdh/environmenal-health/vwp/professionals/abccert.shtml>

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.09							
Sample Matrix : Drinking Water							
Sample Location: Sample 09 - Buttery Room Sink							
Date Collected: 03/26/2019 06:40 AM							
Collected By: Customer							
Date Received: 03/26/2019 09:15 AM							
Temperature Rec'd °C: #20							
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.08							
Sample Matrix : Drinking Water							
Sample Location: Sample 08 - Munchkin Room Sink							
Date Collected: 03/26/2019 06:35 AM							
Collected By: Customer							
Date Received: 03/26/2019 09:15 AM							
Temperature Rec'd °C: #20							
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.07							
Sample Matrix : Drinking Water							
Sample Location: Sample 07 - Peanut Room Food Prep Sink							
Date Collected: 03/26/2019 06:30 AM							
Collected By: Customer							
Date Received: 03/26/2019 09:15 AM							
Temperature Rec'd °C: #20							
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.06							
Sample Matrix : Drinking Water							
Sample Location: Sample 06 - Potytrain Room Food Prep Sink							
Date Collected: 03/26/2019 06:25 AM							
Collected By: Customer							
Date Received: 03/26/2019 09:15 AM							
Temperature Rec'd °C: #20							
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.06							
Sample Matrix : Drinking Water							
Sample Location: Sample 06 - Potytrain Room Food Prep Sink							
Date Collected: 03/30/2019 06:30							
Collected By: Customer							
Date Received: 03/26/2019 09:15 AM							
Temperature Rec'd °C: #20							
Customer: Alpha-Bits Learning Center- Lisa Schroder							
Client Sample ID: Alpha-Bits Learning Center							
Laboratory ID: 119032344.06							
Sample Matrix : Drinking Water							
Sample Location: Sample 06 - Potytrain Room Food Prep Sink							

Report of Analysis

NH ELAP Accreditation #NH1005
Maine State Certification #NH01005
Vermont State Certification #VT1005
Maine Radon Certification #ME17500

490 East Industrial Park Drive
Manchester, NH 03109
www.nelsonanalytical.com
(603)622-0200

NELSON ANALYTICAL LAB

RP190403005

RP190403005

NH ELAP Accreditation #NH1005
Maine State Certification #NH01005
Vermont State Certification #VT1005
Maine Radon Certification #ME17500

NELSON ANALYTICAL LAB

490 East Industrial Park Drive
Manchester, NH 03109
www.nelsonanalytical.com
(603)622-0200

Report of Analysis

Client Sample ID: Alpha-Bits Learning Center
Laboratory ID: 119032344.10
Sample Matrix: Drinking Water
Sample Location: Sample 10 - Fluffernutter Room Sink
Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
Client Sample ID: Alpha-Bits Learning Center
Laboratory ID: 119032344.11
Sample Matrix: Drinking Water
Sample Location: Sample 11 - Busy Bee Room Sink
Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
Client Sample ID: Alpha-Bits Learning Center
Laboratory ID: 119032344.12
Sample Matrix: Drinking Water
Sample Location: Sample 12 - Jumping Bean Room Sink
Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Customer: Alpha-Bits Learning Center- Lisa Schroder
Client Sample ID: Alpha-Bits Learning Center
Laboratory ID: 119032344.13
Sample Matrix: Drinking Water
Sample Location: Sample 13 - Gingersnap Room Food Prep Sink
Temperature Rec'd °C: #20

Parameters	Results	Acceptable Level	Units	Date Analyzed	Test Method	Test Type	Test Remarks
Lead	<0.001	0.015	mg/L	03/30/2019 06:30	EPA 200.8	Primary	Within EPA Standard

Test Types: EPA Primary: Regulated by the EPA as a health related parameter
EPA Secondary: Aesthetic parameter - not regarded as a health concern
Respectfully Submitted



Notes: mg/l-ppm; ug/l-ppb; < denotes "less than"; ND= Non-detected. This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Customer Supplied information is the sample location, date, time, sampler and tests requested. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the website listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions", EPA standards list pH & thorne as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the end for the analysis. Samples will be analyzed as quickly as laboratory operators allow. Means samples may be analyzed the same day they are received. #=sample(s) received at laboratory do not meet method specified temperature criteria. Successful information: S182=NH018(EPA-M50015), S183=NH100(EPA-M400035), S184=NH273, S185=NH250, S186=NH124, ME100035, S187=NH107, S188=NH126, http://des.nh.gov/organization/divisions/water/dwg/mhebp/http://healthvermont.gov/enviro/pt_lab/publichealthlaboratory.aspxhttp://www.maine.gov/dhs/mecdc/environmental-health/dwg/professionals/labccr.shtml