City of Cadillac – Utilities Department – Laboratory Services

State of Michigan Certified Drinking Water Lab #1030

Official Laboratory Report

Client: Rose Lake Forest POA
PO Box 64
Leroy MI 49656

Report Date: 5/19/2026
Project # : 260518.07

Sample ID: Bathroom Sink, Rambeau Park Beach Well, 18 Mile Rd, Leroy
Sampled By: Ann Catchick
Sample Date: 5/17/2026 9:00

PWSID: N/A
Purpose: Other
Startup #1

Parameter	Result	Date Tested	Method	Analyst	RL	MCL	Units
Total Coliform	Negative	5/18/2026 11:56	SM 9223 B Colilert-18	EAS	--	--	per 100 mL
E. Coli	Negative	5/18/2026 11:56	SM 9223 B Colilert-18	EAS	--	--	per 100 mL

Sample Received: 5/18/2026 9:47 8.6 °C (sufficient ice/icepack to start the cooling process)
Sample Comments: Sample received at lab greater than 24 hours from collection time

Sample ID: Bathroom Sink, Rambeau Park Beach Well, 18 Mile Rd, Leroy
Sampled By: Ann Catchick
Sample Date: 5/18/2026 9:05

PWSID: N/A
Purpose: Other
Startup #2

Parameter	Result	Date Tested	Method	Analyst	RL	MCL	Units
Total Coliform	Negative	5/18/2026 11:56	SM 9223 B Colilert-18	EAS	--	--	per 100 mL
E. Coli	Negative	5/18/2026 11:56	SM 9223 B Colilert-18	EAS	--	--	per 100 mL

Sample Received: 5/18/2026 9:47 8.6 °C (sufficient ice/icepack to start the cooling process)
Sample Comments:

RL = Reporting Limit; lowest concentration of standard used for calibration
MCL = Maximum Contaminant Limit; highest amount of a contaminant allowed in drinking water

Any questions should be directed to Laboratory Services at (231) 775-2368.

Reviewed By:

Date: 5/19/2026