

## WATER TESTING FOR GAMMA AND RAMBEAU PARKS

Hello Association Members,

Please see water well test results for Gamma Park and the Rambeau Park (Beach Well) from the fall of 2025. Our 1st quarter 2026 Gamma Park well water test sample was drawn today 3-31-26. Rambeau Park remains a "seasonal well" and will be tested twice this Spring before opening the well for use after it has been chlorinated per the State of Michigan Clean Water Act regulations regarding seasonal wells

Thank You,

RLFPOA Board

# Great Lakes Water Quality Laboratory, Inc.

10/27/2025

**Email:**  
becky@greatlakeswaterlab.net

6461 Sunset Dr  
P O Box 131  
Lake Ann MI 49650

**Ph:** 231-275-7382  
**Fax:** 231-275-6510

**MI Dept. of Env. Quality Lab No:** 0091

## Laboratory Report

**For:** Rose Lake Forest Property Associatio  
PB Box 64  
Leroy MI 49655  
231-421-7834

**Site:** Gamma Park Well/RLFPOA  
  
Leroy MI 49655

**WSSN:**  
**County:** Osceola  
**Township:**

**Point of Collection:** Bathroom Faucet

**District:** Central Michigan District Health Department

**Potable?** Y

**Well Number:**

**Lab ID:** 251013001

**Collected By:** James Smith  
**Date:** 10/12/2025  
**Time:** 4:00pm

**Received On:**  
**Date:** 10/13/2025  
**Time:** 2:00pm

**Reason for Test:** Routine Monitoring

<u>Date/Time Tested</u>	<u>Analyte</u>	<u>Test Result</u>	<u>Suggested Max Contaminant Level</u>	<u>Detection Limit</u>	<u>Units</u>
10/13/2025 06:00p	T Total Coliform	ABS	<1	0	CFU/100mL
10/13/2025 06:00p	E.coli E.coli	ABS	<1	0	CFU/100mL
ABS = Absent of Total Coliform and E Coli Analyst SM					
10/14/2025 06:00a	N03 Nitrate	<1.0	10.0	1.00	mg/L
10/14/2025 06:00p	N02 Nitrite	<0.05	1.00	0.05	mg/L
Analyst BG					

**Sample Comments:**

Bacteriological analysis SM9223  
Nitrate analysis SM 4500 NO3-D  
Nitrite analysis SM 4500 NO2-B

ND = Not Detected; CR = Chlorine Residual

# Great Lakes Water Quality Laboratory, Inc.

10/27/2025

Email:  
becky@greatlakeswaterlab.net

6461 Sunset Dr  
P O Box 131  
Lake Ann MI 49650

Ph: 231-275-7382  
Fax: 231-275-6510

MI Dept. of Env. Quality Lab No: 0091

## Laboratory Report

For: Rose Lake Forest Property Associatio  
PB Box 64  
Leroy MI 49655  
231-421-7834

**Site:** Beach Well/RLFPOA  
Leroy MI 49655

**WSSN:**  
**County:** Osceola  
**Township:**

**Point of Collection:** Bathroom Faucet

**District:** Central Michigan District Health Department

**Potable?** Y

**Well Number:**

**Lab ID:** 251013002

**Collected By:** James Smith  
**Date:** 10/12/2025  
**Time:** 4:00pm

**Received On:**  
**Date:** 10/13/2025  
**Time:** 2:00pm

**Reason for Test:** Routine Monitoring

<u>Date/Time Tested</u>	<u>Analyte</u>	<u>Test Result</u>	<u>Suggested Max Contaminant Level</u>	<u>Detection Limit</u>	<u>Units</u>
10/13/2025 04:00p	T Total Coliform	ABS	<1	0	CFU/100mL
10/13/2025 04:00p	E.coli E.coli	ABS	<1	0	CFU/100mL
ABS = Absent of Total Coliform and E Coli					
Analyst SM					
10/13/2025 04:00p	N03 Nitrate	3.3	10.0	1.00	mg/L
10/13/2025 04:00p	N02 Nitrite	<0.05	1.00	0.05	mg/L
Analyst BG					

**Sample Comments:**

Bacteriological analysis SM9223  
Nitrate analysis SM 4500 NO3-D  
Nitrite analysis SM 4500 NO2-B

ND = Not Detected; CR = Chlorine Residual