

Client Sample Results

Client: Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-95594-2

Client Sample ID: CENTRE-FINISHED

Lab Sample ID: 280-95594-3

Date Collected: 04/05/17 09:50

Matrix: Water

Date Received: 04/06/17 10:25

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.13		0.019	0.0078	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorobutanoic acid (PFBA)	0.031		0.019	0.0093	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorodecane sulfonate (PFDS)	0.0086	U	0.019	0.0086	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorodecanoic acid (PFDA)	0.0074	U	0.019	0.0074	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorododecanoic acid (PFDoA)	0.014	U	0.028	0.014	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluoroheptanoic acid (PFHpA)	0.028		0.028	0.012	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorohexane Sulfonate (PFHxS)	0.0066	U	0.028	0.0066	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorohexanoic acid (PFHxA)	0.059		0.019	0.0027	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorononanoic acid (PFNA)	0.016	U	0.038	0.016	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorooctanoic acid (PFOA)	0.052		0.019	0.0092	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorooctane Sulfonate (PFOS)	0.064		0.028	0.013	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluoropentanoic acid (PFPA)	0.093		0.028	0.010	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorotetradecanoic acid (PFTeA)	0.014	U	0.028	0.014	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluorotridecanoic Acid (PFTriA)	0.017	U	0.038	0.017	ug/L		04/10/17 11:12	04/13/17 05:21	1
Perfluoroundecanoic acid (PFUnA)	0.0065	U	0.019	0.0065	ug/L		04/10/17 11:12	04/13/17 05:21	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	119		60 - 155				04/10/17 11:12	04/13/17 05:21	1
13C8 PFOS	128		45 - 130				04/10/17 11:12	04/13/17 05:21	1

Method: PFC -FOSA - FOSA in Water (LC/MS/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctane Sulfonamide (FOSA)	0.0054	U	0.048	0.0054	ug/L		04/10/17 11:08	04/13/17 01:52	1