

# Client Sample Results

TestAmerica Job ID: 280-113248-1

Client: Alabama Dept. Environmental Management  
 Project/Site: ADEM PFC Sampling Water - Centre

Lab Sample ID: 280-113248-1  
 Matrix: Water

Client Sample ID: CENTRE-FINISHED

Date Collected: 08/15/18 11:50

Date Received: 08/16/18 09:25

**Method: DV-LC-0012 - Fluorinated Alkyl Substances**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.12		0.017	0.0071	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorobutanoic acid (PFBA)	0.017		0.017	0.0084	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorodecane sulfonate (PFDS)	0.0079	U	0.017	0.0079	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorodecanoic acid (PFDA)	0.0073	J	0.017	0.0067	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.026	0.013	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluoroheptanoic acid (PFHpA)	0.015	J	0.026	0.011	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorohexane Sulfonate (PFHxS)	0.0060	U	0.026	0.0060	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorohexanoic acid (PFHxA)	0.033		0.017	0.0025	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorononanoic acid (PFNA)	0.015	U	0.034	0.015	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorooctanoic acid (PFOA)	0.028		0.017	0.0084	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorooctane Sulfonate (PFOS)	0.060		0.026	0.011	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluoropentanoic acid (PFPA)	0.066		0.026	0.0094	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorotetradecanoic acid (PFTeA)	0.013	U	0.026	0.013	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluorotridecanoic Acid (PFTriA)	0.015	U	0.034	0.015	ug/L		08/24/18 22:08	08/27/18 17:32	1
Perfluoroundecanoic acid (PFUnA)	0.0059	U	0.017	0.0059	ug/L		08/24/18 22:08	08/27/18 17:32	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
13C8 PFOA	86		60 - 155				08/24/18 22:08	08/27/18 17:32	1
13C8 PFOS	98		45 - 130				08/24/18 22:08	08/27/18 17:32	1

TestAmerica Denver