

Client Sample Results

Client: Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-113741-1

Client Sample ID: Centre-Finished

Lab Sample ID: 280-113741-1

Date Collected: 08/28/18 11:50

Matrix: Water

Date Received: 08/29/18 09:00

Method: DV-LC-0012 - Fluorinated Alkyl Substances

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.10		0.017	0.0071	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorobutanoic acid (PFBA)	0.021		0.017	0.0085	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorodecane sulfonate (PFDS)	0.0079	U	0.017	0.0079	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorodecanoic acid (PFDA)	0.0068	U	0.017	0.0068	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.026	0.013	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluoroheptanoic acid (PFHpA)	0.014	J	0.026	0.011	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorohexane Sulfonate (PFHxS)	0.0060	U	0.026	0.0060	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorohexanoic acid (PFHxA)	0.034		0.017	0.0025	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorononanoic acid (PFNA)	0.015	U	0.035	0.015	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorooctanoic acid (PFOA)	0.033		0.017	0.0085	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorooctane Sulfonate (PFOS)	0.049		0.026	0.012	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluoropentanoic acid (PFPA)	0.059		0.026	0.0095	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorotetradecanoic acid (PFTeA)	0.013	U	0.026	0.013	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluorotridecanoic Acid (PFTriA)	0.015	U	0.035	0.015	ug/L		09/04/18 19:55	09/07/18 01:22	1
Perfluoroundecanoic acid (PFUnA)	0.0060	U	0.017	0.0060	ug/L		09/04/18 19:55	09/07/18 01:22	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOA	88		60 - 155	09/04/18 19:55	09/07/18 01:22	1
13C8 PFOS	100		45 - 130	09/04/18 19:55	09/07/18 01:22	1