

Client Sample Results

Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-100119-2

Client Sample ID: CENTRE-FINISHED

Lab Sample ID: 280-100119-3

Date Collected: 08/09/17 11:15

Matrix: Water

Date Received: 08/10/17 08:35

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.075		0.020	0.0084	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorobutanoic acid (PFBA)	0.017	J	0.020	0.010	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorodecane sulfonate (PFDS)	0.0094	U	0.020	0.0094	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorodecanoic acid (PFDA)	0.0080	U	0.020	0.0080	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorododecanoic acid (PFDoA)	0.015	U	0.031	0.015	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluoroheptanoic acid (PFHpA)	0.014	U	0.031	0.014	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorohexane Sulfonate (PFHxS)	0.0071	U	0.031	0.0071	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorohexanoic acid (PFHxA)	0.036		0.020	0.0030	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorononanoic acid (PFNA)	0.018	U	0.041	0.018	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorooctanoic acid (PFOA)	0.029		0.020	0.010	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorooctane Sulfonate (PFOS)	0.053		0.031	0.014	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluoropentanoic acid (PFPA)	0.059		0.031	0.011	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorotetradecanoic acid (PFTeA)	0.015	U	0.031	0.015	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluorotridecanoic Acid (PFTriA)	0.018	U	0.041	0.018	ug/L		08/15/17 09:04	08/16/17 15:55	1
Perfluoroundecanoic acid (PFUnA)	0.0071	U	0.020	0.0071	ug/L		08/15/17 09:04	08/16/17 15:55	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	106		60 - 155				08/15/17 09:04	08/16/17 15:55	1
13C8 PFOS	93		45 - 130				08/15/17 09:04	08/16/17 15:55	1

Client Sample ID: CENTRE-PILOT-PRE

Lab Sample ID: 280-100119-4

Date Collected: 08/09/17 11:20

Matrix: Water

Date Received: 08/10/17 08:35

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.093		0.021	0.0086	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorobutanoic acid (PFBA)	0.019	J	0.021	0.010	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorodecane sulfonate (PFDS)	0.0096	U	0.021	0.0096	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorodecanoic acid (PFDA)	0.0082	U	0.021	0.0082	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorododecanoic acid (PFDoA)	0.016	U	0.031	0.016	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluoroheptanoic acid (PFHpA)	0.017	J	0.031	0.014	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorohexane Sulfonate (PFHxS)	0.0073	U	0.031	0.0073	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorohexanoic acid (PFHxA)	0.041		0.021	0.0030	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorononanoic acid (PFNA)	0.018	U	0.042	0.018	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorooctanoic acid (PFOA)	0.036		0.021	0.010	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorooctane Sulfonate (PFOS)	0.064		0.031	0.014	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluoropentanoic acid (PFPA)	0.070		0.031	0.011	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorotetradecanoic acid (PFTeA)	0.015	U	0.031	0.015	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluorotridecanoic Acid (PFTriA)	0.019	U	0.042	0.019	ug/L		08/15/17 09:04	08/16/17 16:07	1
Perfluoroundecanoic acid (PFUnA)	0.0072	U	0.021	0.0072	ug/L		08/15/17 09:04	08/16/17 16:07	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	104		60 - 155				08/15/17 09:04	08/16/17 16:07	1
13C8 PFOS	99		45 - 130				08/15/17 09:04	08/16/17 16:07	1

TestAmerica Denver