

Client Sample Results

Client: Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-106226-1

Client Sample ID: CENTRE-RAW

Lab Sample ID: 280-106226-1

Date Collected: 02/06/18 08:00

Matrix: Water

Date Received: 02/08/18 09:10

Method: DV-LC-0012 - Fluorinated Alkyl Substances									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.11		0.021	0.0085	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorobutanoic acid (PFBA)	0.019	J	0.021	0.010	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorodecane sulfonate (PFDS)	0.0095	U	0.021	0.0095	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorodecanoic acid (PFDA)	0.0081	U	0.021	0.0081	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorododecanoic acid (PFDoA)	0.015	U	0.031	0.015	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluoroheptanoic acid (PFHpA)	0.020	J	0.031	0.014	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorohexane Sulfonate (PFHxS)	0.0072	U	0.031	0.0072	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorohexanoic acid (PFHxA)	0.047		0.021	0.0030	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorononanoic acid (PFNA)	0.018	U	0.041	0.018	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorooctanoic acid (PFOA)	0.036		0.021	0.010	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorooctane Sulfonate (PFOS)	0.036		0.031	0.014	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluoropentanoic acid (PFPA)	0.069		0.031	0.011	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorotetradecanoic acid (PFTeA)	0.015	U	0.031	0.015	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluorotridecanoic Acid (PFTriA)	0.018	U	0.041	0.018	ug/L		02/12/18 09:45	02/13/18 18:16	1
Perfluoroundecanoic acid (PFUnA)	0.0071	U	0.021	0.0071	ug/L		02/12/18 09:45	02/13/18 18:16	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	91		60 - 155				02/12/18 09:45	02/13/18 18:16	1
13C8 PFOS	88		45 - 130				02/12/18 09:45	02/13/18 18:16	1

Lab Sample ID: 280-106226-2

Client Sample ID: CENTRE-FINISHED

Date Collected: 02/07/18 11:15

Matrix: Water

Date Received: 02/08/18 09:10

Method: DV-LC-0012 - Fluorinated Alkyl Substances									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.094		0.021	0.0085	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorobutanoic acid (PFBA)	0.014	J	0.021	0.010	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorodecane sulfonate (PFDS)	0.0095	U	0.021	0.0095	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorodecanoic acid (PFDA)	0.0081	U	0.021	0.0081	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorododecanoic acid (PFDoA)	0.015	U	0.031	0.015	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluoroheptanoic acid (PFHpA)	0.014	U	0.031	0.014	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorohexane Sulfonate (PFHxS)	0.0072	U	0.031	0.0072	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorohexanoic acid (PFHxA)	0.031		0.021	0.0030	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorononanoic acid (PFNA)	0.018	U	0.041	0.018	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorooctanoic acid (PFOA)	0.026		0.021	0.010	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorooctane Sulfonate (PFOS)	0.033		0.031	0.014	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluoropentanoic acid (PFPA)	0.047		0.031	0.011	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorotetradecanoic acid (PFTeA)	0.015	U	0.031	0.015	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluorotridecanoic Acid (PFTriA)	0.018	U	0.041	0.018	ug/L		02/12/18 09:45	02/13/18 18:29	1
Perfluoroundecanoic acid (PFUnA)	0.0071	U	0.021	0.0071	ug/L		02/12/18 09:45	02/13/18 18:29	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	90		60 - 155				02/12/18 09:45	02/13/18 18:29	1
13C8 PFOS	94		45 - 130				02/12/18 09:45	02/13/18 18:29	1

TestAmerica Denver