

Client Sample Results

Client: Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-105644-1

Client Sample ID: CENTRE-RAW

Lab Sample ID: 280-105644-1

Date Collected: 01/17/18 09:30

Matrix: Water

Date Received: 01/19/18 09:50

Method: DV-LC-0012 - Fluorinated Alkyl Substances									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.091		0.017	0.0069	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorobutanoic acid (PFBA)	0.012	J	0.017	0.0082	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorodecane sulfonate (PFDS)	0.0077	U	0.017	0.0077	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorodecanoic acid (PFDA)	0.0066	U	0.017	0.0066	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.025	0.013	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluoroheptanoic acid (PFHpA)	0.017	J	0.025	0.011	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorohexane Sulfonate (PFHxS)	0.0058	U	0.025	0.0058	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorohexanoic acid (PFHxA)	0.037		0.017	0.0024	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorononanoic acid (PFNA)	0.015	U	0.034	0.015	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorooctanoic acid (PFOA)	0.036		0.017	0.0082	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorooctane Sulfonate (PFOS)	0.036		0.025	0.011	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluoropentanoic acid (PFPA)	0.050		0.025	0.0091	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorotetradecanoic acid (PFTeA)	0.012	U	0.025	0.012	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluorotridecanoic Acid (PFTriA)	0.015	U	0.034	0.015	ug/L		01/22/18 20:36	01/24/18 19:46	1
Perfluoroundecanoic acid (PFUnA)	0.0058	U	0.017	0.0058	ug/L		01/22/18 20:36	01/24/18 19:46	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	91		60 - 155				01/22/18 20:36	01/24/18 19:46	1
13C8 PFOS	95		45 - 130				01/22/18 20:36	01/24/18 19:46	1

Client Sample ID: CENTRE-FINISHED

Lab Sample ID: 280-105644-2

Date Collected: 01/18/18 10:45

Matrix: Water

Date Received: 01/19/18 09:50

Method: DV-LC-0012 - Fluorinated Alkyl Substances									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.085		0.017	0.0071	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorobutanoic acid (PFBA)	0.013	J	0.017	0.0084	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorodecane sulfonate (PFDS)	0.0078	U	0.017	0.0078	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorodecanoic acid (PFDA)	0.0067	U	0.017	0.0067	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.026	0.013	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluoroheptanoic acid (PFHpA)	0.013	J	0.026	0.011	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorohexane Sulfonate (PFHxS)	0.0060	U	0.026	0.0060	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorohexanoic acid (PFHxA)	0.034		0.017	0.0025	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorononanoic acid (PFNA)	0.015	U	0.034	0.015	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorooctanoic acid (PFOA)	0.029		0.017	0.0084	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorooctane Sulfonate (PFOS)	0.032		0.026	0.011	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluoropentanoic acid (PFPA)	0.048		0.026	0.0093	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorotetradecanoic acid (PFTeA)	0.013	U	0.026	0.013	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluorotridecanoic Acid (PFTriA)	0.015	U	0.034	0.015	ug/L		01/22/18 20:36	01/24/18 20:10	1
Perfluoroundecanoic acid (PFUnA)	0.0059	U	0.017	0.0059	ug/L		01/22/18 20:36	01/24/18 20:10	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	89		60 - 155				01/22/18 20:36	01/24/18 20:10	1
13C8 PFOS	92		45 - 130				01/22/18 20:36	01/24/18 20:10	1

TestAmerica Denver