

Client Sample Results

Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-99012-2

Client Sample ID: CENTRE-RAW

Lab Sample ID: 280-99012-3

Date Collected: 07/05/17 08:30

Matrix: Water

Date Received: 07/07/17 09:50

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.071		0.019	0.0079	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorobutanoic acid (PFBA)	0.013	J	0.019	0.0094	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorodecane sulfonate (PFDS)	0.0087	U	0.019	0.0087	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorodecanoic acid (PFDA)	0.0075	U	0.019	0.0075	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorododecanoic acid (PFDoA)	0.014	U	0.029	0.014	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluoroheptanoic acid (PFHpA)	0.013	U	0.029	0.013	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorohexane Sulfonate (PFHxS)	0.0067	U	0.029	0.0067	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorohexanoic acid (PFHxA)	0.028		0.019	0.0028	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorononanoic acid (PFNA)	0.017	U	0.038	0.017	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorooctanoic acid (PFOA)	0.026		0.019	0.0094	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorooctane Sulfonate (PFOS)	0.061		0.029	0.013	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluoropentanoic acid (PFPA)	0.038		0.029	0.010	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorotetradecanoic acid (PFTeA)	0.014	U	0.029	0.014	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluorotridecanoic Acid (PFTriA)	0.017	U	0.038	0.017	ug/L		07/10/17 11:45	07/19/17 18:27	1
Perfluoroundecanoic acid (PFUnA)	0.0066	U	0.019	0.0066	ug/L		07/10/17 11:45	07/19/17 18:27	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	103		60 - 155				07/10/17 11:45	07/19/17 18:27	1
13C8 PFOS	110		45 - 130				07/10/17 11:45	07/19/17 18:27	1

Client Sample ID: CENTRE-FINISHED

Lab Sample ID: 280-99012-4

Date Collected: 07/06/17 11:00

Matrix: Water

Date Received: 07/07/17 09:50

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.051		0.019	0.0077	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorobutanoic acid (PFBA)	0.012	J	0.019	0.0091	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorodecane sulfonate (PFDS)	0.0085	U	0.019	0.0085	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorodecanoic acid (PFDA)	0.0073	U	0.019	0.0073	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorododecanoic acid (PFDoA)	0.014	U	0.028	0.014	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluoroheptanoic acid (PFHpA)	0.012	U	0.028	0.012	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorohexane Sulfonate (PFHxS)	0.0065	U	0.028	0.0065	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorohexanoic acid (PFHxA)	0.023		0.019	0.0027	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorononanoic acid (PFNA)	0.016	U	0.037	0.016	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorooctanoic acid (PFOA)	0.021		0.019	0.0091	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorooctane Sulfonate (PFOS)	0.045		0.028	0.012	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluoropentanoic acid (PFPA)	0.035		0.028	0.010	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorotetradecanoic acid (PFTeA)	0.014	U	0.028	0.014	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluorotridecanoic Acid (PFTriA)	0.016	U	0.037	0.016	ug/L		07/10/17 11:45	07/19/17 18:39	1
Perfluoroundecanoic acid (PFUnA)	0.0064	U	0.019	0.0064	ug/L		07/10/17 11:45	07/19/17 18:39	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	103		60 - 155				07/10/17 11:45	07/19/17 18:39	1
13C8 PFOS	96		45 - 130				07/10/17 11:45	07/19/17 18:39	1

TestAmerica Denver