

Client Sample Results

Location: Alabama Dept. Environmental Management
Project/Site: ADEM PFC Sampling - Centre

TestAmerica Job ID: 280-97966-2

Client Sample ID: CENTRE-RAW

Lab Sample ID: 280-97966-1

Date Collected: 06/05/17 08:45

Matrix: Water

Date Received: 06/07/17 09:00

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.065		0.018	0.0073	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorobutanoic acid (PFBA)	0.018		0.018	0.0087	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorodecane sulfonate (PFDS)	0.0081	U	0.018	0.0081	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorodecanoic acid (PFDA)	0.0069	U	0.018	0.0069	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.027	0.013	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluoroheptanoic acid (PFHpA)	0.012	U	0.027	0.012	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorohexane Sulfonate (PFHxS)	0.0062	U	0.027	0.0062	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorohexanoic acid (PFHxA)	0.022		0.018	0.0026	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorononanoic acid (PFNA)	0.015	U	0.036	0.015	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorooctanoic acid (PFOA)	0.019		0.018	0.0087	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorooctane Sulfonate (PFOS)	0.039		0.027	0.012	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluoropentanoic acid (PFPA)	0.030		0.027	0.0097	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorotetradecanoic acid (PFTeA)	0.013	U	0.027	0.013	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluorotridecanoic Acid (PFTriA)	0.016	U	0.036	0.016	ug/L		06/13/17 12:25	06/14/17 20:01	1
Perfluoroundecanoic acid (PFUnA)	0.0061	U	0.018	0.0061	ug/L		06/13/17 12:25	06/14/17 20:01	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	118		60 - 155				06/13/17 12:25	06/14/17 20:01	1
13C8 PFOS	115		45 - 130				06/13/17 12:25	06/14/17 20:01	1

Client Sample ID: CENTRE-FINISHED

Lab Sample ID: 280-97966-2

Date Collected: 06/06/17 11:00

Matrix: Water

Date Received: 06/07/17 09:00

Method: DV-LC-0012 - Perfluorinated Hydrocarbons									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutane Sulfonate (PFBS)	0.088		0.017	0.0069	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorobutanoic acid (PFBA)	0.016	J	0.017	0.0082	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorodecane sulfonate (PFDS)	0.0076	U	0.017	0.0076	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorodecanoic acid (PFDA)	0.0065	U	0.017	0.0065	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorododecanoic acid (PFDoA)	0.012	U	0.025	0.012	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluoroheptanoic acid (PFHpA)	0.012	J	0.025	0.011	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorohexane Sulfonate (PFHxS)	0.0058	U	0.025	0.0058	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorohexanoic acid (PFHxA)	0.026		0.017	0.0024	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorononanoic acid (PFNA)	0.015	U	0.033	0.015	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorooctanoic acid (PFOA)	0.024		0.017	0.0082	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorooctane Sulfonate (PFOS)	0.059		0.025	0.011	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluoropentanoic acid (PFPA)	0.034		0.025	0.0091	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorotetradecanoic acid (PFTeA)	0.012	U	0.025	0.012	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluorotridecanoic Acid (PFTriA)	0.015	U	0.033	0.015	ug/L		06/13/17 12:25	06/14/17 20:14	1
Perfluoroundecanoic acid (PFUnA)	0.0058	U	0.017	0.0058	ug/L		06/13/17 12:25	06/14/17 20:14	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	118		60 - 155				06/13/17 12:25	06/14/17 20:14	1
13C8 PFOS	122		45 - 130				06/13/17 12:25	06/14/17 20:14	1

TestAmerica Denver