

Client Sample Results

TestAmerica Job ID: 280-115064-1

Client: Alabama Dept. Environmental Management
 Project/Site: ADEM PFC Sampling - Centre

Lab Sample ID: 280-115064-1
 Matrix: Water

Client Sample ID: Centre - Finished

Date Collected: 10/02/18 12:30
 Date Received: 10/03/18 09:15

Method: DV-LC-0012 - Fluorinated Alkyl Substances

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	0.025		0.018	0.0088	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorodecanoic acid (PFDA)	0.0070	U	0.018	0.0070	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorododecanoic acid (PFDoA)	0.013	U	0.027	0.013	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluoroheptanoic acid (PFHpA)	0.016	J	0.027	0.012	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorohexanoic acid (PFHxA)	0.040		0.018	0.0026	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorononanoic acid (PFNA)	0.016	U	0.036	0.016	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorooctanoic acid (PFOA)	0.032		0.018	0.0088	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorooctane sulfonate (PFOS)	0.054		0.027	0.012	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluoropentanoic acid (PFPA)	0.073		0.027	0.0097	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorotetradecanoic acid (PFTeA)	0.013	U	0.027	0.013	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorotridecanoic acid (PFTrIA)	0.016	U	0.036	0.016	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluoroundecanoic acid (PFUnA)	0.0062	U	0.018	0.0062	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorobutanesulfonic acid (PFBS)	0.18		0.018	0.0074	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorodecanesulfonic acid (PFDS)	0.0082	U	0.018	0.0082	ug/L		10/05/18 18:59	10/08/18 16:54	1
Perfluorohexanesulfonic acid (PFHxS)	0.0062	U	0.027	0.0062	ug/L		10/05/18 18:59	10/08/18 16:54	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C8 PFOA	87		60 - 155				10/05/18 18:59	10/08/18 16:54	1
13C8 PFOS	94		45 - 130				10/05/18 18:59	10/08/18 16:54	1