

MECHANICAL SPECIFICATIONS

PROVIDE EQUIPMENT INDICATED ON THE DRAWINGS, AND AS REQUIRED FOR A COMPLETE FUNCTIONING SYSTEM.

DEFINITIONS: FURNISH MEANS TO SUPPLY AND DELIVER TO PROJECT SITE, READY FOR INSTALLATION. INSTALL MEANS TO PLACE IN POSITION AND MAKE CONNECTIONS FOR SERVICE OR USE. PROVIDE MEANS TO FURNISH AND INSTALL, COMPLETE AND READY FOR INTENDED USE.

WARRANTY: PROVIDE LABOR AND MATERIALS TO REPAIR OR REPLACE DEFECTIVE PARTS AND MATERIALS AS REQUIRED FOR ONE YEAR AFTER SUBSTANTIAL COMPLETION OR OWNER ACCEPTANCE OF THE COMPLETED PROJECT. PROVIDE A SEPARATE LINE ITEM DEDUCT AMOUNT ON THE PROPOSAL FORM TO DELETE WARRANTY SERVICE, AT THE OWNER'S OPTION.

PROVIDE OPERATION MANUALS, MAINTENANCE MANUALS AND SCHEMATICS FOR ALL MECHANICAL EQUIPMENT INSTALLED.

COORDINATION: COORDINATE WITH THE WORK OF OTHER SECTIONS, EQUIPMENT FURNISHED BY OTHERS, REQUIREMENTS OF THE OWNER, AND WITH THE CONSTRAINTS OF THE EXISTING CONDITIONS OF THE PROJECT SITE.

ROOF PENETRATIONS SHALL COMPLY WITH "SMACNA" AND "NRC-A" STANDARDS, AND WITH THE REQUIREMENTS OF THE EXISTING ROOFING WARRANTY, IF APPLICABLE. DO NOT PERFORM ROOFING PENETRATIONS IN A MANNER WHICH WOULD VOID OR OTHERWISE LIMIT THE EXISTING ROOF WARRANTY.

DUCT DIMENSIONS: UNLESS OTHERWISE NOTED, DUCT DIMENSIONS ON THE DRAWINGS ARE INSIDE CLEAR DIMENSIONS.

SHEET METAL DUCTWORK: PROVIDE SHEET METAL DUCTWORK FABRICATED AND INSTALLED IN ACCORDANCE WITH ASHRAE AND SMACNA STANDARDS, FOR 1" W.G. PRESSURE CLASS, SEAL CLASS "A". SHEET METAL SHALL BE GALVANIZED SHEET STEEL OF LOCK FORMING QUALITY, WITH G90 ZINC COATING. SHEET STEEL SHALL COMPLY WITH ASTM A653 STANDARD SPECIFICATION FOR STEEL SHEET METAL, ZINC COATED (GALVANIZED) OR ZINC-IRON ALLOY-COATED (GALVANNEALED) BY THE HOT DIP PROCESS, AND A924 STANDARD SPECIFICATION FOR GENERAL REQUIREMENTS FOR SHEET, METALLIC-COATED BY THE HOT DIP PROCESS. ALL ANGLE IRON USED FOR SUPPORT SHALL BE GALVANIZED. CONNECTIONS TO WALLS OR FLOOR SHALL BE AIR TIGHT WITH ANGLE IRON AND CAULKING. SEAL ALL DUCT SEAMS, TRANSVERSE AND LONGITUDINAL, AIR TIGHT. PROVIDE TURNING VANES AT ALL 90° ELBOWS.

TRAPEZE DUCT HANGERS: PROVIDE MINIMUM 1" X 2" X 1/2" X 18 GAUGE CHANNELS WITH MINIMUM 1" X 18 GAUGE STRAPS TO STRUCTURAL SUPPORT.

ROUND SHEET METAL DUCT: PROVIDE SPIRAL SEAM (ALL SIZES) OR SNAP LOCK [DUCT SIZES UP TO 10"] GALVANIZED STEEL COMPLYING WITH SMACNA STANDARDS. SPIRAL SEAM DUCTWORK SHALL HAVE SMACNA SEAM TYPE RL-1.

FIBER GLASS DUCT BOARD IS AN ACCEPTABLE ALTERNATIVE IF APPROVED BY OWNER AND THE LOCAL BUILDING CODE OFFICIAL. PRODUCT AND INSTALLATION MUST MEET NAIMA STANDARDS AND OTHER APPLICABLE CODES AND REGULATIONS.

EXPPOSED DUCTWORK: EXPOSED DUCTWORK SHALL BE CLEANED OF DEBRIS AND OIL, THEN WIPED DOWN WITH VINEGAR OR OTHER SURFACE PREPARING CHEMICAL TO PREPARE DUCT FOR PAINT.

DUCT SEALANT: PROVIDE POLYMERIC RUBBER TYPE SEALANT FOR USE ON BOTH INTERIOR LOCATED DUCTWORK AND DUCTWORK EXPOSED TO OUTDOOR CONDITIONS. SEALER SHALL HAVE HIGH BONDING STRENGTH FOR SURE, FIRST TIME SEALING OF JOINTS IN LOW, MEDIUM, AND HIGH PRESSURE DUCT SYSTEMS. SEALER SHALL BE HIGH IN SOLID CONTENT. PROVIDE A TWO PART TAPE SEALING SYSTEM, CONSISTING OF WOVEN FIBER TAPE IMPREGNATED WITH A GYPSUM MINERAL COMPOUND, AND A MODIFIED ACRYLIC/URETHANE ACTIVATOR THAT REACTS EXOTHERMICALLY WITH THE TAPE. TWO PART TAPE SEALING SYSTEM MUST BE RATED FOR BOTH INDOOR AND OUTDOOR APPLICATION. TAPE SHALL NOT CONTAIN ASBESTOS.

DUCT INSULATION: MATERIAL FOR SUPPLY AND RETURN AIR DUCT ABOVE CEILING INSIDE THE BUILDING SHALL HAVE THE EQUIVALENT THERMAL RESISTANCE OF MINIMUM R-6. THE REQUIRED R VALUES ARE FOR INSTALLED INSULATION WITH 25% COMPRESSION AT THE CORNERS. PROVIDE PINS AND WASHERS IN ACCORDANCE WITH SMACNA REQUIREMENTS AND AS REQUIRED TO PREVENT INSULATION FROM SAGGING. PROVIDE ADEQUATE INSULATION AT THE SUPPLY AIR DIFFUSERS TO PREVENT CONDENSATION.

FLEXIBLE DUCT: UL #181 LISTED, CLASS 1, AND CONTAIN A 0.1 PERM RATED POLYETHYLENE INNER LINER, WITH R-8 FIBERGLASS INSULATION. FLEXIBLE DUCTS SHALL BE SECURED TO RIGID SHEET METAL COLLARS AND AIR DIFFUSERS WITH NYLON TIES OR STAINLESS STEEL WORN GEAR STRAPS. SEAL ALL CONNECTIONS AND JOINTS AIR TIGHT. SUPPORT FLEXIBLE DUCTS FROM THE BUILDINGS STRUCTURE WITH MINIMUM 1" WIDE, 1/8 GAUGE, GALVANIZED STEEL STRAP AT MAXIMUM 4'-0" CENTERS. PROVIDE 4" WIDE SHEET METAL SADDLES AT EACH SUPPORT EACH STRAP. SAG OF FLEXIBLE DUCT BETWEEN HANGERS SHALL NOT EXCEED 1/2" PER FOOT OF SUPPORT SPACING. RADIUS FOR TURNS OF FLEXIBLE DUCTS SHALL BE A MINIMUM OF ONE DUCT DIAMETER. FLEXIBLE DUCT RUNS SHALL NOT EXCEED 10'-0" IN LENGTH AND SHALL BE THE SAME SIZE AS THE DIFFUSER NECK CONNECTION.

ROUND VOLUME DAMPERS: PROVIDE MINIMUM 20 GAUGE GALVANIZED STEEL FRAME AND BLADES, MINIMUM 3/8" SQUARE STEEL AXLE, MOLDED SYNTHETIC BEARINGS, WITH LOCKING POSITION REGULATOR. REGULATOR SHALL BE POSITIONED WITH SHEET METAL BRACKET BEYOND DUCT COVERING. WHERE POSITIONING REGULATOR IS NOT ACCESSIBLE, PROVIDE COUPLING AND EXTENSION ROD WITH REGULATOR FOR CEILING OR WALL INSTALLATION, AS REQUIRED.

RECTANGULAR VOLUME DAMPERS: PROVIDE MINIMUM 16 GAUGE GALVANIZED STEEL CHANNEL FRAME, 16 GAUGE GALVANIZED STEEL BLADES, MINIMUM 1/2" HEXAGONAL AXLE, BOLDED SYNTHETIC BEARINGS, WITH 3/8" SQUARE PLATED STEEL CONTROL SHAFT. LINKAGES SHALL BE CONCEALED IN THE FRAME. OPERATING SHAFT SHALL EXTEND BEYOND FRAME AND DUCT TO A LOCKING QUADRANT WITH ADJUSTABLE LEVER. MAXIMUM BLADE WIDTH SHALL NOT EXCEED 6".

DUCT TURNING VANES: PROVIDE FABRICATED TURNING VANES AND VANE RUNNERS, CONSTRUCTED IN ACCORDANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS". PROVIDE TURNING VANES CONSTRUCTED OF CURVED BLADES, SUPPORTED WITH BARS PERPENDICULAR TO BLADES, AND SET INTO SIDE STRIPS SUITABLE FOR MOUNTING IN DUCTWORK. FOLLOW SMACNA GUIDELINES FOR SPACING SUPPORT, AND CONSTRUCTION. ALL BLADES SHALL BE DOUBLE THICKNESS AIRFOIL TYPE.

FLEXIBLE DUCT CONNECTORS: PROVIDE U.L. LABELED 30 OUNCE NEOPRENE COATED FIBERGLASS FABRIC DUCT CONNECTORS.

DUCT ACCESS DOORS: PROVIDE HINGED ACCESS DOORS IN DUCTWORK WHERE REQUIRED FOR ACCESS TO EQUIPMENT. PROVIDE INSULATED ACCESS DOORS FOR INSULATED DUCTWORK. CONSTRUCT OF SAME OR THICKER GAUGE SHEET METAL AS DUCT IN WHICH IT IS INSTALLED. PROVIDE FLUSH FRAMES FOR UN-INSULATED DUCTS, AND EXTENDED FRAMES FOR EXTERNALLY INSULATED DUCTS. PROVIDE CONTINUOUS HINGE ON ONE SIDE, WITH ONE HANDLE-TYPE LATCH FOR ACCESS DOORS 12" HIGH AND SMALLER, AND TWO HANDLE-TYPE LATCHES FOR LARGER ACCESS DOORS.

HVAC CONTROL SYSTEM: PROVIDE ALL THE NECESSARY CONTROLS AND CONTROL WIRING IN CONDUIT COMPATIBLE TO SYSTEMS SHOWN ON EQUIPMENT SCHEDULE M2.0.

PROGRAMMABLE THERMOSTAT FOR EACH SYSTEM SHALL ENABLE THE SUPPLY FAN AND CYCLE THE COOLING AND HEATING STAGES TO MAINTAIN SPACE SET-POINT. SUPPLY FAN RUNS CONTINUOUSLY DURING THE OCCUPIED MODE.

EACH THERMOSTAT SHALL HAVE A DEAD BAND OF AT LEAST 5 DEGREES (ΔJ) WITHIN WHICH THE SUPPLY OF HEATING AND COOLING IS SHUT OFF.

EACH THERMOSTAT SHALL HAVE SETBACK AND SET-UP CAPABILITY DURING THE UNOCCUPIED MODE. FOR SETBACK, THE HEATING SHALL RESTART AND TEMPORARILY OPERATE ACCORDING TO A SET-POINT ADJUSTABLE DOWN TO 55 DEGREES. FOR SET-UP, THE COOLING SHALL RESTART AND TEMPORARILY OPERATE ACCORDING TO A SET-POINT ADJUSTABLE UP TO 85 DEGREES OR TO PREVENT HIGH SPACE HUMIDITY LEVELS.

EACH SYSTEM SHALL BE PROVIDED WITH A MOTORIZED OUTSIDE AIR DAMPER THAT WILL AUTOMATICALLY SHUT WHEN THE SYSTEM OR SPACES SERVED ARE NOT IN USE. VENTILATION OUTSIDE AIR DAMPERS SHALL BE CAPABLE OF AUTOMATICALLY CLOSING DURING PREOCCUPANCY BUILDING WARM-UP, COOL DOWN, AND SETBACK, EXCEPT WHEN VENTILATION REDUCES ENERGY COSTS (e.g., NIGHT PURGE) OR WHEN VENTILATION MUST BE SUPPLIED TO MEET CODE REQUIREMENTS.

COMMISSIONING/VERIFICATION: HVAC CONTROL SYSTEM SHALL BE TESTED TO ENSURE THAT CONTROL ELEMENTS ARE CALIBRATED, ADJUSTED, AND IN PROPER WORKING CONDITION, AND THAT THE SYSTEM MEETS THE DESIGN REQUIREMENTS.

TEST AND BALANCE: CONTRACT DIRECTLY A THIRD PARTY TO PROVIDE TEST AND BALANCE OF THE HVAC SYSTEM. THE GENERAL CONTRACTOR IS RESPONSIBLE FOR SCHEDULING, TEST AND ADJUST ALL MECHANICAL SYSTEM AND EQUIPMENT TO ASSURE PROPER BALANCE AND OPERATION. PERFORM TESTS IN ACCORDANCE WITH NEBB PROCEDURAL STANDARDS-1999 OR AABC 2002, AND ASHRAE STANDARD 111. ELIMINATE NOISE AND VIBRATION, AND ASSURE PROPER FUNCTION OF CONTROLS. SUBMIT COMPLETED TEST AND BALANCE REPORT TO OWNER'S REPRESENTATIVE. BALANCING CONTRACTOR SHALL BE INDEPENDENT AND CERTIFIED WITH NEBB OR AABC. BALANCE ALL SYSTEMS WITHIN 5% OF AIR FLOW INDICATED ON DRAWINGS, AND REPORT ALL DISCREPANCIES TO THE HVAC CONTRACTOR FOR CORRECTION. MARK FINAL BALANCE POSITIONS ON DAMPERS WITH PERMANENT MARKER.

COMPLETION REQUIREMENTS: THE CONTRACTOR SHALL PROVIDE, WITHIN 90 DAYS AFTER THE DATE OF SYSTEM ACCEPTANCE, RECORD DRAWINGS AND AN OPERATING AND MAINTENANCE MANUAL TO THE BUILDING OWNER OR THE DESIGNATED REPRESENTATIVE OF THE OWNER.

THE RECORD DRAWING SHALL BE OF THE ACTUAL INSTALLATION AND INCLUDE AS A MINIMUM THE LOCATION AND PERFORMANCE DATA ON EACH PIECE OF EQUIPMENT, GENERAL CONFIGURATION OF DUCT AND PIPE DISTRIBUTION SYSTEM INCLUDING SIZES, AND THE TERMINAL AIR OR WATER DESIGN FLOW RATES.

THE OPERATING AND MAINTENANCE MANUALS SHALL BE IN ACCORDANCE WITH INDUSTRY-ACCEPTED STANDARDS AND SHALL INCLUDE, AT A MINIMUM, THE FOLLOWING: (A) SUBMITTAL DATA STATING EQUIPMENT SIZE AND SELECTED OPTIONS FOR EACH PIECE OF EQUIPMENT REQUIRING MAINTENANCE; (B) OPERATION MANUALS AND MAINTENANCE MANUALS FOR EACH PIECE OF EQUIPMENT REQUIRING MAINTENANCE, EXCEPT EQUIPMENT NOT FURNISHED AS PART OF THE PROJECT. REQUIRED ROUTINE MAINTENANCE ACTIONS SHALL BE CLEARLY IDENTIFIED; (C) NAMES AND ADDRESSES OF AT LEAST ONE SERVICE AGENCY; (D) HVAC CONTROLS SYSTEMS MAINTENANCE AND CALIBRATION INFORMATION, INCLUDING WIRING DIAGRAMS, SCHEMATICS, AND CONTROL SYSTEM SEQUENCE DESCRIPTIONS. DESIRED OR FIELD-DETERMINED SET-POINTS SHALL BE PERMANENTLY RECORDED ON CONTROL DRAWINGS AT CONTROL DEVICES OR, FOR DIGITAL CONTROL SYSTEMS, IN PROGRAMMING COMMENTS; (E) A COMPLETE NARRATIVE OF HOW EACH SYSTEM EACH SYSTEM IS INTENDED TO OPERATE, INCLUDING SET-POINTS.

HVAC GENERAL NOTES

1. THE INTENT OF THESE PLANS AND SPECIFICATIONS IS TO INCLUDE ALL LABOR, EQUIPMENT, MATERIALS, AND SERVICES NECESSARY TO FURNISH, INSTALL, TEST, AND ADJUST A COMPLETE WORKABLE HEATING, VENTILATION, AND AIR CONDITIONING SYSTEM AS SHOWN, PRESCRIBED, OR REASONABLY IMPLIED BUT NOT LIMITED TO THAT EXPLICITLY INDICATED IN THE CONTRACT DOCUMENTS, BUT NECESSARY FOR THE PROPER EXECUTION AND COMPLETION OF THE INTENT THEREOF.

2. THE ENTIRE INSTALLATION SHALL CONFORM TO THE APPLICABLE CODES AND REGULATIONS REQUIRED BY AUTHORITIES HAVING JURISDICTION, IN THE EVENT OF CONFLICT BETWEEN SPECIFICATIONS, CODES, AND REGULATIONS, THE MORE RESTRICTIVE SHALL APPLY.

3. DRAWINGS FOR HVAC WORK ARE DIAGRAMATIC SHOWING THE GENERAL LOCATION, TYPE, LAYOUT, AND EQUIPMENT REQUIRED. THE DRAWINGS SHALL NOT BE SCALED FOR EXACT MEASUREMENT. REFER TO ARCHITECTURAL DRAWINGS FOR DIMENSIONS. PROVIDE ALL DUCTWORK, MATERIALS, CONNECTIONS, ACCESSORIES, FITTINGS, OFFSETS, TRANSITIONS, DAMPERS AS REQUIRED FOR A COMPLETE WORKABLE SYSTEM.

4. ALL EQUIPMENT SHALL BE INSTALLED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS AND APPROVED LISTING. ALL EQUIPMENT, PIPING AND SUPPORTS SHALL BE RESTRAINED IN ACCORDANCE WITH THE LATEST EDITION OF THE "GUIDELINES FOR SEISMIC RESTRAINTS OF MECHANICAL SYSTEMS AND PLUMBING PIPING SYSTEMS" BY THE SHEET METAL AND AIR CONDITIONING CONTRACTORS NATIONAL ASSOCIATION (SMACNA). ALL EQUIPMENT SHALL BE ANCHORED TO RESIST THE LATERAL FORCE REQUIREMENTS OF CHAPTER 16 OF THE 2012 INTERNATIONAL BUILDING CODE.

5. COORDINATE THE INSTALLATION OF THE HVAC SYSTEM WITH ALL OTHER TRADES PRIOR TO FABRICATION OR INSTALLATION. COORDINATE THE LOCATIONS OF PENETRATIONS AND FINAL LOCATION OF ALL EQUIPMENT WITH THE GENERAL CONTRACTOR. PROVIDE EQUIPMENT WEIGHTS, EQUIPMENT DIMENSIONS, PLATFORM SIZES & LOCATIONS, CURB SIZES & LOCATIONS, CONCRETE PAD SIZES AND LOCATIONS AS REQUIRED. COORDINATE LOCATIONS OF GAS & CONDENSATE LINES WITH PLUMBING CONTRACTOR. COORDINATE LOCATIONS OF POWER, DISCONNECTS, AND CONTROL CONDUIT WITH THE ELECTRICAL CONTRACTOR. COORDINATE LOCATIONS OF ALL DIFFUSERS, REGISTERS, AND GRILLES WITH ARCHITECTURAL PLANS, ELECTRICAL LIGHTING PLANS AND ARCHITECTURAL ELEVATIONS.

6. DETAILS FOR EQUIPMENT PADS, PLATFORMS, AND FLASHINGS SHALL BE AS INDICATED BY THE ARCHITECTURAL/STRUCTURAL/CIVIL DRAWINGS, UNLESS NOTED OTHERWISE.

7. ALL EQUIPMENT, DUCTS, PIPING, SUPPORTS, AND OTHER DEVICES OUTSIDE OF THE BUILDING OR EXPOSED TO WEATHER, SHALL BE COMPLETELY WEATHER-PROOFED.

8. OUTSIDE AIR INTAKES SHALL BE AT LEAST 10 FT. AWAY OR 3 FT. BELOW ANY VENT OR EXHAUST DISCHARGE.

9. ALL DUCT SIZES ARE CLEAR INSIDE DIMENSIONS. DUCTWORK SHALL BE CONSTRUCTED, ERECTED, INSULATED AND TESTED IN ACCORDANCE CHAPTER 6 OF THE 2012 INTERNATIONAL MECHANICAL CODE.

10. ALL EXHAUST FANS SHALL BE EQUIPED WITH A BACK DRAFT DAMPER.

11. DUCT AND AIR TRANSFER PENETRATIONS THRU BUILDING ASSEMBLIES REQUIRING PROTECTION SHALL BE PROTECTED WITH FIRE DAMPERS, SMOKE DAMPERS, COMBINATION SMOKE/FIRE DAMPERS AND CEILING RADIATION DAMPERS IN ACCORDANCE WITH SECTION 607 OF THE INTERNATIONAL MECHANICAL CODE. DUCTS NOT REQUIRING DAMPERS SHALL COMPLY WITH SECTION 714 & 717 OF THE 2019 CALIFORNIA BUILDING CODE.

12. INSTALL SMOKE DETECTORS AND PROVIDE FOR SMOKE DETECTION AND AUTOMATIC SHUT-OFF OF ALL AIR HANDLING EQUIPMENT IN ACCORDANCE WITH SECTION 606 OF THE 2019 CALIFORNIA MECHANICAL CODE.

13. UNLESS NOTED OTHERWISE, ALL LINE VOLTAGE WIRING, CONDUIT, FINAL CONNECTIONS, DISCONNECTS, STARTERS, AND OVER CURRENT PROTECTION DEVICES SHALL BE PERFORMED AND INSTALLED BY THE ELECTRICAL CONTRACTOR AS INDICATED ON THESE MECHANICAL DRAWINGS AND/OR ELECTRICAL DRAWINGS AND/OR ELECTRICAL SECTION OF THE SPECIFICATIONS.

14. INSTALL ALL LOW VOLTAGE HVAC CONTROL WIRE AND DEVICES PER PLAN. ALL WIRE SHALL BE IN CONDUIT PROVIDED AND INSTALLED BY THE ELECTRICAL CONTRACTOR UNLESS NOTED OTHERWISE.

15. PROVIDE OWNER WITH THREE COPIES OF A CERTIFIED AIR BALANCE REPORT PREPARED IN BY A THIRD PARTY CERTIFIED BY THE AABC OR NEBB. TEST, ADJUST AND BALANCE THE HVAC SYSTEM IN ACCORDANCE WITH AABC OR NEBB PROCEDURES. PROVIDE START-UP/TEST REPORTS FOR ALL AIR HANDLING EQUIPMENT, FANS, AND REFRIGERATION EQUIPMENT. TEST AND VERIFY PROPER OPERATION OF ALL MAKE-UP AIR/EXHAUST AIR INTERLOCK SYSTEMS AND THEIR SEQUENCES OF OPERATION. BALANCE ALL AIR FLOWS WITHIN 5% OF DESIGN VALUES. PERMANENTLY MARK BALANCE POSITION OF ALL REGULATING DEVICES.

16. PROVIDE OWNER WITH THREE SETS OF AS-BUILT PLANS AND OPERATIONS AND MAINTENANCE MANUALS. CLEARLY IDENTIFY ALL EQUIPMENT WITH PERMANENT PLASTIC OR METAL LABELS/TAGS (PEN MARKING NOT ACCEPTABLE).

17. PROVIDE ONE YEAR WARRANTY ON ALL LABOR, PARTS AND MATERIALS.

18. ANY CHANGE OR DEVIATION FROM THESE PLANS OR SPECIFICATIONS SHALL REQUIRE THE WRITTEN APPROVAL OF THE ENGINEER PRIOR TO COMMENCEMENT OF SUCH WORK.

19.0

a) DUCTS FOR DEMAND CONTROLLED VENTILATION SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE FAN MANUFACTURER'S INSTALLATION INSTRUCTIONS. THE PROVISIONS ASHRAE 62.2, TABLE 5.3, OR THE AIRFLOW SHALL BE MEASURED AS REQUIRED BY AND IN COMPLIANCE WITH ASHRAE 62.2, 5.4.

b) DUCTS FOR KITCHEN COOKTOPS OR RANGES SHALL BE SHOWN OF METAL WITH A SMOOTH INTERIOR. [CMC 504.3].

1) IDENTIFY THE DETAILED REQUIREMENTS OF CMC DRYER DUCTS. SPECIFY--

a) DUCTS FOR DOMESTIC CLOTHES DRYERS SHALL BE INSTALLED IN ACCORDANCE WITH CMC 504.0.

b) DUCTS FOR DOMESTIC CLOTHES DRYERS SHALL BE RIGID METALLIC DUCTS WITH A MINIMUM MILL THICKNESS OF 16 (0.016-INCH). SHALL HAVE A MINIMUM 4-INCH DIAMETER AND A SMOOTH INTERIOR. THE COMBINED HORIZONTAL AND VERTICAL LENGTH OF THE DUCTS OF THE DUCTS SHALL BE 14-FEET, WHICH SHALL BE REDUCED BY 2-FEET FOR EVERY 90-DEGREE ELBOW IN EXCESS OF TWO ELBOWS.

c) LISTED CLOTHES DRYER TRANSITION DUCTS NOT MORE THAN 6-FEET IN LENGTH SHALL BE PERMITTED TO CONNECT THE DRYER TO THE EXHAUST DUCTS AS LONG AS THEY ARE NOT CONCEALED WITHIN CONSTRUCTION, AND THEY ARE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.

LEGEND

		DUCT WORK (WIDTHxDEPTH)
		LINED DUCT WORK (WIDTHxDEPTH DIMENSIONS ARE FOR L.D.)
		SUPPLY DUCT, SECTION
		RETURN DUCT, SECTION
		EXHAUST DUCT, SECTION
		RISE OR DROP IN DIRECTION OF AIR FLOW
	FLEX. CONN.	FLEXIBLE CONNECTION
		DUCT TRANSITION, ROUND AND RECTANGULAR
		SPLITTER DAMPER
		EXTRACTOR AT BRANCH DUCT
		TURNING VANES
		FLEXIBLE DUCT
		SINGLE LINE DUCT WORK
	AVD	AUTOMATIC VOLUME DAMPER
	MVD	MANUAL VOLUME DAMPER
	BDD	BACKDRAFT DAMPER
	MD	MODULATING DAMPER
	AFD	AUTOMATIC FIRE DAMPER
	AD	ACCESS DOOR
	SD	SUPPLY DIFFUSER
	RR	RETURN REGISTER
	ER	EXHAUST REGISTER
	SWR	SIDE WALL SUPPLY REGISTER
	SWE	SIDE WALL RETURN OR EXHAUST
	LD	LINEAR DIFFUSER
	DL	DOOR LOUVER
	UC	UNDER CUT DOOR
	VAV	VARIABLE AIR VOLUME
	①	THERMOSTAT
	②	DUCT SMOKE DETECTOR

SPECIAL NOTICE TO CONTRACTORS

1. ALL CONTRACTORS (GENERAL CONTRACTOR AND SUB-CONTRACTORS) BIDDING THIS PROJECT ARE REQUIRED TO VISIT THE JOB SITE AND VERIFY THE EXISTING CONDITIONS PRIOR TO SUBMITTING THEIR BID. CONTRACTORS ARE TO CAREFULLY REVIEW ALL CONSTRUCTION DOCUMENTS AND NOTE ANY DISCREPANCIES BETWEEN THE CONSTRUCTION DOCUMENTS AND THE CONDITIONS OBSERVED AT THE JOB SITE PRIOR TO SUBMISSION OF ANY BID. THE BUILDING OWNER REPRESENTATIVE LISTED BELOW MAY BE CONTACTED FOR ACCESS TO THE JOB SITE.

2. CONTRACTORS ARE RESPONSIBLE FOR VERIFYING THE LOCATION AND CONDITION OF ALL POINTS OF CONNECTION, LOCATION AND CONDITION OF ALL BUILDINGS (ROOF/FLOOR/CEILING) PENETRATIONS, LOCATION AND CONDITION OF ALL UTILITIES AND BUILDING SYSTEMS INCLUDING, BUT NOT LIMITED TO, GAS, WATER, SEWER, VENT, ELECTRICAL, BUILDING MECHANICAL SYSTEMS, DUCT CONNECTIONS, EXHAUST/OUTSIDE AIR CONNECTIONS, SECURITY, FIRE ALARM, DATA, AND PHONE PRIOR TO SUBMISSION OF THEIR BID.

3. ANY DISCREPANCIES BETWEEN THE CONSTRUCTION DOCUMENTS AND THE CONDITIONS OBSERVED SHALL BE BROUGHT TO THE ATTENTION, IN WRITING, TO THE ARCHITECT AND/OR ENGINEER PRIOR TO PROCEEDING WITH CONSTRUCTION.

4. NO WORK SHALL BE DONE ON ANY PART OF THE BUILDING BEYOND THE POINT INDICATED IN EACH SUCCESSIVE INSPECTION WITHOUT FIRST OBTAINING THE WRITTEN APPROVAL OF THE CODE OFFICIAL. NO CONSTRUCTION SHALL BE CONCEALED WITHOUT BEING INSPECTED AND APPROVED.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS

APPEARING HEREIN CONSTITUTE THE

ORIGINAL AND UNPUBLISHED WORK OF THE

DESIGNER AND THE SAME MAY NOT BE

DUPLICATED, USED OR DISCLOSED WITHOUT

CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:


MECHANICAL SPECIFICATIONS, LEGEND AND GENERAL NOTES

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: NTS
-----------	-------------	-----------------------

DRAWING NO.

REV.

M 0 . 0 0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPERIUM ROOTS

TITLE:
MECHANICAL LAYOUT 1 of 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"
-----------	-------------	-------------------------------

DRAWING NO. M 1 . 0 1 A	REV.
-----------------------------------	------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS			
TITLE: MECHANICAL LAYOUT 2 of 4			
PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"	
DRAWING NO. M 1 . 0 1 B			REV.

GENERAL NOTES

1. MECHANICAL CONTRACTOR SHALL EXAMINE ALL OTHER SPECIFICATIONS, DRAWINGS AND ALL FEATURES OF BUILDING CONSTRUCTION WHICH MAY AFFECT HIS WORK AND SHALL B GOVERNED BY THESE AND OTHER SPECIFICATIONS, INCLUDIN THE GENERAL CONDITIONS AND PARTICULAR INSTRUCTIONS T ALL BIDDER AND SUPPLIERS .
2. ALL WORK SHALL BE EXECUTED AND INSPECTED IN STRICT ACCORDANCE WITH ALL LOCAL CODES AND/OR STATE CODES, LAWS, ORDINANCES, RULES AND REGULATIONS APPLICABLE TO THIS PARTICULAR CLASS OF WORK, AND EACH CONTRACTOR SHALL INCLUDE IN HIS PRICE ALL APPLICABLE SERVICE CHARGES, FEES, PERMITS, TAXES, AND OTHER SIMILAR COSTS IN CONNECTION THEREWITH .
3. PRIOR TO FABRICATION OF DUCTWORK, THE MECHANICAL CONTRACTOR SHALL EXAMINE AND VERIFY ALL CONDITIONS ABOVE AND BELOW THE CEILING WHICH MAY INTERFERE WITH THE DUCT SYSTEM AND NOTIFY THE ARCHITECT OF ANY CONFLICT ENCOUNTERED, CONTRACTOR SHALL PROVIDE ALL OFFSETS, ETC. WHICH MAY BE REQUIRED, WITHOUT ADDITIONAL COST TO THE OWNER
4. ALL SHEET METAL DUCT CONSTRUCTION SHALL BE IN STRICT ACCORDANCE WITH "SMACNA" LOW PRESSURE DUCT CONSTRUCTION STANDARD
5. TURNING VANES SHALL BE INSTALLED IN ALL BENDS IN RECTANGULAR DUCT EXCEEDING 30°
6. ALL DUCTS SHALL BE SUPPORTED WITH 1" WIDE, 16 GAUGE, GALVANIZED STEEL BANDS .
7. ALL RECTANGULAR DUCT SHALL BE INSULATED WITH A MIN. OF 1" INTERNAL LINER, 2 LBS. DENSITY R-60. ALL ROUND DUCTS AND DIFFUSER TOPS SHALL HAVE A MIN. 2" THICK OF FOIL BACKED BLANKET TYPE INSULATION R=4-4.2, WITH ALL JOINTS BUTTED AND TAPED .
8. ALL DUCT DIMENSIONS SHOWN ON PLANS ARE INTERNAL
9. THE MECHANICAL CONTRACTOR SHALL COORDINATE THE LOCATION OF SUPPLY AND RETURN AIR REGISTERS, DUCTS, GRILLES AND DIFFUSERS WITH LIGHTING AND CEILING PATTERNS
10. PROVIDE LATERAL BRACING OF ALL DUCTS AND PIPES AS REQUIRED BY CODE .
11. INSULATE AND SEAL ALL DUCTWORK PER CHAPTER 10 OF THE STATE MECHANICAL CODE (T-24, PART 4)
12. MOUNT ALL THERMOSTATS AT 48" ABOVE FINISHED FLOOR
13. ALL BRACING OF DUCTS AND PIPING SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA GUIDELINES
14. WHERE BRACING DETAILS ARE NOT SHOWN ON THE DRAWINGS OR IN THE GUIDELINES, THE FIELD INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE ARCHITECT AND THE MECHANICAL ENGINEER
15. DUCT SMOKE DETECTOR SHALL BE INSTALLED BELOW THE ROOF
16. ALL MECHANICAL EQUIPMENT AND SYSTEMS INSTALLED AS PART OF PROJECT SHALL COMPLY WITH ALL REQUIREMENTS OF THE 2013 CALIFORNIA MECHANICAL CODE AND THE 2013 CALIFORNIA BUILDING CODE AND THE 2013 CALIFORNIA BUILDING ENERGY EFFICIENCY STANDARDS .
17. OUTSIDE AIR FOR A HEATING OR COOLING SYSTEM SHALL NOT BE TAKEN FROM CLOSER THAN 10 FEET FROM AN APPLIANCE VENT OUTLET, VENT OPENING OF A PLUMBING SYSTEM, OR THE DISCHARGE OUTLET OF EXHAUST FAN, UNLESS THE OUTLET IS 3 FT. ABOVE THE OUTSIDE AIR INLET (CMC 314.3)
18. PROVIDE 120 VOLT ELECTRICAL OUTLETS WITHIN 25 FT. OF ALL MECH. EQUIPT. (CMC 309)
19. HEATING, VENTILATING AND AIR CONDITIONING SYSTEMS SHALL BE BALANCED IN ACCORDANCE WITH ONE OF THE FOLLOWING METHODS IN ACCORDANCE WITH CMC 317.1 REQUIREMENTS .

A. AABC NATIONAL STANDARDS FOR TOTAL SYSTEM BALANCE

B. ACCA MANUAL B

C. ASHRAE 111

D. NEBB PROCEDURAL STANDARDS FOR TESTING, ADJUSTING, AND BALANCING OF ENVIRONMENTAL SYSTEMS

E. SMACNA HVAC TESTING, ADJUSTING, AND BALANCING
20. MATERIALS EXPOSED WITHIN DUCTS OR PLENUMS SHALL BE NON COMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX NOT TO EXCEED 25 AND A SMOKE DEVELOPED INDEX NOT TO EXCEED 50 WHERE TESTED AS A COMPOSITE PRODUCT IN ACCORDANCE WITH ASTM E84 OR UL 723 .

SCHEDULE No. 1
AIR CONDITIONER - OUTDOOR UNIT

TAG	ODU-01 TO 04 & 06 TO 10
SERVING	FLOWERS & VEG.
MANUFACTURER	CARRIER
OUTDOOR MODEL	38AUQ-25
MOTOR VOLT / PH / HZ	208-230 / 3 / 60
MCA (A)	73.7
FUSE (A)	100.0
COOLING & HEATING CAPACITY (TONS)	20.0
OUTDOOR DIMENSIONS (L x W x H) (inch)	85 x 45-1/8 x 50-3/8

460 V

SCHEDULE No. 3
HEAT PUMP - OUTDOOR UNIT

TAG	ODU-11, 12	ODU-05
SERVING	DRY/CURE ROOM	GF OPERATION AREAS
MANUFACTURER	CARRIER	CARRIER
OUTDOOR MODEL	38AUQ-07	38AUQ-07
MOTOR VOLT / PH / HZ	208-230 / 3 / 60	208-230 / 3 / 60
MCA (A)	25.0	25.0
FUSE (A)	30.0	30.0
COOLING & HEATING CAPACITY (TONS)	6.0	6.0
OUTDOOR DIMENSIONS (L x W x H) (inch)	46 x 56-1/4 x 42-3/8	46 x 56-1/4 x 42-3/8

NOTES

SCHEDULE No. 6
HEAT PUMP - OUTDOOR UNIT (MULTI ZONE)

TAG	ODU-13 & 14	ODU-15	ODU-16 TO 18	ODU-19
SERVING	NURSERY			
MANUFACTURER	CARRIER	CARRIER	CARRIER	CARRIER
OUTDOOR MODEL	38MGRQ36D-3	38MGRQ18B-3	38MGRQ36D-3	38MGRQ18B-3
MOTOR VOLT / PH / HZ	208-230 / 1 / 60	208-230 / 1 / 60	208-230 / 1 / 60	208-230 / 1 / 60
MCA (A)	35.0	18.0	35.0	18.0
FUSE (A)	50.0	25.0	50.0	25.0
COOLING & HEATING CAPACITY (TONS)	3.0	1.5	3.0	1.5
OUTDOOR DIMENSIONS (W x H x D) (inch)	41.15 x 52.48 x 17.63	37.31 x 31.88 x 14.82	41.15 x 52.48 x 17.63	37.31 x 31.88 x 14.82

SCHEDULE No. 7
DEHUMIDIFIER SCHEDULE

TAG	DEH-225	DEH-225
LOCATION	FLOWER, NURSERY	VEG.
MANUFACTURER	QUEST	QUEST
MODEL	QUEST 225 4035400	QUEST 225 4035400
DESIGN GALLONS	28	28
SELECT GALLONS	28	28
FLOW RATE (CFM)	526	526
SELECTED PRESSURE DROP (INCH W.C.)	0.0	0.0
ELECTRICAL (V / PH / HZ)	240 / 1 / 60	240 / 1 / 60
CURRENT DRAW (A)	6.9	6.9
RATINGS	1,500 Watts	1,500 Watts
MCA (A)	-	-
MOP (A)	-	-
OPERATING TEMPERATURE	56 TO 95 °F	56 TO 95 °F

SCHEDULE No. 2
AIR CONDITIONER - INDOOR UNIT

TAG	IDU-01 TO 04 & 06 TO 10
SERVING	FLOWERS & VEG.
MANUFACTURER	CARRIER
INDOOR MODEL	40RUQ-25
AIR FLOW (CFM)	8,000
MOTOR VOLT / PH / HZ	208-230 / 3 / 60
MCA (A)	23.0
FUSE (A)	40.0
COOLING & HEATING CAPACITY (TONS)	20.0
OUTDOOR DIMENSIONS (L x W x H) (inch)	89 x 56-1/16 x 28-3/16

SCHEDULE No. 4
HEAT PUMP - INDOOR UNIT

TAG	IDU-11, 12	IDU-05
SERVING	DRY/CURE ROOM	GF OPERATION AREAS
MANUFACTURER	CARRIER	CARRIER
INDOOR MODEL	38RUQ-07	38RUQ-07
AIR FLOW (CFM)	3,000	3,000
MOTOR VOLT / PH / HZ	208-230 / 3 / 60	208-230 / 3 / 60
MCA (A)	7.0	7.0
FUSE (A)	15.0	15.0
COOLING & HEATING CAPACITY (TONS)	6.0	6.0
OUTDOOR DIMENSIONS (L x W x H) (inch)	42-3/4 x 49 x 56-1/4	42-3/4 x 49 x 56-1/4

SCHEDULE No. 7
HEAT PUMP - INDOOR UNIT (MULTI ZONE)

TAG	IDU-13 TO 14	IDU-15 TO 19
SERVING	NURSERY	STO.,CORD.,EXTR.,LAB.
MANUFACTURER	CARRIER	CARRIER
INDOOR MODEL	40MAQB36-003	40MAQB12-001
AIR FLOW (CFM)	780	360
MOTOR VOLT / PH / HZ	115 / 1 / 60	115 / 1 / 60
FLA (A)	0.40	0.33
HP	0.053	0.053
COOLING & HEATING CAPACITY (TONS)	3.0	1.0
OUTDOOR DIMENSIONS (L x W x H) (inch)	46.00 x 13.00 x 11.02	32.87 x 7.8 x 11.02

SCHEDULE No. 5
FAN SCHEDULE

MANUFACTURER	GREENHECK	GREENHECK
MODEL	SQ 70-75	SP AP 0511 W
TAG	EF-01/02	EF-03/04/05
LOCATION	TOILETS	KITCHEN, TOILETS
DESIGN FLOW (CFM)	124	50
SELECT FLOW (CFM)	124	50
DESIGN PRESSURE DROP (INCH W.C.)	0.15	0.15
SELECTED PRESSURE DROP (INCH W.C.)	0.15	0.15
ELECTRICAL (V / PH / HZ)	115 / 1 / 60	115 / 1 / 60
ABSORBED POWER	0.01 hp	5.5 Watts
MOTOR SPEED (RPM)	1050	820
FAN TYPE	INLINE FAN	CEILING FAN
DRIVE TYPE	DIRECT DRIVE	DIRECT DRIVE

NOTES

SCHEDULE No. 10
GRAVITY VENTILATOR

TAG	GV-01 TO 09
LOCATION	FLOWER & VEG.
MANUFACTURER	GREENHECK
MODEL	GRSI
THROAT SIZE	20"x24"
CURB CAP I.D.	26"x30"
CFM CAPACITY	2700 CFM
MAXIMUM S.P. DROP	0.15
DAMPER	YES

NOTES

1. PROVIDE 12" ROOF CURB WITH SECURITY BARS.
2. PROVIDE INSECT SCREEN
3. PROVIDE FACTORY 2" WASHABLE FILTERS

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY




















PROJECT:

IMPERIUM ROOTS

TITLE:

MECHANICAL EQUIPMENT SCHEDULE

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		NTS
DRAWING NO.		REV.
M 2 . 0 1		



CLIENT:
ADDRESS:

CONFIDENTIALITY STATEMENT:
ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS
TITLE: MECHANICAL GENERAL DETAILS
PROJ. NO. PROJ. ENGR. SCALE @ 24X36: NTS
DRAWING NO. REV. M 3 . 0 1

PLUMBING SPECIFICATIONS

THE WORK INCLUDES MODIFICATION TO THE EXISTING PLUMBING SYSTEM AND PROVIDING NEW MATERIALS, FITTINGS AND ACCESSORIES NECESSARY FOR A COMPLETE FUNCTIONING PLUMBING SYSTEM. THE WORK ALSO INCLUDES ROUGH-IN AND FINAL CONNECTIONS TO FOOD SERVICE EQUIPMENT AND BEVERAGE DISPENSING EQUIPMENT PROVIDED BY OTHERS. ALL WORK SHALL BE IN ACCORDANCE WITH LOCAL CODES AND/OR ORDINANCES AND IS SUBJECT TO INSPECTION.

HOOK-UP CHARGES, PERMITS AND ALL OTHER EXPENSES RELATED TO A COMPLETE AND FUNCTIONING PLUMBING SYSTEM ARE INCLUDED AS A PART OF THIS SECTION.

WARRANTY: PROVIDE LABOR AND MATERIALS TO REPAIR OR REPLACE DEFECTIVE PARTS AND MATERIALS AS REQUIRED FOR ONE YEAR AFTER SUBSTANTIAL COMPLETION OR OWNER ACCEPTANCE OF THE COMPLETED PROJECT. PROVIDE A SEPARATE LINE ITEM DEDUCT AMOUNT ON THE PROPOSAL FORM TO DELETE WARRANTY SERVICE, AT THE OWNER'S OPTION.

THE INTENT OF THE DRAWINGS IS TO INDICATE THE GENERAL EXTENT OF WORK REQUIRED FOR THE PROJECT. THE DRAWINGS FOR PLUMBING WORK ARE DIAGRAMMATIC, SHOWING THE GENERAL LOCATION, TYPE, FIXTURES AND EQUIPMENT REQUIRED. THE DRAWINGS SHALL NOT BE SCALED FOR EXACT MEASUREMENTS. REFER TO MANUFACTURER'S STANDARD ROUGH-IN DRAWINGS FOR PLUMBING FIXTURE INSTALLATION REQUIREMENTS. COMPLY WITH ALL APPLICABLE ADA INSTALLATION REQUIREMENTS.

COORDINATE WITH THE WORK OF OTHER SECTIONS. EQUIPMENT FURNISHED BY OTHERS, AND WITH THE CONSTRAINTS OF THE EXISTING CONDITIONS OF THE PROJECT SITE.

PIPING SYSTEMS - GENERAL: ALL PIPING SHALL BE RUN PARALLEL TO BUILDING LINES AND SUPPORTED AND ANCHORED AS REQUIRED TO FACILITATE EXPANSION AND CONTRACTION. ALL PIPING SHALL BE CONCEALED EXCEPT IN UNFINISHED SPACES. INSTALL AS REQUIRED TO MEET ALL CONSTRUCTION CONDITIONS AND TO ALLOW FOR INSTALLATION OF OTHER WORK SUCH AS DUCTS AND ELECTRICAL CONDUIT. AT ALL CONNECTIONS BETWEEN FERROUS PIPING AND NONFERROUS PIPING, PROVIDE AN ISOLATING DIALECTIC UNION. ALL HANGERS SHALL BE COMPATIBLE WITH PIPING MATERIAL TO PREVENT CORROSION.

PROVIDE ALL FITTINGS, ACCESSORIES, OFFSETS, AND MATERIALS NECESSARY TO FACILITATE THE PLUMBING SYSTEM'S FUNCTIONING AS INDICATED BY THE DESIGN AND THE EQUIPMENT INDICATED.

FIXTURES/EQUIPMENT FURNISHED BY OTHERS: PLUMBING CONTRACTOR SHALL PROVIDE UTILITY CONNECTIONS REQUIRED SUCH AS WATER, GAS, AIR, SUPPLIES, WASTE OUTLET, TRAPS, ETC., AT ALL PLUMBING TYPE FIXTURES OR EQUIPMENT FURNISHED BY OWNER. GENERAL CONTRACTOR, FOOD SERVICE CONTRACTOR, EQUIPMENT SUPPLIER, ETC., INCLUDED ARE STOP VALVES, ESCUTCHEONS, AND CHROME PLATED BRASS TUBING WITH COMPRESSION FITTINGS.

SEWER AND WASTE PIPING: PROVIDE ALL DRAINS AND SEWERS WITHIN THE SPACE WITH CONNECTION TO THE EXISTING DRAINAGE SYSTEMS ON-SITE. SANITARY DRAINAGE PIPING ABOVE FLOOR SHALL BE CO-EXTRUDED PVC DWV (SCHEDULE 40) PIPE, FITTINGS AND CONNECTIONS. SANITARY DRAINAGE PIPING BELOW GRADE SHALL BE CO-EXTRUDED PVC DWV (SCHEDULE 40) PIPE WITH SOLVENT WELD FITTINGS MAY BE USED (WHERE PERMITTED BY CODE/LOCAL AUTHORITIES). ALL DRAINAGE PIPING SHALL BE UNIFORMLY PITCHED, 1/4" PER FOOT UNLESS OTHERWISE REQUIRED BY EXISTING CONDITIONS, OR INDICATED ON THE DRAWINGS.

VENTS: PROVIDE A COMPLETE SYSTEM OF STANDARD WEIGHT CAST IRON NO-HUB VENT RISERS WHERE THE CEILING SPACE IS USED AS A RETURN AIR PLENUM OR USE CO-EXTRUDED PVC DWV (SCHEDULE 40) PIPE (WHERE PERMITTED BY CODE/LOCAL AUTHORITIES) WHERE THERE IS A DUCTED RETURN AIR SYSTEM. DO NOT USE PVC PIPE IN RETURN AIR PLENUM SPACES. THE VENT SYSTEM SHALL BE CARRIED THROUGH THE ROOF WITH APPROPRIATE FLASHING.

CONDENSATE AND INDIRECT DRAIN PIPING: PIPING ABOVE FLOOR SHALL BE CO-EXTRUDED PVC DWV (SCHEDULE 40) PIPE, FITTINGS AND CONNECTIONS. PIPING BELOW GRADE SHALL BE CO-EXTRUDED PVC DWV (SCHEDULE 40) PIPE WITH SOLVENT WELD FITTINGS.

CLEANOUTS: PROVIDE CLEANOUTS AT THE END OF EACH HORIZONTAL RUN, AND AT THE BASE OF ALL VERTICAL WASTE AND DRAIN PIPES. CLEANOUTS SHALL BE OF THE SAME SIZE AS THE PIPES THEY SERVE, CONFORMING TO CODE REQUIREMENTS. PROVIDE SUITABLE WALL OR FLOOR CLEANOUTS WITH ACCESSORIES TO OBSCURE FROM VIEW.

WATER DISTRIBUTION PIPING: LAYOUT WATER PIPING SO THAT THE ENTIRE SYSTEM CAN BE DRAINED. HOT AND COLD WATER PIPING SHALL BE 1/2" MIN. CPVC PIPE WITH SOLVENT FITTING. PROVIDE WATER HAMMER ARRESTERS AT EACH FIXTURE OR GROUP OF FIXTURES AS REQUIRED. INSTALL CHROME PLATED BRASS ESCUTCHEON PLATES AT ALL PENETRATIONS THROUGH FINISHED SURFACES INCLUDING TO OBSCURE FROM VIEW.

PIPE INSULATION: INSULATE (AS ALLOWED BY CODE) ALL LISTED SERVICE PIPING AS FOLLOWS. DOMESTIC COLD/HOT WATER, HOT WATER RETURN, STORM WATER PIPING, PROVIDE 1" PREFORMED FIBERGLASS, AS/SS-11, FLAME SPREAD 25, SMOKE DEVELOPED 50, ASTM-C-547, FOR CONDENSATE PIPING PROVIDE 1/2" THICK INSULATION OF SAME CHARACTERISTICS AS LISTED FOR 1" ABOVE, WHERE PERMITTED BY LOCAL CODES, PROVIDE 1/2" SELF-ADHESIVE UNICELLULAR FOAM PIPE INSULATION WITH PREFORMED PVC FITTING COVERS, EQUAL TO SELF-ADHESIVE ARMSTRONG 2000 WITH K FACTOR OF 0.27 AT 75 DEGREES MEAN TEMPERATURE. INSULATE ANY EXPOSED CONDENSATE PIPING WITH WASTE TEMPERATURE BELOW 40 DEGREES F.

SHUTOFF VALVES, WITH UNIONS SHALL BE PROVIDED FOR SERVICE TO EACH PLUMBING FIXTURE. FOOD SERVICE EQUIPMENT ITEM OR OTHER EQUIPMENT ITEM, TO FACILITATE ISOLATION FOR REPAIR OR REPLACEMENT. VALVES SHALL BE EQUAL TO JENKINS #9921 BALL VALVE, CHROME-FINISHED BRONZE, TEFLON SEATS AND PACKING, 400 LB. W.O.G., SOLDER END.

ACCESS PANELS SHALL BE PROVIDED WHERE CONCEALED CONTROL DEVICES, VALVES, ETC. ARE CONCEALED WITHIN WALLS, WHERE ACCESS FOR ADJUSTMENT AND MAINTENANCE IS POSSIBLE THROUGH LAY-IN SUPPORTED CEILINGS. ACCESS PANELS ARE NOT REQUIRED.

PIPING SYSTEM - PVC SCHEDULE 40, SCHEDULE 80 AND CPVC PIPE WITH SOLVENT FITTINGS SHALL BE USED WHERE PERMITTED BY CODE/LOCAL AUTHORITIES.

INSTALLATION: THOROUGHLY CLEAN ITEMS BEFORE INSTALLATION. CAP PIPE OPENINGS TO EXCLUDE DIRT UNTIL FIXTURES ARE INSTALLED AND FINAL CONNECTIONS HAVE BEEN MADE. PROCEED AS RAPIDLY AS CONSTRUCTION WILL PERMIT. SET FIXTURES LEVEL AND IN PROPER ALIGNMENT. INSTALL SUPPLIES IN PROPER ALIGNMENT WITH FIXTURES. INSTALL SILICONE SEALANT BETWEEN FIXTURES AND ADJACENT MATERIAL, FOR SANITARY JOINT, AND OMIT ESCUTCHEONS.

REPAIR EXISTING PLUMBING SYSTEM COMPONENTS DAMAGED BY CONSTRUCTION OPERATIONS AND RESTORE TO ORIGINAL CONDITIONS.

TEST WATER SYSTEM UNDER 150 PSIG HYDROSTATIC PRESSURE, FOR FOUR (4) HOURS MINIMUM. WHEN TESTING INDICATES MATERIALS OR WORKMANSHIP IS DEFICIENT, REPLACE OR REPAIR AS REQUIRED; AND REPEAT TEST UNTIL STANDARDS ARE ACHIEVED.

ROOF PENETRATIONS SHALL COMPLY WITH "SMACNA" AND "NRCA" STANDARDS, AND WITH THE REQUIREMENTS OF THE EXISTING ROOFING WARRANTY, IF APPLICABLE. DO NOT PERFORM ROOFING PENETRATIONS IN A MANNER WHICH WOULD VOID OR OTHERWISE LIMIT THE EXISTING ROOFING WARRANTY.

GENERAL NOTES

1. THE INTENT OF THESE PLANS AND SPECIFICATIONS IS TO INCLUDE ALL LABOR, EQUIPMENT, MATERIALS, AND SERVICES NECESSARY TO FURNISH, INSTALL, TEST, AND ADJUST A COMPLETE WORKABLE PLUMBING INSTALLATION AS SHOWN, PRESCRIBED, OR REASONABLY IMPLIED BUT NOT LIMITED TO THAT EXPLICITLY INDICATED IN THE CONTRACT DOCUMENTS, BUT NECESSARY FOR THE PROPER EXECUTION AND COMPLETION OF THE INTENT THEREOF.

2. THE ENTIRE INSTALLATION SHALL CONFORM TO THE REQUIREMENTS OF THE 2006 UNIFORM PLUMBING CODE, 2006 INTERNATIONAL BUILDING CODE, 2006 INTERNATIONAL ENERGY CONSERVATION CODE AND ALL OTHER APPLICABLE CODES AND REGULATIONS REQUIRED BY AUTHORITIES HAVING JURISDICTION. IN THE EVENT OF CONFLICT BETWEEN SPECIFICATIONS, CODES, AND REGULATIONS, THE MORE RESTRICTIVE SHALL APPLY.

3. COORDINATE ENTIRE INSTALLATION OF THE PLUMBING SYSTEM WITH THE WORK OF OTHER TRADES PRIOR TO ANY FABRICATION OR INSTALLATION. FIELD VERIFY ALL DIMENSIONS AND CONDITIONS. REPORT ANY DISCREPANCIES, IN WRITING, TO THE ENGINEER PRIOR TO COMMENCEMENT OF WORK.

4. CONTRACTOR SHALL PROVIDE AS-BUILT DRAWINGS WITH ALL CHANGES NOTED THEREON AT THE COMPLETION OF THE PROJECT IN ACCORDANCE WITH THE SPECIFICATIONS.

5. PROVIDE ONE YEAR WARRANTY ON ALL PARTS AND LABOR.

6. THE DRAWINGS ARE DIAGRAMMATIC AND INTENDED TO SHOW SCOPE. CONTRACTOR SHALL COORDINATE HIS WORK WITH OTHER TRADES TO PROVIDE THE BEST ARRANGEMENT OF ALL DUCT, PIPE, CONDUIT, ETC.

7. ALL CUTTING AND PATCHING OF THE EXISTING STRUCTURE SHALL BE PROVIDED UNDER OTHER SECTIONS OF THE WORK. PROVIDE NECESSARY REQUIREMENTS TO THE PROJECT SUPERINTENDENT.

8. ALL HOT WATER PIPING AND RECIRCULATION PIPING (EXCEPT RUNOUTS 12 FT. OR SHORTER TO INDIVIDUAL FIXTURES) SHALL BE INSULATED TO MEET THE REQUIREMENTS OF THE 2006 INTERNATIONAL ENERGY CONSERVATION CODE

9. CONDENSATE DRAINS SHALL BE PROVIDED FOR EACH AIR CONDITIONING UNIT. HORIZONTAL CONDENSATE DRAINS ABOVE ANY CEILING SHALL BE INSULATED WITH MIN. 3/8" THICK CLOSED CELL INSULATION.

10. PIPING:
A. WASTE, VENT, AND STORM DRAIN PIPING SHALL BE CO-EXTRUDED PVC (SCHEDULE 40) PIPE
B. WATER PIPE SHALL BE CPVC PIPE

C. CONDENSATE PIPING SHALL BE CO-EXTRUDED PVC (SCHEDULE 40) PIPE
D. INSIDE GAS PIPING SHALL BE BLACK IRON SCHEDULE 40 WITH MALLEABLE IRON FITTINGS. OUTSIDE SHALL BE GALVANIZED IRON SCHEDULE 40 WITH GALVANIZED FITTINGS. GAS LINE TO BE PAINTED GRAY IN COLOR. A 24 HOUR METERED GAS TEST SHALL BE REQUIRED.
E. ALL PIPING NOT ENCLOSED IN CONDITION SPACE OR AT EXTERIOR WALLS SHALL BE INSULATED.
F. PIPING: PVC SCHEDULE 40, SCHEDULE 80 AND CPVC PIPING WITH SOLVENT WELD FITTINGS SHALL BE USED WHERE PERMITTED BY CODE/LOCAL AUTHORITIES

11. ALL VENTS OR EXHAUSTS SHALL BE AT LEAST 10 FT. AWAY OR 3 FT. ABOVE ANY WINDOW, DOOR, OPENING, OR AIR INTAKE.

12. CLEANOUTS SHALL BE INSTALLED PER THE UNIFORM PLUMBING CODE.

13. PROVIDE WATER TIGHT FLASHINGS WHEREVER PIPES PASS THROUGH EXTERIOR WALLS, ROOFS, OR FLOORS.

14. PROVIDE ISOLATION FOR ALL PIPES THAT COME IN CONTACT WITH THE STRUCTURE.

15. LOCATION OF EXISTING UTILITIES AND POINTS OF CONNECTION ARE APPROXIMATE. CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND DEPTHS OF EXISTING UTILITIES AND SERVICES PRIOR TO STARTING WORK OF THIS SECTION. IF INDICATED POINTS OF CONNECTION CANNOT BE MADE TO EXISTING UTILITIES AS FOUND, THE CONTRACTOR SHALL NOTIFY THE ENGINEER PRIOR TO INSTALLING ANY WORK WHICH MAY BE AFFECTED.

16. VALVES SHALL BE NIBCO, JENKINS, HAMMOND, RED & WHITE OR APPROVED EQUAL. SERVICE PRESSURE SHALL BE SUITABLE FOR SERVICE INTENDED. THE MAIN WATER SHUT OFF VALVE SHALL BE A FULL PORT BALL TYPE AND APPROVED FOR SERVICE INTENDED.

17. CONTRACTOR SHALL PROVIDE ALL SHUT OFF VALVES AS NECESSARY TO ISOLATE ANY EQUIPMENT, PLUMBING ITEMS, OR FIXTURES, THAT MAY NEED SERVICING OR ARE SUBJECT TO FAILURE WHETHER OR NOT SUCH VALVES ARE SHOWN ON THE DRAWINGS.

18. PROVIDE HANGERS AND SUPPORTS AS REQUIRED. PLUMBERS TAPE AND WIRE ARE NOT ACCEPTABLE.

19. CONTRACTOR IS RESPONSIBLE FOR HIS OWN TRENCHING, BACKFILL, AND COMPACTION OF TRENCHES NECESSARY TO COMPLETE HIS SCOPE OF WORK. BACKFILLED TRENCHES SHALL BE RETURNED TO THEIR ORIGINAL GRADE UNLESS NOTED OTHERWISE.

20. CONTRACTOR SHALL AFFIX A MAINTENANCE LABEL TO ALL EQUIPMENT REQUIRING ROUTINE MAINTENANCE AND SHALL PROVIDE MAINTENANCE AND OPERATIONAL MANUALS IN ACCORDANCE WITH THE SPECIFICATIONS.

21. ALL EQUIPMENT THAT REQUIRES KEYS OR SPECIAL TOOLS TO OPERATE SHALL SUPPLY THE OWNER WITH TWO OF ANY SUCH KEYS OR TOOLS FOR EACH PIECE OF EQUIPMENT THAT REQUIRE THE SAME.

25. ANY CHANGE OR DEVIATION FROM THESE PLANS OR SPECIFICATIONS SHALL REQUIRE THE APPROVAL, IN WRITING, OF THE ENGINEER PRIOR TO COMMENCEMENT OF SUCH WORK.

26. ALL PLUMBING, ELECTRICAL, AND GAS LINES SHALL BE CONCEALED WITHIN THE BUILDING STRUCTURE TO AS GREAT EXTENT AS POSSIBLE. ALL LINES NOT CONCEALED SHALL BE SECURED 6" OFF THE FLOOR AND 3/4" FROM THE WALLS USING STANDOFF BRACKETS

27. AN APPROVED BACKFLOW PREVENTOR SHALL BE PROPERLY INSTALLED UPSTREAM OF ANY POTENTIAL HAZARD BETWEEN THE POTABLE WATER SUPPLY AND SOURCE OF CONTAMINATION.

28. WATER SUPPLY CARBONATORS SHALL BE PROTECTED BY AN APPROVED REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTOR. THE RELIEF VALVE SHALL DRAIN DIRECTLY TO A FLOOR SINK WITH A 1" MIN. AIR GAP.

PIPE MATERIAL SCHEDULE										
SERVICE		COPPER	COPPER	COPPER	CAST	BLACK	GALV.	YVR.	ABS	SCH.40 PVC
		TYPE "M"	TYPE "L"	TYPE "K"	IRON	STEEL	STEEL	CLAY		
WATER PIPING	INSIDE		X							
	OUTSIDE									
SANITARY DRAIN	INSIDE									X
	OUTSIDE									X
SANITARY VENT	INSIDE									X
	OUTSIDE									X
GAS PIPING	INSIDE				X					
	OUTSIDE						X			
STORM DRAIN	INSIDE									X
	OUTSIDE									
INDIRECT DRAINAGE	INSIDE								X	
	OUTSIDE								X	
CONDENSATE	INSIDE								X	
	OUTSIDE								X	
COMPRESSED AIR	INSIDE				X					
	OUTSIDE					X	X			
NOTES:										

PLUMBING LEGEND		
SYMBOL	ABBREV	DESCRIPTION
	SS or W	NEW SEWER OR WASTE
	V	NEW VENT
	CW	NEW COLD WATER
	HW	NEW HOT WATER
	G	NEW GAS
	CD	NEW CONDENSATE DRAIN
	CA	COMPRESSED AIR
	FCO	FLOOR CLEANOUT
	WCO	WALL CLEANOUT
	FD	FLOOR DRAIN
	FS	FLOOR SINK
	TP	TRAP PRIMER & TRAP PRIMER PIPING
	SOV	SHUTOFF VALVE
	CV	CHECK VALVE
	PRV	BACKFLOW PREVENTER W/ SOVS
	RFI	RAIN FILL
	DN	PIPE DOWN
	UP	PIPE UP
	POC	POINT OF CONNECTION
	PNM	PLUMBING NOTE CALL-OUT ABOVE
	ABV	ABOVE FINISH FLOOR
	AP	ACCESS PANEL
	BL	BELOW
	BLDG	BUILDING
	CLG	CEILING
	CON	CONNECTION
	EL	ELEVATION
	FIN	FINISH
	FL	FLOOR
	GR	GRADE
	NIS	NOT TO SCALE
	OC	ON CENTER
	SL	SLOPE AT A PERCENTAGE
	SH	SHEET
	TP	TYPICAL
	VIR	VENT INTO ROOF

PLUMBING / GENERAL NOTES

BATHUBS AND WHIRLPOOL BATHUBS. THE MAX. HOT WATER TEMPERATURE DISCHARGING SHALL BE LIMITED TO 120 DEGREES. CPC 4.402.19
BATHUBS WASTE OPENING IN FLOOR OVER CRAWL SPACES SHALL BE PROTECTED BY A METAL SCREEN NOT EXCEEDING 1/2" OR SOLID COVER. CPC 3.113.12.4.2019
SHOWERS AND TUB-SHOWERS COMBINATIONS IN ALL BUILDINGS SHALL BE PROVIDED WITH INDIVIDUAL CONTROL VALVES OF THE PRESSURE BALANCE, THERMOSTATIC, OR COMBINATION OF BOTH THAT PROVIDE SCALD AND THERMAL SHOCK PROTECTION. VALVES SHALL BE ADJUSTED TO DELIVER A MAXIMUM MIXED WATER SETTING OF 120 DEGREES FAHRENHEIT. THE WATER HEATER THERMOSTAT SHALL NOT BE CONSIDERED A SUITABLE CONTROL FOR MEETING THIS PROVISION. 418.0 CPC/2019
VERIFY AND WHERE WATER PRESSURE EXCEEDS 80 PSI AN APPROVED PRESSURE REGULATOR PRECEDED BY AN ADEQUATE STRAINER SHALL BE INSTALLED 408.2 C/C / 2019
1. INSTALL TEMPERATURE AND PRESSURE RELIEF VALVE WITH MINIMUM 3/4" DRAIN PIPE AND TERMINATE TO THE EXTERIOR OF THE BUILDING OVER WINDOW, DOOR OR VISIBLE LOCATION. DISCHARGE FROM A RELIEF VALVE INTO A WATER HEATER PAN SHALL BE PROHIBITED CPC 608.5, 510.8.
2. PROVIDE (ON THE PLANS) A GAS PIPING DIAGRAM OF THE GAS PIPING SYSTEM THAT INCLUDES ALL PIPE SIZES, PIPE LENGTHS AND BTU RATINGS.

3. SUBMIT GAS LOAD CALCULATIONS IN ACCORDANCE WITH CPC TABLE 12-8 TO VERIFY THE PIPE SIZES ARE ADEQUATE FOR THE MAXIMUM DELIVERY CAPACITY OF CUBIC FEET OF GAS PER HOUR.
4. A WHOLE HOUSE GAS TEST IS REQUIRED UPON COMPLETION OF THE INSTALLATION, ALTERATION, OR REPAIR OF ANY GAS PIPING. THE CITY SHALL BE NOTIFIED WHEN GAS PIPING IS READY FOR INSPECTION.
5. 2 GPM SHOWER FIXTURE, MAX. 1.8 GPM BATHROOM FAUCET, MAX. 2 GPM KITCHEN FAUCET, AND MAX. 1.28 WATER CLOSET TO CONFORM TO CITY GREEN REQUIREMENTS.

BATHROOMS: PROVIDE AN EXHAUST FAN (AT LEAST 50 CFM) DUCTED TO THE OUTSIDE (MINIMUM 4" DIAMETER FLEX DUCT WITH A MAXIMUM LENGTH OF 70') WITH A MINIMUM VENTILATION RATE OF 100 CFM, IDENTIFY THE REQUIREMENT FOR A BACKDRAFT DAMPER ON THE DUCT, AN ENERGY STAR COMPLIANT EXHAUST FAN THAT IS CONTROLLED BY A HUMIDITY SENSOR THAT IS CAPABLE OF BEING ADJUSTED BETWEEN ≤ 50–PERCENT TO 80–PERCENT HUMIDITY; AND A SEPARATE SWITCH FROM THE LIGHT UNLESS THE FAN IS ALLOWED TO OPERATE WITH THE LIGHT SWITCHED OFF.

6- NOTE THAT ALL PLUMBING VENTS SHALL TERMINATE NOT LESS THAN 6" ABOVE ROOF NOR LESS THAN 1' FROM ANY VERTICAL SURFACE. VENTS SHALL TERMINATE NOT LESS THAN 10" FROM OR 3' ABOVE ANY WINDOW, DOOR, OPENING AIR INTAKE, OR VENT SHAFT NOR 3' FROM LOT LINE. (2019 CPC 906) IF WATER PRESSURE EXCEEDS 80 PSI, AND EXPANSION TANK AND AN APPROVED PRESSURE REGULATOR SHALL BE INSTALLED. (2019 CPC 608.2) NON-REMOVABLE BACK FLOW PRE-VENTER OR BIRD-TYPE VACUUM BREAKER WILL BE INSTALLED ON ALL EXTERIOR HOSE BIBS. (2019 CPC 603.4.7) HOT WATER RE-CIRCULATING SYSTEM IS INSTALLED, THE ENTIRE LENGTH OF HOT WATER PIPES SHALL BE INSULATED. (2008 CALIFORNIA ENERGY REGULATIONS 150 (J)) HOT WATER PIPE FROM THE WATER HEATER TO THE KITCHEN WILL BE INSULATED. (2008 CALIFORNIA ENERGY REGULATIONS 151(F) 8 D)

PLUMBING FIXTURE FLOW RATE

FIXTURE TYPE	MAXIMUM FLOW RATE
Water closets	1.28 gallons flush
Shower heads	2.0 gpm @ 80 psi
Lavatory faucets	1.2 gpm @ 60 psi
Kitchen faucets	1.8 gpm @ 60 psi

NOTES:
1- Projects which disturb less than one acre of soil shall manage storm water drainage during construction by one of the following: A. Retention basins. B. Where storm water is conveyed to a public drainage system, water shall be filtered by use of a barrier system, watfle or other approved method.
2- Site grading or drainage system will manage all surface water flows to keep water from entering buildings (swales, water collection, French drains, etc.). CGC Section 4.106.3. Exception: Additions not altering the drainage path.
3- When a shower is provided with multiple shower heads, the sum of flow to all the heads shall not exceed 1.8 gpm @ 80 psi, or the shower shall be designed so that only one head is on at a time. CGC Section 4.303.1.3.2.
4- Landscape irrigation water use shall have weather or soil based controllers. CGC Section 4.304.1.
5- The plans that a minimum of 65% of construction waste is to be recycled. CGC Section 4.408.1.
6- The contractor shall submit a Construction Waste Management Plan, per CGC Section 4.408.2.
7- The builder is to provide an operation manual (containing information for maintaining appliances, etc.) for the owner at the time of final inspection. CGC Section 4.410.1.
8- The gas fireplace(s) shall be a direct-vent sealed- combustion type. Woodstove or pellet stoves must be US EPA Phase II rated appliances. CGC Section 4.503.1.

WATER SAVING STANDARDS.

THE WATER SAVING PERFORMANCE STANDARDS FOR A PLUMBING FIXTURE ARE THOSE ESTABLISHED BY THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI), CURRENT REVISION, OR THE FOLLOWING STANDARDS, WHICHEVER ARE THE MORE RESTRICTIVE.
1. THE MAXIMUM FLOW FROM A SINK OR LAVATORY FAUCET OR A FAUCET AERATOR SHALL NOT EXCEED 0.5 GALLONS OF WATER PER MINUTE AT A PRESSURE OF 40 POUNDS PER SQUARE INCH WHEN TESTED IN ACCORDANCE WITH ANSI TESTING PROCEDURES
2. THE MAXIMUM VOLUME OF WATER PER FLUSH FROM A TOILET SHALL NOT EXCEED AN AVERAGE OF 1.28 GALLONS WHEN TESTED IN ACCORDANCE WITH ANSI TESTING PROCEDURES
3. THE MAXIMUM VOLUME OF WATER PER FLUSH FROM A URINAL AND THE ASSOCIATED FLUSH VALVE, IF ANY, SHALL NOT EXCEED AN AVERAGE OF ONE GALLON WHEN TESTED IN ACCORDANCE WITH ANSI TESTING PROCEDURES

SPECIAL NOTICE TO CONTRACTORS

1. ALL CONTRACTORS (GENERAL CONTRACTOR AND SUB-CONTRACTORS) BIDDING THIS PROJECT ARE REQUIRED TO VISIT THE JOB SITE AND VERIFY THE EXISTING CONDITIONS PRIOR TO SUBMITTING THEIR BID. CONTRACTORS ARE TO CAREFULLY REVIEW ALL CONSTRUCTION DOCUMENTS AND NOTE ANY DISCREPANCIES BETWEEN THE CONSTRUCTION DOCUMENTS AND THE CONDITIONS OBSERVED AT THE JOB SITE PRIOR TO SUBMISSION OF ANY BID. THE BUILDING OWNER REPRESENTATIVE LISTED BELOW MAY BE CONTACTED FOR ACCESS TO THE JOB SITE.
2. CONTRACTORS ARE RESPONSIBLE FOR VERIFYING THE LOCATION AND CONDITION OF ALL POINTS OF CONNECTION, LOCATION AND CONDITION OF ALL BUILDING (ROOF/FLOOR/CEILING) PENETRATIONS, LOCATION AND CONDITION OF ALL UTILITIES AND BUILDING SYSTEMS INCLUDING, BUT NOT LIMITED TO, GAS, WATER, SEWER, VENT, ELECTRICAL, BUILDING MECHANICAL SYSTEMS, DUCT CONDITIONS, EXTERIOR/OUTSIDE AIR CONNECTIONS, SECURITY, FIRE ALARM, DATA, AND PHONE PRIOR TO SUBMISSION OF THEIR BID.
3. ANY DISCREPANCIES BETWEEN THE CONSTRUCTION DOCUMENTS AND THE CONDITIONS OBSERVED SHALL BE BROUGHT TO THE ATTENTION, IN WRITING, TO THE ARCHITECT AND/OR ENGINEER PRIOR TO PROCEEDING WITH CONSTRUCTION.

PLUMBING SPECS
SCALE : NTS

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:

PLUMBING SPECIFICATIONS,
LEGEND AND GENERAL NOTES


PROJ. NO. PROJ. ENGR. SCALE @ 24X36:

NTS

DRAWING NO.

REV.

P 0 . 0 0



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 → 1-1/2" WASTE DROP AND 2" VENT RISE.
- 2 → 2" VENT RISE TO HIGH LEVEL.
- 3 → 3" FLOOR DRAIN.
- 4 → 4" FLOOR CLEAN-OUT.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPERIUM ROOTS

TITLE:
DRAINAGE LAYOUT 1 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"
-----------	-------------	-------------------------------

DRAWING NO. P 1 . 0 1 A	REV.
-----------------------------------	------



- PLUMBING SHEET NOTES**
- SHEET NOTES:**
- 1 — 1-1/2" WASTE DROP AND 2" VENT RISE.
 - 2 — 2" VENT RISE TO HIGH LEVEL.
 - 3 — 3" FLOOR DRAIN.
 - 4 — 4" FLOOR CLEAN-OUT.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.


- NOTES:**
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
 2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
 3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
 4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS

TITLE: **DRAINAGE LAYOUT 1 OF 4**

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"
DRAWING NO. P 1 . 0 1 B		REV.



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 — 1-1/2" WASTE DROP AND 2" VENT RISE.
- 2 — 2" VENT RISE TO HIGH LEVEL.
- 3 — 3" FLOOR DRAIN.
- 4 — 4" FLOOR CLEAN-OUT.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:


DRAINAGE LAYOUT 3 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		1/4"=1'-0"

DRAWING NO.

P 1 . 0 1 C

REV.



MATCHLINE
MATCHLINE

MATCHLINE MATCHLINE

PLUMBING SHEET NOTES

SHEET NOTES:

- 1 — 1-1/2" WASTE DROP AND 2" VENT RISE.
- 2 — 2" VENT RISE TO HIGH LEVEL.
- 3 — 3" FLOOR DRAIN.
- 4 — 4" FLOOR CLEAN-OUT.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:


DRAINAGE LAYOUT 4 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		1/4"=1'-0"

DRAWING NO.

P 1 . 0 1 D

REV.



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 → DCW, DHW RISE TO HIGH LEVEL.
2 → 1/2" DCW & 1/2" DHW DROP IN WALL.
3 → DCW FROM BELOW FLOOR.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:


WATER SUPPLY LAYOUT 1 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		3/16"=1'-0"

DRAWING NO.

P 2 . 0 1 A

REV.



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 → DCW, DHW RISE TO HIGH LEVEL.
- 2 → $\frac{1}{2}$ " DCW & $\frac{1}{2}$ " DHW DROP IN WALL.
- 3 → DCW FROM BELOW FLOOR.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:

WATER SUPPLY LAYOUT 2 OF 4

PROJ. NO.

PROJ. ENGR.


SCALE @ 24X36:

3/16"=1'-0"

DRAWING NO.

P 2 . 0 1 B

REV.



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 — DCW, DHW RISE TO HIGH LEVEL.
- 2 — $\frac{1}{2}$ " DCW & $\frac{1}{2}$ " DHW DROP IN WALL.
- 3 — DCW FROM BELOW FLOOR.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:


IMPERIUM ROOTS

TITLE:

WATER SUPPLY LAYOUT 3 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'-0"
-----------	-------------	------------------------------

DRAWING NO. P 2 . 0 1 C	REV.
-----------------------------------	------



PLUMBING SHEET NOTES

SHEET NOTES:

- 1 → DCW, DHW RISE TO HIGH LEVEL.
- 2 → 1/2" DCW & 1/2" DHW DROP IN WALL.
- 3 → DCW FROM BELOW FLOOR.

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

- NOTES:**
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
 2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
 3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
 4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS

TITLE: **WATER SUPPLY LAYOUT 4 OF 4**

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'-0"
-----------	-------------	------------------------------

DRAWING NO. P 2 . 0 1 D	REV.
-----------------------------------	------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:


IMPERIUM ROOTS

TITLE:

**FERTILIZER/IRRIGATION LAYOUT
1 OF 4**

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"
-----------	-------------	-------------------------------

DRAWING NO. P 3 . 0 1 A	REV.
-----------------------------------	------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:


FERTILIZER/IRRIGATION LAYOUT
2 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'-0"
-----------	-------------	-------------------------------

DRAWING NO.

P 3 . 0 1 B

REV.



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS

TITLE: **FERTILIZER/IRRIGATION LAYOUT**
3 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'-0"
-----------	-------------	------------------------------

DRAWING NO. P 3 . 0 1 C	REV.
-----------------------------------	------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS

TITLE: **FERTILIZER/IRRIGATION LAYOUT**
4 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'-0"
-----------	-------------	------------------------------

DRAWING NO. P 3 . 0 1 D	REV.
-----------------------------------	------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPERIUM ROOTS

TITLE:

FERTILIZER SINGLE LINE DIAGRAM

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: NTS

DRAWING NO.

P 3 . 0 2

REV.

SCHEDULE No. 1
COMMERCIAL ELECTRIC WATER HEATER

TAG	WH-01	WH-02
LOCATION	TOILETS & KITCHEN	TOILETS
MANUFACTURER	AO SMITH	AO SMITH
MODEL	DEN-40	DEN-52
TYPE	ELECTRICAL	ELECTRICAL
NOMINAL CAPACITY (GAL)	40.0	52.0
UEF	0.92	0.92
ELECTRICAL POWER (KW)	6000	6000
DIMENSION (Ø x H) INCHES	20.5" x 59"	24" x 56.5"
ELECTRICAL V/PH/Hz	120/1/60	120/1/60
HOT & COLD CONNECTION (INCH)	3/4 NPT	3/4 NPT

WATER CONSERVING PLUMBING FIXTURES AND FITTINGS	
4303.1.1	All Water closets: <1.28 gal/flush Tank type water closet shall be certified to the performance criteria of the U.S. EPA WaterSense Specification for Tank-type Toilets.
4303.1.2	Urinals: <0.5 gal/flush
4303.1.3.1	Single showerheads: <1.8 gpm @ 80 psi
4303.1.3.2	Multiple showerheads: combined flow rate of all showerheads and/or other shower outlets controlled by a single valve shall not exceed 1.8 gpm @ 80 psi or only one shower outlet is to be in operation at a time.
4303.1.4.1	Residential Lavatory Faucets: 0.8 gpm @ 20 psi < Flow Rate <1.2 gpm @ 60 psi
4303.1.4.2	Lavatory Faucets in common and Public Use Areas (outside of dwellings or sleeping units) in residential buildings: <0.5 gpm @ 60 psi
4303.1.4.3	Metering Faucets: <0.25 gallons per cycle
4303.1.4.4	Kitchen Faucets: <1.8 gpm @ 60 psi; Maximum Flow Rate of 1.8 gpm

PLUMBING FIXTURE CERTIFICATION REQUIRED:

A plumbing fixture certification must be completed and signed by either a licensed general contractor, or a plumbing subcontractor, or the building owner certifying the flow rate of the fixtures installed. A copy of the certification can be obtained from the development services department.



Commercial Electric
Water Heaters

DURA-POWER™

Designed for use as a recovery heater having its own storage tank. Available in upright standard models (DEN) and lowboy models (DEL).

GLASSLINED TANK

- Thirteen sizes; 6 thru 119 gallon capacity. Tank interior is coated with glass specially designed by A. O. Smith for water heater use.

ELEMENTS

- Zinc plated copper sheaths for longer life. Medium watt density means lower surface temperature to minimize scale build-up and more surface to heat water. Element sizes from 1.5 to 6.1 KW. Maximum input KW (see chart).

STANDARD VOLTAGES

- 120, 277 single phase and 208, 240 and 480V unbalanced three-phase delta, easily converted to single-phase at terminal block (except 208V with 5500 watt elements). Single element heaters, single-phase only.

TERMINAL BLOCK

- Factory-installed. Just bring the service to heater and connect to block. Terminal block not supplied on 120V & 277 volt models. (No junction box on DEL-6-20)

CONTROLS

- Temperature control (adjustable through a range of 130° to 170°F on single element and 120° to 180°F on dual element) and manual reset high temperature cutoff per element

CSA CERTIFIED AND ASME RATED
T&P RELIEF VALVE

SIMPLIFIED CIRCUITRY, COLOR
CODED FOR EASE OF SERVICE

ANODE ROD FOR MAXIMUM
CORROSION PROTECTION

CABINET HAS BONDZERIZED
UNDERCOAT WITH BAKED
ENAMEL FINISH

TOP INLET AND OUTLET OPENINGS

DRAIN VALVE
(EXCLUDES DEL 6-20)

UL APPROVED FIELD CONVERSION
PROGRAM

COMPLIANCE

- Meets the standby loss Requirements of the U.S. Department of Energy and current edition of ASHRAES 90.1

LIMITED WARRANTY OUTLINE

- If the tank should leak any time during the first three years, under the terms of the warranty, A. O. Smith will furnish a replacement heater; installation, labor, handling and local delivery extra. THIS OUTLINE IS NOT A WARRANTY. For complete information consult the written warranty or A. O. Smith Water Products Company.




© January 2022 A. O. Smith Corporation. All rights reserved.
www.aosmith.com | 800-527-1033 Toll-Free USA | A. O. Smith Corporation | 500 Tennessee Valley Parkway | Ashland City, TN 37015

Page 1 of 4
A0SCET15400



Commercial Electric
Water Heaters



ROUGH-IN DIMENSIONS

Models	UEF	No. of Elements	Nominal Capacity	Rated Storage Volume	A		B		C		D		Shipping Weight		
					Inches	mm	Inches	mm	Inches	mm	Inches	mm	Lbs.	Kg.	
DEL-6	N/A	1	6	6	15-1/2	394	14-1/4	362	11	279	N/A	N/A	N/A	35	15.9
DEL-10	N/A	1	10	10	18-1/4	464	18	457	12-1/2	318	N/A	N/A	N/A	54	24.5
DEL-15	N/A	1	15	15	26	660	18	457	20-1/2	521	N/A	N/A	N/A	58	26.3
DEL-20	N/A	1	20	19	22-1/8	565	21-3/4	552	19-3/8	391	N/A	N/A	N/A	73	33.1
DEL-30	0.92	2	30	33	33-1/2	851	26	660	24	610	8	203	118	53.5	
DEL-40**	0.92	2	40	35	32	813	23	584	24	610	8	203	118	53.5	
DEL-50	0.92	2	50	48	36	914	26-1/2	673	25	635	8	203	172	78	
DEN-30	0.92	2	30	37	49-3/4	1264	29-1/2	751	53-1/4	1353	8	203	118	53.5	
DEN-40	0.92	2	40	45	50	1488	32-1/2	831	53-1/8	1353	8	203	128	56.7	
DEN-52	0.92	2	52	50	50	1661	34	861	56-1/2	1433	8	203	149	65.8	
DEN-66	N/A	2	66	60	60-3/4	1543	21-3/4	552	N/A	N/A	8	203	176	79.8	
DEN-80	N/A	2	80	76	59-3/8	1508	24	610	N/A	N/A	8	203	211	95.7	
DEN-120	N/A	2	120	108	62-7/16	1586	29-3/8	746	N/A	N/A	8	203	326	147.9	

*No side outlet available on DEL-6 Model

**Retrofit model

Note: All 60, 80 and 120 models will be manufactured with two 6.1kW elements - 12.2kW

U.S. Gallons/HR and Litres/HR at Temperature Rise Indicated												
Element Wattage (Upper/Lower)	Input KW	6°	36°	40°	54°	60°	72°	80°	90°	100°	108°	120°
		C°	20 C°	22.2 C°	30 C°	33.3 C°	40 C°	44.4 C°	50 C°	55.5 C°	60 C°	66.6 C°
6100/6100	12.2	GPH	138	124	92	82	69	62	55	49	46	41
		LPH	522	469	348	310	261	235	208	184	174	153

Recovery capacities at 100°F equal for simultaneous element operation - 4.1 gph x 2.9 KW of both elements.

For other rise multiply element KW as previously explained by 4.1 and divide by temperature rise.

Full load current for single phase = total watts.

Page 2 of 4
A0SCET15400

PLUMBING FIXTURE SCHEDULE												
FMTL ID	DESCRIPTION	MANUFACTURER	MODEL	ROUGH-IN				REMARKS				
				W	V	CW	HW					
3CS-1	3-COMPARTMENT SINK	SELECT BY ARCH/OWNER	-	3"	2"	3/4"	3/4"	SELECTED BY ARCHITECT/OWNER. VERIFY FOR EXACT SPECIFICATION AND MODEL NUMBER OF PLUMBING FIXTURE WITH ARCHITECT AND OWNER PRIOR TO ORDERING AND INSTALLATION				
HS-1	HAND SINK	SELECT BY ARCH/OWNER	-	2"	2"	1/2"	1/2"	SELECTED BY ARCHITECT/OWNER. VERIFY FOR EXACT SPECIFICATION AND MODEL NUMBER OF PLUMBING FIXTURE WITH ARCHITECT AND OWNER PRIOR TO ORDERING AND INSTALLATION				
TP-1	TRAP PRIMER	WATTS	LFTP300-DR	-	-	1/2"	-	WATTS DRAINAGE LFTP300-DR PRESSURE DROP ACTIVATED LEAD FREE BRASS TRAP PRIMER WITH EPDM SEALS, INTEGRAL AIR GAP, AND 1/2" SWEAT OR NPT THREADED CONNECTIONS. OPERATING PRESSURE 25 PSI - 125 PSI. TESTED AND APPROVED IN CONFORMANCE WITH ASSE STANDARD 1018. SPECIFY MODEL LFTP300-DU-DR FOR DISTRIBUTION UNIT.				
FCO	FLOOR CLEANOUT	WATTS	CO-200-S	PIPE SIZE	-	-	-	WATTS DRAINAGE CO-200-S EPOXY COATED CAST IRON FLOOR CLEANOUT WITH 5"X5" SQUARE ADJUSTABLE GASKETED NICKEL BRONZE TOP, REMOVABLE GAS TIGHT GASKETED BRASS CLEANOUT PLUG, AND NO HUB (STANDARD) OUTLET.				
WCO	WALL CLEANOUT	WATTS	CO-380	PIPE SIZE	-	-	-	WATTS DRAINAGE CO-380 CAST IRON CLEANOUT WITH GASKETED BRASS COUNTERSUNK PLUG, AND NO HUB CONNECTION.				
FS-1	FLOOR SINK	WATTS	FS-780	2"	2"	-	-	WATTS DRAINAGE FS-780 12" SQUARE X 6" DEEP 14 GA. TYPE 304 STAINLESS STEEL SANITARY FLOOR SINK WITH LOOSE SET CAST STAINLESS STEEL GRATE, DOME BOTTOM STRAINER, AND NO HUB (STANDARD) OUTLET.				
FD-1	FLOOR DRAIN	WATTS	FD-320-Y	2"	2"	-	-	WATTS DRAINAGE FD-320-Y EPOXY COATED CAST IRON AREA DRAIN WITH ANCHOR FLANGE, WEEPHOLES, 8" DIAMETER FIXED TOP WITH HEEL PROOF DUCTILE IRON GRATE, AND NO HUB (STANDARD) OUTLET				
WC-1	WATER CLOSET (ADA APPROVED)			4"	2"	3/4"	-	DELTA MODEL # C41908-WH4.5547(411) TURNER 2-PIECE 1.28 GPF SINGLE FLUSH ROUND FRONT TOILET IN WHITE. TOILET SHALL BE ADA AND ASME A112.19.1 COMPLIANT (OR APPROVED EQUAL).				
LAV-1	LAVATORY (ADA APPROVED)			2"	2"	1/2"	1/2"	"KOHLER" HUDSON MODEL K-2849 WHITE VITREOUS CHINA WALL MOUNTED LAVATORY WITH 4" CENTERS OR APPROVED EQUAL. INCLUDE MODEL K-7401-5A FAUCET WITH STANDARD AERATOR AND WRISTBLADE HANDLES. LAVATORY AND FAUCETS SHALL BE ADA AND ASME A112.19.1M COMPLIANT (OR APPROVED EQUAL)				

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

- ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
- THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
- THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
- THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY


PROJECT:

IMPERIUM ROOTS


TITLE:

PLUMBING EQUIPMENT SCHEDULE.


PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		NTS
DRAWING NO.		REV.
P 4 . 0 1		




1 TYPICAL WASTE AND VENT RISERS
SCALE: NONE




2 TRAP PRIMER
SCALE: NONE




3 FLOOR DRAIN WITH TRAP SEAL PROTECTION
SCALE: NONE




ANTI-SCALD MIXING VALVE
NO SCALE




MOP SINK DETAIL
NO SCALE




CONDENSATE DETAIL
NO SCALE




FLOOR SINK DETAIL
NO SCALE




TRAP PRIMER DETAIL
NO SCALE




VENT THRU ROOF DETAIL
NO SCALE




FLOOR DRAIN DETAIL
NO SCALE



FLOOR CLEANOUT DETAIL
NO SCALE



WATER ENTRY DETAIL
NO SCALE



COND. ON FLOOR SINK DETAIL
NO SCALE

CLIENT:
ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPERIUM ROOTS
TITLE: PLUMBING GENERAL DETAILS
PROJ. NO. PROJ. ENGR. SCALE @ 24X36: NTS
DRAWING NO. P 5 . 0 1 REV.

GENERAL ELECTRICAL NOTES	
#	DESCRIPTION
1	GENERAL CONTRACTOR SHALL VERIFY FIELD CONDITIONS BEFORE SUBMITTING BID. THE DRAWINGS SHALL BE INSTALLED AND CONNECTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE ARTICLE 300.
2	ALL WORK SHALL BE DONE IN ACCORDANCE WITH 2019 NEC, AS AMENDED BY 2019 ELECTRICAL CODE, 2019 ENERGY CODE AND ANY ADDITIONAL STATE OR LOCAL REQUIREMENTS.
3	GENERAL CONTRACTOR SHALL OBTAIN AND PAY FOR ALL PERMITS, CERTIFICATES, ETC. REQUIRED.
4	GENERAL CONTRACTOR SHALL OBTAIN AND PAY FOR BOTH ROUGH AND FINAL UNDER-WRITERS OR OTHER APPROVED INSPECTION AGENCY CERTIFICATES "ELECTRICAL INSPECTION". THESE CERTIFICATES SHALL BE PRESENTED WITH REQUEST FOR FINAL PAYMENT.
5	IT IS THE INTENT OF THESE PLANS TO PROVIDE A COMPLETE OPERATING ELECTRICAL SYSTEM. THIS CONTRACTOR SHALL FURNISH AND INSTALL ALL WIRING, EQUIPMENT, MATERIAL, ETC. REQUIRED, EXCEPT WHERE SPECIFICALLY NOTED AS BEING FURNISHED BY OTHERS. SHOULD THERE BE ANY QUESTIONS CONCERNING RESPONSIBILITY, THEY SHALL BE ADDRESSED TO ARCHITECT PRIOR TO BID. NO EXTRA CHARGES WILL BE ALLOWED.
6	ELECTRICAL SERVICE SHALL BE COORDINATED WITH THE EXISTING FIELD CONDITIONS.
7	CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS TO ALL CONTROLS, OWNER-SUPPLIED EQUIPMENT, MECHANICAL AND PLUMBING EQUIPMENT AS REQUIRED.
8	REFER TO ARCHITECTURAL DRAWINGS FOR ELEVATION DETAILS. ALL FIXTURE AND DEVICE LOCATIONS SHOWN ON ARCHITECTURAL DRAWINGS SUPERSEDE THOSE SHOWN ON ELECTRICAL PLANS.
9	CIRCUIT NUMBER ON THE DRAWINGS ARE FOR IDENTIFICATION ONLY AND DO NOT INDICATE THE POSITION ON THE PANEL BOARD. CONNECT THE CIRCUITS WITH THE LIGHTEST LOADS AND THE RECEIPTABLE CIRCUITS NEAR THE TOP OF THE PANEL, AND THE MORE HEAVILY LOADED CIRCUITS NEAR THE BOTTOM. BALANCE ALL CIRCUITS EVENLY BETWEEN PHASE SO THAT FEEDER WIRES CARRY APPROXIMATELY EQUAL CURRENT. ALL PHASES MUST BE BALANCED WITHIN 10% OR LESS. G.C. SHALL REBALANCE IF NECESSARY.
10	BRANCH CIRCUIT CONDUCTOR INSULATION SHALL BE COLOR CODED AND SHALL BE 600 VOLT, TYPE THHN/THWN.
11	CABLES IN HIGH TEMPERATURE AREAS SHALL HAVE INSULATION TYPE SUITABLE FOR THE TEMPERATURE. CABLES USED IN SPACES FOR ENVIRONMENTAL AIR SHALL CONFORM WITH APPLICABLE N.E.C. REQUIREMENTS.
12	ALL WIRING USED IN RETURN OR DISCHARGE AIR PLENUMS SHALL BE PLENUM RATED OR INSTALLED PER METHODS APPROVED BY THE LATEST EDITION OF THE N.E.C. FOR SUCH APPLICATION.
13	ALL WIRE AND CABLE CONDUCTORS SHALL BE COPPER WITH INSULATION RATED 600V. CONDUCTORS SIZED #10 AWG AND SMALLER SHALL BE SOLID OR STRANDED, AND CONDUCTORS SIZED LARGER THAN #10 AWG SHALL BE STRANDED WIRE.
14	BRANCH CIRCUITS FOR POWER AND LIGHTING SHALL NOT BE LESS THAN #12 AWG. OR AS NOTED. WIRES ARE TO BE SIZED FOR THE APPROPRIATE VOLTAGE DROPS. SEE WIRE SIZE SCHEDULE ON THIS SHEET.
15	ALL DATA CABLES SHALL BE CAT6, PLENUM RATED, TO BE PROVIDED BY OWNER. SELECTED VENDOR SHALL BE TOXIC FREE. PROVIDE OUTLET BOXES AND "RING AND STRING" FOR PULLING OF CABLES IN CONCEALED SPACES.
16	CONDUCTOR WIRING SHALL NOT BE LESS THAN #14 AWG UNLESS OTHERWISE NOTED.
17	HOMERUNS SHOWN ARE SCHEMATIC. CONTRACTOR MAY ORIGINATE HOMERUNS FROM DIFFERENT LOCATIONS. ALL WIRE INCLUDING HOMERUNS SHALL BE DELINEATED ON AS-BUILT DRAWINGS.
18	ALL WIRING INSTALLED UNDER THIS CONTRACT SHALL BE TESTED FOR PROPER CONNECTIONS AND SHORT CIRCUITS PRIOR TO THE TURNING OVER OF WORK AS A COMPLETE UNIT.
19	PROVIDE ALL ELECTRICAL SYSTEM GROUNDING IN ACCORDANCE WITH N.E.C. REQUIREMENTS EVEN IF IT IS NOT SHOWN ON THE DRAWINGS. INCLUDE ADDITIONAL GROUNDING CONDUCTORS IN ALL RACEWAYS EVEN THOUGH THE DRAWINGS SHOW ONLY CIRCUIT AND/OR NEUTRALS CONDUCTORS. THE PLUMBING AND PIPING SYSTEM SHALL NOT BE USED AS A GROUND. ALL TRANSFORMER NEUTRALS SHALL BE GROUND TO BUILDING STEEL IN ACCORDANCE WITH NEC 250-70.
20	ALL CONDUITS PASSING THROUGH PARTITIONS ARE TO BE APPROPRIATELY SLEEVED AND SEALED.
21	FURNISH AND INSTALL ALL CONDUIT WITH PULL WIRES AS REQUIRED. ALL OUTLET BOXES SHALL BE STEEL, EXTRA DEEP WITH GROUNDING PIGTAILS. GROUNDING PUSH-CLIPS ARE NOT ACCEPTABLE.
22	ALL PENETRATIONS SHALL BE INSTALLED AND SEALED PER NATIONAL STATE AND LOCAL CODES.
23	DO NOT MAKE ANY CHANGES OR SUBSTITUTIONS WITHOUT SPECIFIC WRITTEN APPROVAL FROM THE ARCHITECT OR ENGINEER.
24	GUARANTEE ALL WORK, MATERIAL AND EQUIPMENT FOR A PERIOD OF ONE YEAR FROM THE DATE OF APPROVAL AND FINAL ACCEPTANCE.
25	THIS DESIGN IS BASED ON INITIAL DESIGN DATA. GENERAL CONTRACTOR TO SUPPLY AND INSTALL FEEDERS, FUSES AND CIRCUIT BREAKERS TO MATCH THE NAMEPLATE RATING OF ALL EQUIPMENT. THIS SHALL BE INCLUDED IN THE INITIAL BID PROPOSAL AND NO EXTRAS SHALL BE ENTERTAINED.
26	LABEL ALL JUNCTION BOXES, OUTLETS, LIGHT SWITCH, ETC. WITH CIRCUIT NUMBER ON INTERIOR OR COVER PLATE. USE SELF-ADHESIVE "Dymo" LABEL 1/8" HIGH LETTERS.
27	GENERAL CONTRACTOR SHALL PROVIDE SEISMIC RESTRAINTS AND SUPPORTS FOR ALL FLOOR, WALL, AND CEILING MOUNTED ELECTRICAL EQUIPMENT TO RESIST EARTHQUAKE EFFECTS DETERMINED IN ACCORDANCE WITH THE BUILDING CODE.
28	THE G.C. SHALL PROVIDE ALL EQUIPMENT, MATERIALS AND LABOR TO COMPLETE ALL ELECTRICAL WORK IN A NEAT AND WORKMANLIKE MANNER AND IN ACCORDANCE WITH GOOD COMMERCIAL PRACTICE INCLUDING THE INSTALLATION OF ALL THE EQUIPMENT MATERIALS AND SYSTEMS AND THE FINAL CONNECTIONS TO THE OWNER'S EQUIPMENT AND FIXTURES AS REQUIRED BY THE OWNER. THE G.C. SHALL ALSO FURNISH TEMPORARY WIRING AND LIGHTING TO PROVIDE A MINIMUM OF 25 FC IN WORK AREAS FOR USE OF ALL THE TRADES DURING CONSTRUCTION AND THE INSTALLATION OF THE OWNERS FIXTURES. THE G.C. IS RESPONSIBLE TO REMOVE ALL TEMPORARY WIRING UPON COMPLETION OF CONSTRUCTION OF ALL TRADES.
29	THIS CONTRACTOR SHALL BE RESPONSIBLE TO PROVIDE AND INSTALL ALL SUPPLEMENTARY SUPPORT, INCLUDING SUPPORT STEEL AS REQUIRED TO HANG ALL EQUIPMENT AND LIGHTING FROM THE EXISTING STRUCTURE IN ACCORDANCE WITH THE ARCHITECTURAL/STRUCTURAL SUPPORT AND LOADING CRITERIA.
30	IT IS THE RESPONSIBILITY OF THIS CONTRACTOR TO PROVIDE FULLY DIMENSIONED COORDINATION DRAWINGS FOR ALL OF HIS RESPECTIVE WORK. THESE DRAWINGS MUST BE FULLY COORDINATED WITH ALL EXISTING CONDITIONS. ALL HVAC, PLUMBING, FIRE PROTECTION, ELECTRICAL, LIGHTING, STRUCTURAL AND ARCHITECTURAL SYSTEMS PRIOR TO PREPARING COMPOSITE MULTI DISCIPLINE COORDINATION DRAWINGS.
31	ALL DISCONNECTING MEANS AND EQUIPMENT INDICATED ON THE DRAWING SHALL BE IDENTIFIED BY NAMEPLATE IN COMPLIANCE WITH THE NATIONAL ELECTRICAL CODE 110-22.
32	ALL WIRING FOR THE EMERGENCY LIGHTING AND EMERGENCY SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE ARTICLE 700.
33	THE WIRING METHODS AND MATERIALS INDICATED IN THE SPECIFICATIONS AND ON THE DRAWINGS SHALL BE INSTALLED AND CONNECTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE ARTICLE 300.

GENERAL ELECTRICAL NOTES	
#	DESCRIPTION
33	THE WIRING METHODS AND MATERIALS INDICATED IN THE SPECIFICATIONS AND ON THE DRAWINGS SHALL BE INSTALLED AND CONNECTED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE ARTICLE 300.
34	THE ELECTRICAL SERVICE AND DISTRIBUTION SYSTEM AS INDICATED ON THE RISER DIAGRAM AND MATERIALS INDICATED IN THE SPECIFICATIONS SHALL BE IN COMPLIANCE WITH THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE ARTICLE 230, SERVICES.
35	ALL OVER CURRENT PROTECTION SHALL BE IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE SECTION 240, OVERCURRENT PROTECTION.
36	ALL GROUNDING REQUIREMENTS OF THE COMPLETE ELECTRICAL DISTRIBUTION SYSTEM AND AS INDICATED IN THE SPECIFICATIONS SHALL BE IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ARTICLE 250, GROUNDING AND BONDING.
37	PROTECT LABOUR REQUIRED CUTTING AND PATCHING OF CONCRETE FLOOR AND/OR CUTTING OF ROOF. CONTRACTOR SHALL COORDINATE WITH BUILDING ENGINEER.
38	FOR ALL LIGHTING FIXTURES MOUNTED IN HUNG CEILING THE GENERAL CONTRACTOR SHALL PROVIDE AND INSTALL INDIVIDUAL SUPPORT AT EACH CORNER OF RECESSED LIGHTING TROFFER CONNECTED TO BUILDING STEEL ABOVE ALL CONDUIT AND MC CABLE MOUNTED ABOVE HUNG CEILING SHALL BE INDIVIDUALLY SUPPORTED IN THE SAME FASHION AS PER NEC REQUIREMENTS.
39	DO NOT SCALE FROM THESE DRAWINGS.
40	PLANS ARE PREPARED WITH REQUIRED BRANCH CIRCUITS INDICATED BY CIRCUITS NUMBERS. PROVIDE AND INSTALL ALL CONDUITS, CONDUCTORS, BOXES, MISCELLANEOUS FITTINGS, ETC. FOR A COMPLETE AND OPERABLE SYSTEM (HOME RUN SHOWN). BRANCH CIRCUIT INSTALLATION SHALL COMPLY WITH SPECIFICATIONS AND N.E.C.
41	ELECTRICAL RECEPTACLE, SWITCH AND CONTROL HEIGHTS (CBC-1136A.1.1) RECEPTACLE HEIGHTS: ELECTRICAL RECEPTACLE OUTLETS ON BRANCH CIRCUITS OF 30 AMPERES OR LESS AND COMMUNICATION SYSTEM RECEPTABLES SHALL BE LOCATED NO MORE THAN 48 INCHES (1219MM) MEASURED FROM THE TOP OF THE RECEPTACLE OUTLET BOX OR RECEPTACLE HOUSING NOR LESS THAN 15 INCHES (381MM) MEASURED FROM THE BOTTOM OF THE RECEPTACLE OUTLET BOX OR RECEPTACLE HOUSING TO THE LEVEL OF FINISHED FLOOR OR WORKING PLATFORM. IF THE REACH IS OVER AN OBSTRUCTION (FOR EXAMPLE, A KITCHEN BASE CABINET) BETWEEN 20 AND 25 INCHES (508 AND 635MM) IN DEPTH, THE MAXIMUM HEIGHT MEASURED AT THE BOX IS REDUCED TO 44 INCHES (1118MM) FOR FORWARD APPROACH, OR 46 INCHES (1168MM) FOR SIDE APPROACH, PROVIDED THE OBSTRUCTION IS NO MORE THAN 24 INCHES (610MM) IN DEPTH. OBSTRUCTION SHALL NOT EXCEED MORE THAN 25 INCHES (635MM) FROM THE WALL BENEATH THE RECEPTACLE.
42	SWITCH AND CONTROL HEIGHTS: (CBC-1136A.2.1) CONTROL OR SWITCHES INTENDED TO BE USED BY THE OCCUPANT OF THE ROOM OR AREA TO CONTROL LIGHTING AND RECEPTACLE OUTLETS, APPLIANCES, ALARMS OR COOLING, HEATING AND VENTILATING EQUIPMENT SHALL BE LOCATED NO MORE THAN 48 INCHES (1219MM) MEASURED FROM THE TOP OF THE OUTLET BOX NOR LESS THAN 15 INCHES (381MM) MEASURED FROM THE BOTTOM OF THE OUTLET BOX TO THE LEVEL OF THE FINISHED FLOOR OR WORKING PLATFORM. IF THE REACH IS OVER A PHYSICAL BARRIER OR AN OBSTRUCTION (FOR EXAMPLE, A KITCHEN BASE CABINET) BETWEEN 20 AND 25 INCHES (508 AND 635MM) IN DEPTH, THE MAXIMUM HEIGHT IS REDUCED TO 44 INCHES (1118MM) FOR FORWARD APPROACH, OR 46 INCHES (1168MM) FOR SIDE APPROACH, PROVIDED THE OBSTRUCTION IS NO MORE THAN 24 INCHES (610MM) IN DEPTH. PHYSICAL BARRIERS OR OBSTRUCTIONS SHALL NOT EXTEND MORE THAN 25 INCHES (635MM) FROM THE WALL BENEATH A CONTROL.

LIGHTING FIXTURE SCHEDULE						
Type	Symbol	Type Location Description	Mfg Catalog #	Lamps	Watts	Voltage Notes
L1		Ceiling Recessed led (6" round)	"Lithonia Ltg" LDN6 40/05 L06AR LD	LED	20W	120/ 277V New dimmable lighting fixture
L1E		Ceiling Recessed led (6" round) EM	"Lithonia Ltg" LDN6 40/05 L06AR LD	LED	20W	120/ 277V New dimmable EM lighting fixture
L2		Surface mtd. 1W X 4L lighting fixture	"Lithonia lighting"ZL1N-L4 6-3000LM-35K-MVOLT	LED	25W	120/ 277V New dimmable lighting fixture
EX		Surface mtd. 1W X 4L lighting fixture WITH 90 MIN BATTERY	"Lithonia lighting"ZL1N-L4 6-3000LM-35K-MVOLT-EM	LED	25W	120/ 277V New EM SIGN lighting fixture
L3		Wall mounted FIXTURE HIGH EFFICIENCY	"Lithonia Ltg" FMABFL 14 20840 F20	LED	20W	120/ 277V New dimmable lighting fixture
L4		2X4Recessed led	"Lithonia" ZTL4-48L-LP83 5	LED	40W	120/ 277V New dimmable lighting fixture
L5		2X4Recessed led WITH 90 MIN BATTERY	"Lithonia" ZTL4-48L-LP83 5-EM	LED	40W	120/ 277V New dimmable lighting fixture
L6			Luxx 1000 DE 480v	LED	1032W	277V New dimmable lighting fixture
L7			Luxx 645W LED Pro 120-277v	LED	645W	120/ 277V New dimmable lighting fixture
L8		suspended high bay led	Litonia JCBLL 9000LM ACCR 30K 70CRI	LED	63W	120/ 277V New dimmable lighting fixture
L9		suspended high bay led with 90m battery	Litonia JCBLL 9000LM ACCR 30K 70CRI-EM	LED	63W	120/ 277V New dimmable lighting fixture
L10		2' wall bracket & Surface Mount LED	Litonia WL2 18L EZ1 LP840	LED	17.5W	120/ 277V New dimmable lighting fixture
L11			120 V T5 LIGHTING FIXTURE (4 FOOT)	LED	216W	120 New dimmable lighting fixture

ELECTRICAL LEGEND	
SYMBOL	DESCRIPTION
	SINGLE POLE SWITCH AND BOX, WALL MOUNTED +44" AFF. LOWER CASE LETTER INDICATES CIRCUIT CONTROLLED BY SWITCH WITH OCCUPANCY SENSOR.
	TWO WAY SINGLE POLE SWITCH AND BOX, WALL MOUNTED +44" AFF. LOWER CASE LETTER INDICATES CIRCUIT CONTROLLED BY SWITCH WITH OCCUPANCY SENSOR.
	WALL MOUNTED DIMMER SWITCH, 0-10V DIMMING WITH ON-OFF SWITCH.
	WALL MOUNTED 3 WAY ON, CENTER OFF LOW VOLTAGE SWITCH FOR LCP CONTROLLER LIGHTS.
	RECEPTACLE, DUPLEX 20A, 120V GRD, NEMA 5-20R +18" AFF U.O.N.(WP=WEATHERPROOF, GFCI=GROUND FAULT CIRCUIT INTERRUPTER)
	DEDICATE RECEPTACLE, DUPLEX 20A, 120V GRD, NEMA 5-20R +18" AFF U.O.N. (WP=WEATHERPROOF, GFI=GROUND FAULT CIRCUIT INTERRUPTER)
	USB RECEPTACLE, DUPLEX 20A, 120V GRD, NEMA 5-20R +42" AFF U.O.N.
	RECEPTACLE, SINGLE, 20A, 120V GRD, NEMA 5-20R +18" AFF UON.
	RECEPTACLE, DOUBLE DUPLEX (2) 20A, 120V, GRD - NEMA (2) 5-20R +18" AFF U.O.N.
	RECEPTACLE DUPLEX 20A, 120V GRD NEMA 5-20R FLOOR MOUNTED.
	RECEPTACLE DOUBLE DUPLEX (2) 20A, 120V GRD, NEMA 5-20R UON. FLOOR MOUNTED.
	2 PORT VOICE/ DATA OUTLET, WALL MOUNT +18" AFF PROVIDE RING & STRING TO PULL CABLES THRU HOLLOW WALL. VOICE/ DATA WIRING BY TELECOM SYSTEM INSTALLER.
	TV OUTLET, WALL MOUNT +60" AFF PROVIDE RING & STRING TO PULL CABLES THRU HOLLOW WALL.
	COMBINATION 4-PLEX RECEPTACLE, NEMA 5-20R DOUBLE DUPLEX (1) DUPLEX AUTO CONTROLLED BY OCCUPANCY SENSOR PER T24, (1) DUPLEX UNCONTROLLED), & TYPE 6 VOICE/DATA OUTLET, FLOOR MOUNTED. PROVIDE MIN. 3/4" TEL/DATA CONDUIT WITH PULL WIRES.
	4-PLEX RECEPTACLE, NEMA 5-20R DOUBLE DUPLEX (1) DUPLEX AUTO CONTROLLED BY OCCUPANCY SENSOR PER T24, (1) DUPLEX UNCONTROLLED), +18" AFF. U.O.N. SEE NOTE 2.
	DUPLEX RECEPTACLE, NEMA 5-20R OCCUPANCY SENSOR CONTROLLED, +18" AFF. SEE NOTE 2.
	GFCI DUPLEX RECEPTACLE ABOVE COUNTER LEVEL, NEMA 5-20R.
	GFCI DUPLEX RECEPTACLE ABOVE COUNTER LEVEL, VACANCY SENSOR CONTROLLED, NEMA 5-20R.
	SPECIAL PURPOSE CONNECTION FOR ELECTRICAL EQUIPMENT. VERIFY CONNECTION TYPE AND WIRING REQUIREMENTS PRIOR TO ROUGH-IN.
	CLASS 1, DIVISION 1 RATED EXPLOSION-PROOF OUTLET. SEE ADDITIONAL NOTES ON SHEET E3.1.
	RECEPTACLE, 120V/240V, 3PH, 4W, GRD, RATING AS INDICATED IN PLANS.
	RECEPTACLE 20A, 480V, 3PH, 4W, GRD, NEMA L22-20R, +18" AFF UON.
	DUPLEX RECEPTACLE 20A, 120V, GND (5-20R U.O.N.), SUSPENDED BY TYPE S.O. CORD WITH GRIPS AT EACH END.
	DOUBLE DUPLEX RECEPTACLE 20A, 120V, GND (5-20R U.O.N.), SUSPENDED BY TYPE S.O. CORD WITH GRIPS AT EACH END.
	TWIST-LOCK RECEPTACLE 20, 250V, SINGLE PHASE (L6-20R U.O.N.), SUSPENDED BY TYPE S.O. CORD WITH GRIPS AT EACH END.
	OCCUPANCY SENSOR LOW VOLTAGE CEILING MOUNTED FOR ROOM CONTROLLER.
	OCCUPANCY SENSOR LOW VOLTAGE WALL MOUNTED FOR ROOM CONTROLLER.
	CEILING MOUNTED DAYLIGHT SENSOR.
	JUNCTION BOX CEILING MOUNTED, SIZE TO CODE, TAPE AND TAG WIRES.
	JUNCTION BOX WALL MOUNTED, SIZE TO CODE, TAPE AND TAG WIRES.
	ELECTRICAL PANELBOARD, SURFACE OR FLUSH MOUNTED (277/480V).
	ELECTRICAL PANELBOARD, SURFACE OR FLUSH MOUNTED (120/208V).
	SPECIAL PURPOSE ELECTRICAL PANELBOARD, SURFACE OR FLUSH MOUNTED.
	TRANSFORMER - DRY TYPE.
	FUSED DISCONNECT SWITCH WITH DUAL ELEMENT FUSES. SWITCH AND FUSES RATING PER NAMEPLATE OF SERVED UNIT. NON-FUSED DISCONNECT SWITCH, RATING PER NAMEPLATE OF SERVED UNIT.
	MAGNETIC MOTOR STARTER, NEMA RATING AS REQUIRED PER SERVED UNIT.
	WALL MOUNTED JUNCTION BOX FOR PRE-WIRED FURNITURE POWER SYSTEM CONNECTION. PROVIDE POWER WHIP WITH TERMINATION PLUG TO MATCH FURNITURE SYSTEM CONNECTOR. LOCATE BOX AS LOW AS POSSIBLE. FIELD COORDINATE FINAL LOCATION.
	COMBINATION TELEPHONE AND DATA OUTLET, WALL MOUNTED AS LOW AS POSSIBLE FOR FLEXIBLE CONNECTION TO FURNITURE SYSTEM.
	FLOOR MOUNTED FURNITURE FEEDS W/POWER & TELE/DATA PORT CAPACITY FOR ELECTRIFIED DESKS PER CLIENT'S REQUIREMENTS.
	POWER POLES W/POWER & TELE/DATA PORT CAPACITY FOR ELECTRIFIED DESKS PER CLIENT'S REQUIREMENTS.
	Smoke Detector
	Carbon Monoxide Detector
LEGEND NOTES: 1. MOUNTING HEIGHT INDICATED ARE AFF TO CENTER OF PLATE. IN CASE OF CONFLICT GENERAL NOTES 41 & 42 SHALL PREVAIL. 2. NOT ALL SYMBOLS AND ABBREVIATIONS ARE NECESSARILY USED IN THIS PROJECT.	

WIRE SCHEDULE AND NOTES					
LOAD PER PH (KVA)	WIRE SIZE (AWG)	MAXIMUM LENGTH OF BRANCH CIRCUIT PER UTILIZATION VOLTAGE (120, 1PH, MAX V.D. 3%) (240, 1PH, MAX V.D. 3%) (240, 3PH, MAX V.D. 3%)			NOTES AND REMARKS
< 1.92	#12	56 FT	85 FT	98 FT	5
	#10	94 FT	141 FT	163 FT	5
	#8	144 FT	217 FT	250 FT	5
< 1.44	#6	230 FT	345 FT	398 FT	5
	#12	75 FT	113 FT	130 FT	5
	#10	125 FT	188 FT	217 FT	5
< 1.26	#8	192 FT	289 FT	334 FT	5
	#6	306 FT	460 FT	531 FT	5
	#12	86 FT	129 FT	149 FT	
< 1.08	#10	143 FT	215 FT	248 FT	
	#8	220 FT	330 FT	381 FT	
	#12	100 FT	150 FT	173 FT	
< 0.9	#10	167 FT	250 FT	289 FT	
	#8	256 FT	385 FT	445 FT	
	#12	120 FT	180 FT	240 FT	
< 0.72	#10	200 FT	300 FT	347 FT	
	#12	150 FT	225 FT	260 FT	
	#10	250 FT	376 FT	434 FT	
#	NOTES				
1	CONTRACTOR SHALL REFER TO THIS TABLE PRIOR TO START OF BRANCH CIRCUIT ROUGH-IN.				
2	CONTRACTOR SHALL USE THE APPROPRIATE WIRE SIZE IN CONJUNCTION WITH THE LENGTH OF THE PROPOSED FIELD VERIFIED ROUTING OF BRANCH CIRCUIT WIRING (INCLUDING VERTICAL & LATERAL RUN, ROUTED PARALLEL/PERPENDICULAR TO THE BUILDING STRUCTURE).				
3	SEE PANEL SCHEDULE FOR THE CORRESPONDING KVA LOAD PER PHASE OF A PARTICULAR BRANCH CIRCUIT.				
4	RESISTANCE VALUES USED ARE FOR UNCOATED COPPER WIRES IN STEEL CONDUIT, 75 DEGREE C., OPERATING AT 60HZ.				
5	THE VALUES IN "120V, 1PH" COLUMN IS TO BE USED FOR GENERAL PURPOSE RECEPTACLE LOADS.				

ABBREVIATIONS AND TAGS			
ABB.	DESCRIPTION	ABB.	DESCRIPTION
EW	ELECTRIC WATER HEATER	SD	SMOKE DETECTOR
(E)	EXISTING TO REMAIN	TEL	TELEPHONE
EC	ELECTRICAL CONTRACTOR	TX	TRANSFORMER
FA	FIRE ALARM	TV	TELEVISION
FMT	FLEXIBLE METALLIC TUBING	UAC	UNDER ANOTHER CONTRACT
GC	GENERAL CONTRACTOR	UAS	UNDER ANOTHER SECTION
GFI	GROUND FAULT INTERRUPTER	UON	UNLESS OTHERWISE NOTED
IG	ISOLATED GROUND	V.D.	VOLTAGE DROP
LL	LANDLORD	W	WIRE
LV	LOW VOLTAGE	WP	WEATHERPROOF
	MECHANICAL UNIT TAG. SEE MECHANICAL DRAWINGS FOR ADDITIONAL DESCRIPTION.		DETAIL TAG. REFER TO DETAIL 4 ON SHEET NUMBER E-4.

ELECTRICAL DRAWING SCHEDULE	
#	TITLE
E1.0	ELECTRICAL LEGEND, NOTES, SCHEDULES & ABBREVIATIONS
E2.0	ELECTRICAL SPECIFICATIONS
E3.0	LIGHTING LAYOUT
E4.0	POWER LAYOUT
E5.0	SINGLE LINE DIAGRAM SHEET 1 OF 2
E6.0	SINGLE LINE DIAGRAM SHEET 2 OF 2
E7.0	PANEL BOARD SCHEDULE SHEET 1 OF 2
	—

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
ELECTRICAL LEGEND, NOTES, SCHEDULES & ABBREVIATIONS

PROJ. NO. PROJ. ENGR. SCALE @ 24X36:
NTS

DRAWING NO. REV.
E1.01 0

ELECTRICAL SPECIFICATIONS

PART 1	GENERAL
1.01	<p>SCOPE OF WORK: Furnish and install all materials and equipment and provide all labor, tools, transportation, superintendence and services required and necessary to complete the work shown on the drawings and/or specified herein. Also include all other work and miscellaneous items, not specifically mentioned, but reasonably inferred for a complete installation including all accessories and appurtenances required for testing the system. It is the intent of the drawings and specifications that all systems be complete, and ready for operation.</p> <p>REGULATORY REQUIREMENTS: Code compliance is mandatory. Nothing in these Drawings and Specifications work not conforming to these codes. Where work is shown to exceed minimum code requirements, comply with drawings and specifications. All work and materials shall comply with the latest rules, codes and regulations, including, but not limited to the following: 1. Occupational Safety and Health Act Standards (OSHA). 2. NFPA #70: National Electric Code (NEC), California Electrical Code (CEC). 3. NFPA #101: Life Safety Code. 4. State Fire Marshal. 5. Local Utilities Companies.</p> <p>LICENSE, FEES AND PERMITS: Electrical contractor shall pay for all licenses, permits and inspection fees required by the authority having jurisdiction and shall arrange for all required inspections.</p> <p>SAFETY AND INDEMNITY: The Contractor shall be solely and completely responsible for conditions of the job site, including safety of all persons and property during performance of work. This requirement will apply continuously and not be limited to normal working hours. No act, service, drawing review or construction review by the Owner, the Engineers or their Consultants, is intended to include review of the adequacy of the Contractor's safety measures, in, on, or near the construction site.</p> <p>DRAWINGS AND SPECIFICATIONS: All drawings and all Divisions of these specifications shall be considered as a whole and work of this Division shown anywhere therein shall be furnished under this Division. Drawings are diagrammatic and indicate the general arrangement of equipment and wiring. Minor direct routing of conduits and wiring is not assured. Exact requirements shall be governed by conditions of the job. Consult all other drawings in preparation of the bid. Extra lengths of wiring or addition of pull or junction boxes, etc., necessitate by such conditions shall be included in the bid.</p> <p>CONDITIONS AT SITE: The electrical contractor shall have examined the site and familiarized themselves with all discernible existing conditions. No extra payment will be allowed for work required because of these conditions, whether specifically mentioned or not.</p> <p>WORKMANSHIP AND CONTRACTOR'S QUALIFICATIONS: Only quality workmanship will be accepted. Haphazard or poor installation will be cause for rejection of work.</p> <p>SHOP DRAWINGS AND MATERIALS LISTS: Submit to Owner in a single package six (6) copies of complete shop drawings and materials list, as noted below, for review within fifteen (15) days after award of contract. Submittals required as follows: 1. Wiring devices: switches, receptacles, device plates. 2. Enclosures for utility company metering. 3. Main fused disconnect switch. 4. Panelboards. 5. Disconnect switches. 6. Lighting fixtures, lamps and lighting control equipment.</p> <p>SUBSTITUTIONS: One or more makes of materials or methods may have been specified to establish the standard of quality, workmanship, finish and design required, but other materials or methods equal in quality, workmanship, finish, design, and guaranteed performance, will be accepted. However, all changes and substitutions shall be requested in letter form and shall be accompanied with a statement of the amount of money to be returned to the contract if the substitution is permitted. No work involving materials submitted for substitution shall proceed until written acceptance is received from the Owner. The Owner is the sole judge of acceptability of preferred substitutions. If a substitution item is permitted, and any re-design effort is thereby necessitated, the required redesign shall be at the Contractor's expense.</p> <p>COORDINATION: Coordinate work with other trades to avoid conflict and to provide correct rough-in and connection for equipment furnished under other trades that require electrical connections. Inform Contractors of other trades of the required access to and clearances around electrical equipment to maintain service ability and code compliance. Verify equipment dimensions and requirements with provisions specified under this Section. Check actual job conditions before fabricating work. Report necessary changes in time to prevent needless work. Changes or additions, subject to additional compensation, which are made without written authorization and an agreed price, shall be at the Contractor's risk and expense.</p> <p>CUTTING AND PATCHING: All cutting and patching required for work of this Division is included herein. Coordination with General Contractor and other trades is imperative. Contractor shall bear the responsibility for and the added expense of adjusting for improper holes, supports, etc.</p> <p>ACCEPTANCE DEMONSTRATION: Upon completion of the work, at a time to be designated by the Owner, the Contractor shall demonstrate for the Owner the operation of the electrical installation including any and all special items installed by him or installed under his supervision. Properly set automatic time switches to perform switching operations in accordance with schedules provided by the Owner's representative, and demonstrate (using the manufacturer's operating instructions) how to override and/or test time switches programming.</p> <p>RECORD DRAWINGS, EQUIPMENT DATA: Maintain one set of clean working drawings at the job site and enter daily such "as-built" information as feeder and service routes, pull box locations and changes in layout or arrangement which occur during construction. Deliver completed drawings to the Owner. Deliver to the Owner's representative three copies of data sheets or other current manufacturers' publications for each item of electrical equipment furnished for the project including at least these data: 1. Technical description and replaceable parts list. 2. Physical description and installation instructions. 3. Main fused disconnect switch. 4. Manufacturer's Warranty.</p> <p>CLEAN-UP: Rid the premises of scrap materials, trash and debris both during construction and at completion of the project. Leave the building and surrounding area in a clean and orderly condition.</p> <p>GUARANTEE: Guarantee the installation free from defects of workmanship and materials for a period of one year after Date of Certification of final payment and promptly remedy any defects developing during this period, without charge.</p> <p>TEMPORARY SERVICES: Provide adequate and safe temporary electrical power and lighting throughout the construction and finishing of the premises. In addition to special or unusual requirements, provide at least these items: 1. Three 20-amp circuits for construction power tools. Provide GFI temporary circuits with coverplates to meet OSHA requirements. 2. Three or more light strings suspended approximately one foot below the height of finish ceiling with lamps spaced not more than twelve feet on centers. Strings shall be run the length of the store space parallel to the demising walls, with one string within eight feet of each wall and one (or more) intermediate string(s) arranged to limit the spacing between rows to sixteen feet or less. 3. Flood lighting and task lighting for painting and other finish work. When permanent electrical service is operable, disconnect and remove from the premises the materials and equipment used for temporary power and lighting, and restore modifications and repair damage caused by the installation, use or removal of temporary service provisions.</p>

PART 2	PRODUCTS
2.01	<p>MATERIAL APPROVAL: All materials must be new and bear Underwriter's Laboratories label. Materials that are not covered by UL testing standards shall be tested and approved by an independent testing laboratory or a governmental agency. Material not in accordance with these specifications may be rejected either before or after installation.</p> <p>CONDUITS AND OTHER RACEWAYS: A. Rigid Steel: Hot-dipped galvanized. B. Intermediate Metal Conduit (IMC): Hot-dipped galvanized. C. Electrical Metallic Tubing (EMT): Electro-galvanized. D. Wireway: Code gauge steel, with knockouts and hinged cover, corrosion resistant gray baked enamel finish. E. Provide fittings and accessories approved for the purpose equal in all respects to the conduit or raceway. EMT connectors and couplings shall be steel setscrew type indoors and steel compression type in wet locations and outdoors.</p>
2.02	<p>WIRES AND CABLES: A. For power and lighting system 600V or less: 1. Conductor: minimum size #12 AWG. a. #12 and #10 AWG solid copper. b. #8 AWG and larger shall be stranded copper. 2. Insulation type: a. #12 to #1 AWG: THWN for wet or underground and THHN for dry locations. b. #1/0 through #4/0 AWG: XHHW (55 mils). c. #250 MCM and larger: XHHW (65 mils). d. Grounding wire: TW. B. For signal and communications circuit: 1. Special cables shall be as specified on drawings. 2. Conductors for general use shall be stranded copper conductor, #16 AWG minimum, with THWN insulation for underground or wet locations and THHN insulation for dry locations. C. Acceptable Products: General Electric, Anacoconda, Okanite, Paranjite or Triangle products conforming or exceeding applicable IPCEA standards.</p>
2.03	<p>OUTLET BOXES, JUNCTION AND PULL BOXES: A. Outlet boxes: 4" square x 1-1/2" deep (or larger) galvanized sheet steel KO-type with plaster ring and cover for general interior use and cast metal type FS or FD with matching screw covers for exterior and exposed interior locations (gasketed to damp wet locations). B. Junction boxes shall be same as outlet boxes up to 42 cu. in. and codegauge steel in larger sizes with surface or flush-type screw-mounted trim covers, both boxes and covers inhibitor-primed and painted inside out. C. Pull boxes shall be same as junction boxes unless indicated otherwise on the drawings, with covers. D. Telephone outlet boxes shall be the type and size required by the serving telephone company but not smaller than 4-11/16" square x 2-1/8" deep with single-gang ring and Sierra #S-754N split plate bushing.</p>
2.05	<p>WIRING DEVICES AND PLATES: Wiring devices and plates shall be by Pass and Seymour or approved equal. 1. Standard design: a. Switch and receptacles devices shall be plastic bodies, color per architect. b. Wall plates shall be metal type 430, stainless steel, color per architect. c. Isolated ground receptacles shall be white with orange triangle as required per NEC, manufactured by "Leviton" # 5362-IGW or approved equal.</p>
2.06	<p>CONDUIT HANGERS: For individual conduit runs not directly fastened to the structure, use rod hangers manufactured by Caddy, Unistrut or Powerstrut. For multiple conduit runs, use Unistrut or Powerstrut trapeze type conduit support designed for maximum deflection not greater than 1/8".</p>
2.07	<p>WIRE CONNECTORS: For wire sizes #8 AWG and smaller: Insulated pressure type (with live spring) rated 105 degrees C, 600V, for building wiring and 1000V in signs or fixtures. Scotchklok or Ideal. For wire size #8 AWG and larger: T & B or equivalent compression type with 3M #534+ or Plymouth "Slipknot Grey" tape insulation.</p>
2.08	<p>PANELBOARDS: A. Construction: Cabinets shall be of code gauge, galvanized steel, surface or flush mounted as indicated. Doors shall be of cold-rolled steel with concealed hinges and flush catch and lock. All panels shall be keyed alike. Panels located adjacent to each other shall have identically sized enclosure and trims. Minimum panel width shall be 20". Finish exposed part with one coat of primer and one coat of light grey enamel suitable for overpainting in field if desired. B. Bus Bars: Provide ground block with full complement of terminals in addition to insulated neutral bus. Future breaker spaces shall have complete provision including busses and connecting hardware. C. Manufacturers: Panelboards shall be General Electric Type "AQ" or type "AE" or equivalent products of Eaton Cutler-Hammer, Square-D or Siemens-ITE. D. Circuit Breakers: Shall be quick-make, quick-break, molded case type: 1. 120/240 Volt Panels: Shall be General Electric Type "Q" line, bolt-on type, with minimum symmetrical interrupting capacity as shown. 2. Provide multi-pole units with common trip element. 3. Circuit breakers used on "ON-OFF" control of fluorescent lighting (panelboard switching) shall be Underwriters' Laboratories listed and marked "SWD" to indicate their suitability. E. Identification: Provide screwed-on (no adhesives) bakelite or photo-etched metallic nameplate identification on outside of each panel showing panel designation, voltage and phase in minimum 1/8" high letters. Each panel shall contain a metal-framed circuit directory inside cover, with plastic protector. Complete shop drawings are required. See Article 1.08. F. Complete shop drawings are required. See Article 1.08.</p>
2.09	<p>INDIVIDUALLY MOUNTED MOTOR CONTROLLERS: A. For Polyphase Motors: Combination motor circuit protector and magnetic starter, with 3-leg overload protection. Provide two interlock contacts of the interchangeable open-close type. Provide hand-off-automatic selector switch, motor running pilot light and reset button in cover. Circuits 300V and over shall be provided with 120V control transformers. B. Starters for fractional horsepower 120V motors shall be manual type unless shown otherwise, equipped with built-in overload protection. C. Acceptable manufacturers: General Electric, Siemens, Square D, Eaton, and Allen Bradley.</p>
2.10	<p>LIGHTING: A. Furnish and install all fixtures complete, including lamps and ballast ready for service. B. Supports: Proper supports and mounting accessories, such as hangers, stems, yokes, plaster frames, etc. shall be provided as required by the type of ceiling installed. Where swivel canopies or ball aligners are specified, they shall cause fixture to hang plumb regardless of ceiling slope. C. Fixture designation: Fixture types are designated on drawings. Where only one fixture designation is shown, it applies to all fixtures in that room or area. For exact fixture count and location refer to reflected ceiling plan.</p>
2.11	<p>MISCELLANEOUS MATERIALS: A. Safety Switches: Heavy duty type, 600V, horsepower rated for motors, fused or non-fused as required. Mount in enclosure with NEMA rating as required for the specific application General Electric, Square D or Eaton.</p>

PART 2	PRODUCTS
2.12	<p>DRY TYPE TRANSFORMERS: General: Equipment shall conform to or exceed requirements of NEMA, ANSI Standard C89.2 for Dry Type Transformers for General Applications. Acceptable products are those of General Electric Company's "QL" Line or equivalent Square D, Siemens-ITE, or Eaton. Electrical Ratings: 1. Secondary windings voltage: 480Y/277V Volts, 3-Phase, WYE Grounded. Primary windings voltages: 208Y/120V Volts, 3-Phase . Frequency: 60 Hz. KVA rating: As shown on drawings. Taps: Six (6) 2.5% full capacity taps; 2 above and 4 below, rated voltage. Impedance: For transformers larger than 75 KVA, 4.5% minimum, 5.75% maximum. 2. Winding temperature rise shall be 150 degrees Centigrade in accordance with UL Specification Article 508. 3. Transformer shall be capable of operating at 100% of nameplate rating continuously while in an ambient temperature not exceeding 40 degrees Centigrade. 4. Transformer shall meet the daily overload requirements of ANSI Standard C57.96. Vibration Isolation, Factory-Installed: Provide neoprene rubber pads to isolate core and coil assembly from transformer enclosure. Installation: 1. Anchor transformer securely with minimum 1/2" diameter bolts. Strength of bolts used to secure the transformer shall be sufficient to resist shear and uplift produced by force equal to 1/2 of the equipment mass applied horizontally at center of gravity. 2. Provide 1" thick high resiliency pads to isolate transformer from floor or platform. Korfund "Elasto Rib" or equivalent. 3. Use flexible conduits at least 24" long for electrical connections. 4. Provide grounding of each transformer secondary including all conduits, wires, and connectors in accordance with NEC 250-26 and any local additional regulations.</p>
3.01	<p>GENERAL: A: Electrical system layouts indicated on the drawings are generally diagrammatic and shall be followed as closely as actual construction and work of other trades will permit. Cover exact routing of cable and wiring and the locations of outlets by the structure and equipment served. Take all dimensions from architectural drawings. B. Consult all other drawings, verify scales and report any dimensional discrepancies or other conflicts with Owner before submitting bid. C. All home runs to panelboards are indicated as starting from the outlet nearest the panel and continuing in the general direction of that panel. Continue such circuits to the panel as though the routes were completely indicated. Terminate homeruns of signal, alarm, and communication systems in a similar manner. D. Avoid cutting and boring holes through structure or structural members wherever possible. Obtain prior approval of Owner and conform to all structural requirements when cutting or boring the structure is necessary and permitted. E. Furnish and install all necessary hardware, hangers, blocking, brackets, bracing, runners, etc. required for equipment specified under this Section. F. Provide necessary backing required to insure rigid mounting of outlet boxes.</p>
3.02	<p>WIRING METHODS: A. Install all wiring in raceway or use IMC cable. Where approved by all Applicable codes, conduit shall be rigid steel, IMC or EMT, as follows: 1. Above ground: Use rigid steel, IMC or EMT. a. Wet locations: Rigid steel or IMC only. b. Locations subject to mechanical injury: Rigid steel or IMC only. c. Dry locations and not subject to mechanical injury: EMT, IMC or rigid steel conduit. 2. Underground: Use rigid steel. B. Use flexible conduits in the following applications: 1. Recessed lighting fixtures. 2. Motor connections. 3. At building joints. At wet locations, flexible conduit shall be liquid tight type.</p>
3.03	<p>INSTALLATION OF CONDUITS: A. General: 1. Run all conduit concealed unless otherwise noted or shown. 2. Run all conduit parallel to or at right angles to center lines of columns and beams. 3. Conduits above ceilings shall not obstruct removal of ceiling tiles, lighting fixtures, air diffusers, etc. 4. Conduits shall not cross any duct shaft or area designated as future duct shaft horizontally. Conduit risers when allowed in duct shaft must be coordinated with Mechanical work to avoid any conflict. B. Conduit Supports: 1. Support conduits with Underwriter's Laboratories listed steel conduit supports at intervals required by the National Electric Code. Wires or sheet metal strips are not acceptable for conduit support. Use conduit hangers for all conduits not directly fastened to structure and for all multiple conduit runs. Do not attach any conduit to mechanical ducts or pipes. 2. Individual conduits 1/2" and 3/4" size for lighting may be supported from ceiling support wires with Caddy clips only if acceptable to local code. Only one conduit is permitted to be attached to any ceiling support wire. Hang such conduit so as not to affect level of ceiling. 3. Avoid attaching conduit to fan plenums. When it is necessary to support conduit from fan plenum, provide a length of flexible conduit between portion attached fan plenum and portion attached to the building to minimize transmission of vibration to the building structure.</p>
3.04	<p>CONNECTIONS TO EQUIPMENT: A. General: 1. Furnish and install required power supply conduit and wiring to all equipment. See below for other wiring required. 2. Furnish and install a disconnect switch immediately ahead of and adjacent to each magnetic motor starter or appliance unless the motor appliance is located adjacent and within sight of the serving panelboard, circuit breaker or switch. Verify all equipment nameplate current ratings prior to installation. 3. Install all rough-in work for equipment from approved shop drawings to suit the specific requirements of the equipment. 4. Furnish and install manual thermal protection for all motors not integrally equipped with thermal protection. 5. Furnish 120 Volt power to each control panel and time switch requiring a source of power to operate.</p>
3.05	<p>WIRE COLOR CODE: Color coding shall be continuous for wire #12 through #10 AWG. Phase conductors #8 and larger and nonconductors of any size in cable assemblies may have colored phasing tape at terminations. Color code wires as follows: Voltage Phase A Phase B Phase C Neutral Ground 120/208V Black Blue Yellow White Green 277/480V Brown Orange Yellow Gray Green</p>

PART 3	EXECUTION
3.06	<p>INSTALLATION OF WIRES: A. Pull no wire into any portion of the conduit system until all construction work which might damage the wire has been completed. B. Install all wire continuous from outlet to outlet or terminal to terminal. Splices in cables when required shall be made in handholes, pull boxes or junction boxes. Make branch circuit splices in outlet boxes with 8" of correctly color-coded tails left in the box. C. Splices in wires and cables shall be made utilizing materials and methods described herein before. D. Make all ground, neutral and line connections to receptacle and wiring device terminals as recommended by manufacture. Provide ground jumper from outlet box to ground terminal of devices when the device is not approved for grounding through the mounting screws. E. Provide Brady wire markers where number of conductors in a box exceeds four. F. Megger and record insulation resistance of all 600 Volt insulated conductors size #4/0 and larger using 500 Volt megger for one minute. Make tests with circuits isolated from source and load.</p>
3.07	<p>IDENTIFICATION: A. Provide nameplates for switchgears, panelboards, and all similar devices. Nameplates shall be screwed (no adhesives) engraved bakelite or photo-etched metallic nameplate identification showing panel designation, voltage and phase in minimum 1/4" high letters. B. Provide dyno labels on all lighting switches and convenience and special purpose receptacles to show panel and circuit number to which the device is connected. C. Each panelboard shall contain a metal-framed circuit directory inside cover, with plastic protector. D. Panelboard Schedule: After completion of work, provide typewritten updated panelboard schedules for all panelboards.</p>
3.08	<p>REMODELING WORK: A. Existing electrical wiring which will not be made obsolete and which will be disturbed due to construction changes required by this contract shall be restored to operating condition. Where construction changes require, outlets and conduit runs shall be relocated. Extend conduits and pull in new wiring or install junction boxes and splice in new wiring. B. Outlets from which fixtures, switches, receptacles, and/or other electrical devices are moved and which are not replaced or reused shall be removed, where outlets boxes, etc., are completely removed, the contractor shall cut off conduits and remove wiring. C. Where conduits extending through floors are to be abandoned, the contractor shall cut and cap or plug conduit, and the conduit shall not protrude above the floor. D. Where existing conduit is to be abandoned, the conduit shall be removed if it is exposed, in a crawl space or in accessible ceiling. Where it is impossible to remove the conduit, it shall be cut off and capped or plugged. E. Remove all existing wiring not reused or required to maintain continuity circuits to remain. F. The contractor shall be held fully responsible for the proper restoration of all existing surfaces requiring patching, plastering, painting and/or other repairs due to the installation of electrical work under the terms of this specification. Close all openings, repair all surfaces, etc., as required. G. Maintain circuit continuity to areas outside of this work. Provide new conduit and conductors as required to maintain continuity and maintain area as existing.</p>
3.09	<p>GROUNDING: A. Electrical service and separately derived alternating current system shall be grounded in accordance with NEC Article 250-3 to 250-26, inclusive. B. Ground non-current carrying metal parts of electrical equipment enclosures, frames, conductor raceways or cable trays to provide a low impedance path for line-to-ground fault current and to bond all non-current carrying metal parts together. Provide ground conductor in each raceway system in addition to conductors shown. Equipment ground conductor shall be electrically and mechanically continuous from the electrical circuit source to the equipment to be grounded. Size ground conductors per NEC Article 250-95 unless larger conductors are shown on drawings. C. Grounding conductors shall be identified with green insulation. Where green insulation is not available on larger sizes, black insulation shall be used and suitable identified with green tape at each junction box or device enclosure.</p> <p>END OF SECTION</p>

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS

APPEARING HEREIN CONSTITUTE THE

ORIGINAL AND UNPUBLISHED WORK OF THE

DESIGNER AND THE SAME MAY NOT BE

DUPLICATED, USED OR DISCLOSED WITHOUT

CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY


PROJECT:

IMPREIUM PROJECT - CULTIVATION

TITLE:

ELECTRICAL SPECIFICATIONS

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		NTS
DRAWING NO.		REV.
E 2 . 0 1		0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
LIGHTING LAYOUT 1 OF 4


PROJ. NO.

PROJ. ENGR.

SCALE @ 24X36:
3/16"=1'

DRAWING NO.
E 3 . 0 1 A

REV.
0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

- NOTES:**
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
 2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
 3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
 4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
LIGHTING LAYOUT 2 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'
-----------	-------------	----------------------------

DRAWING NO. E 3 . 0 1 B	REV. 0
-----------------------------------	------------------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:


1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
LIGHTING LAYOUT 3 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'
DRAWING NO. E 3 . 0 1 C		REV. 0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:


IMPREIUM PROJECT - CULTIVATION

TITLE:

LIGHTING LAYOUT 4 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'
-----------	-------------	---------------------------

DRAWING NO. E 3 . 0 1 D	REV. 0
-----------------------------------	------------------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPREIUM PROJECT - CULTIVATION

TITLE:

POWER LAYOUT 1 OF 4


PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		3/16"=1'

DRAWING NO.

E 4 . 0 1 A

REV.

0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
POWER LAYOUT 2 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 3/16"=1'
-----------	-------------	----------------------------

DRAWING NO. E 4 . 0 1 B	REV. 0
-----------------------------------	------------------



CLIENT:
ADDRESS:

CONFIDENTIALITY STATEMENT:
ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:
1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT:
IMPREIUM PROJECT - CULTIVATION

TITLE:
POWER LAYOUT 3 OF 4

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'
-----------	-------------	---------------------------

DRAWING NO. E 4 . 0 1 C	REV. 0
-----------------------------------	------------------



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.


REV. NO.	DESCRIPTION	DATE	BY

PROJECT: IMPREIUM PROJECT - CULTIVATION		
TITLE: POWER LAYOUT 4 OF 4		
PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: 1/4"=1'
DRAWING NO. E 4 . 0 1 D		REV. 0

PERCENT NEUTRAL	TRANSFORMER NAME	SERVES	MOUNTING	KVA	PRIMARY VOLTAGE	SECONDARY VOLTAGE	SECONDARY DEVICE			SETS	PHASE	NEU	GND	CONDUIT
							TYPE	AMPS	POLE					
100%	TR-1	PANEL MDP	WALL/CEILING	1000	480/3PH	208/120, 3PH	MCB	2500	3	6	#600kcmil	#600kcmil	#350G	4"


UFER GROUND NOTE :

ALL STEEL REBARS MEASURING 1/2" OR MORE IN DIAMETER AND 20' OR LONGER IN LENGTH THAT IS ENCASED IN NOT LESS THAN 2 INCHES OF CONCRETE SHALL BE BONDED TO THE BUILDING'S GROUNDING ELECTRODE SYSTEM IN ACCORDANCE WITH CEC 250 (ELECTRICAL SUB CODE) SECTION 250.52(A)(3). THE "UFER" GROUND CAN BE 20 L.F. OF #2 OR #4 COPPER WIRING LAID INSIDE THE FOOTING AND THE SAME WIRE IS LONG ENOUGH TO REACH TO THE LOCATION OF THE MAIN ELECTRICAL PANEL OF THE HOUSE. UFER GROUND CAN BE (1) L-SHAPED PIECE OF #4 STEEL REBAR CONNECTED TO THE OTHER STEEL REBAR IN THE FOOTING AND STICKING OUT IN SUFFICIENT LENGTH FOR CONNECTION AT THE LOCATION OF THE MAIN ELECTRICAL PANEL OF THE HOUSE



DETAIL "G" OF GROUNDING ELECTRODE SYSTEM (*250.50) & GROUNDING ELECTRODES (*250.52) AS SERVICE

SCALE: NTS



DETAIL "H" GROUNDING ELECTRODE SYSTEM (*250.50) & GROUNDING ELECTRODES (*250.52) AS REQUIRED

SCALE: NTS

CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE DESIGNER AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPREIUM PROJECT - CULTIVATION

TITLE:

**SINGLE LINE DIAGRAM
SHEET 1 OF 2**


PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		NTS

DRAWING NO.

E 5 . 0 1

REV.

0



CLIENT:

ADDRESS:

CONFIDENTIALITY STATEMENT:

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

NOTES:

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL
UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN
CONJUNCTION WITH ALL RELEVANT
DESIGNER, ENGINEER OR SPECIALIST
DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL
DIMENSION AT SITE BEFORE COMMENCING
WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR
PROVIDING ALL NECESSARY TEMPORARY
SUPPORT TO THE BUILDING AND ANY
ADJACENT STRUCTURES.

REV. NO.	DESCRIPTION	DATE	BY

PROJECT:

IMPREIUM PROJECT - CULTIVATION

TITLE:

**SINGLE LINE DIAGRAM
SHEET 2 OF 2**

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36:
		NTS

DRAWING NO.

E 6 . 0 1

REV.

0

Location: CORRIDOR					CONNECTED LOAD					DERIV	
	LOAD SUMMARY	CL	DF		A	B	C	TOTAL			
L	Lighting	29.03	1.00	16.77	19.06	18.06		68.11			
R	Recessed Canopy Recept	1.62		1.62				1.62			
H	Heating (Space)		1.25								
C	Cooling		1.00								
A	HVAC		1.00								
P	Process		1.00								
O	Other Continuous		1.25								
K	Kitchen		0.65								
N	Noncontinuous	14.04	1.00	3.94	5.34	4.90	14.04				
M	Motor		1.00								
Total		68.65		22.23	23.40	22.92	81.77				
Total Demand Load (kVA) 81.77											
Total Demand Current (A) 226.98											
Min. Feeder Ampacity (A) 263.72											

PANEL A	
PANELBOARD DESIGNATION	
SYSTEM VOLTAGE	
208/120/3, 3-W	
SYSTEM GROUNDING	
208/120/3, 3-W	
SYSTEM TYPE	
NORMAL	
FEEDER RCT	
300A, 3P CB Bus Plug	
CONDUCTOR TYPE	
350-kcmil, #400 CU	
CONDUCTOR PHASE	
1	
MINS	
300A, 3CB	
SICR	
SERIES RATED	
80%	
Kvcs RATING	
10	
FEEDER LENGTH (FT)	
0	
FEEDER (DIP) IN	
6.65	
FAULT CURRENT	
22	
Kvcs RATING	
22	
ENCLOSURE	
TYPE 1R	

#	DESCRIPTION	W	WIRE	GRD	CB	KVA	A	B	C	KVA	CB	WIRE	GRD	DESCRIPTION	#
1	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	5.16			2.58	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	2
3	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	6.45			3.23	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	4
5	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23		5.16	5.16	2.58	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	6
7	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	6.45			3.23	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	8
9	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23		5.16	5.16	2.58	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	10
11	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	6.45			3.23	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	12
13	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	5.16			2.58	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	14
15	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	6.45			3.23	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	16
17	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23		5.16	5.16	2.58	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	18
19	Lighting Veg Room A	L	2x 10 AWG	#100	30A-1P	3.23	6.45			3.23	30A-1P	2x 10 AWG	#100	Lighting Veg Room A	20
21	Sockets Veg Room A	R	2x 12 AWG	#120	20A-1P	0.81	1.62	0.81		0.81	20A-1P	2x 12 AWG	#120	Sockets Veg Room A	22
23	to back boost (200V/240V-1.5kva) of dehumidifier 1	N	2x 12 AWG	#120	20A-2P	0.75		1.50	0.75	0.75	20A-2P	2x 12 AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 2	24
25	to back boost (200V/240V-1.5kva) of dehumidifier 2	N	2x 12 AWG	#120	20A-2P	0.75	1.50		0.75	0.75	20A-2P	2x 12 AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 3	26
27	to back boost (200V/240V-1.5kva) of dehumidifier 3	N	2x 12 AWG	#120	20A-2P	0.75		1.50	0.75	0.75	20A-2P	2x 12 AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 4	28
29	EF-17	N	2x 12 AWG	#120	20A-1P	0.83	1.03			0.83	20A-1P	2x 12 AWG	#120	EF-09	30
32	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58	0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	34
33	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	36
35	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58		0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	38
37	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	40
39	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58		0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	42
41	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	44
43	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58		0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	46
45	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	48
47	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	50
49	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58		0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	52
51	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	54
53	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	56
55	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29	0.58		0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	58
57	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	60
59	OSCILLATING FAN	N	2x 12 AWG	#120	20A-1P	0.29		0.58	0.58	0.58	20A-1P	2x 12 AWG	#120	OSCILLATING FAN	62
61	SPARE	N	20A-1P							20A-1P				SPARE	64
63	SPARE	N	20A-1P							20A-1P				SPARE	66
65	SPARE	N	20A-1P							20A-1P				SPARE	68
Total Connected Load 22.91 22.91 21.52															

Location: CORRIDOR						CONNECTED LOAD		DEMAND	PANEL A'		
LOAD SUMMARY						A	B	C	TOTAL	PANELBOARD DESIGNATION	
CL	DF										
L Lighting	29.03	1.00	12.90	9.89	6.45	29.03				SYSTEM VOLTAGE	208/120/3, 3-W
M Convenience Recept	8.07	1.00	0.81	3.23	4.04	8.07				BUS SIZE	200
H Heating (Space)	1.25					1.25				SYSTEM TYPE	NORMAL
C Cooling	1.00					1.00				FEEDER WIRE	208A-3C-THHN CU
A HVAC	1.00					1.00				CONDUCTOR SIZE	30A-4G-865 CU
P Process	1.00					1.00				CONDUCTOR CIRCUMFERENCE	1
O Other Continuous	1.25					1.25				MANUFACTURER	20GA MCB
K Kitchen	0.65					0.65				OVER CURRENT	SERIES TRIP
N Noncontinuous	11.20	1.00	4.22	3.39	3.58	11.20				MOB WIRING	80%
M Motor	1.00					1.00				GROUND FAULT	NO
Total	48.29		17.93	10.29	14.07	48.29				FEEDER LENGTH (FT)	50
Total Demand Load (KVA) 48.29										FEEDER % DROP (%)	0.640
Total Demand Current (A) 134.04										FAULT CURRENT	
Min. Feeder Ampacity (A) 167.55										NOM RATING	32
										ENCLOSURE	TYPE 1R

1	DESCRIPTION	W	R	E	GRD	CB	KVA	A	B	C	KVA	CB	W	R	E	GRD	DESCRIPTION	1	2		
1	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45		3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	2		
2	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	4		
3	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	6	
4	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	8	
5	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	10	
6	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	12	
7	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	14	
8	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	16	
9	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	18	
10	LIGHTING AT FLOWER ROOM A'	L	2x	10	AWG	#100	30A-1P	3.23	6.45	3.23	6.45	3.23	30A-1P	2x	10	AWG	#100	LIGHTING AT FLOWER ROOM A'	L	20	
11	Sockets Flower ROOM A'	R	2x	12	AWG	#120	30A-1P	0.81	1.74		0.81	20A-1P	2x	12	AWG	#120	Sockets Flower ROOM A'	R	22		
12	EF-17	N	2x	12	AWG	#120	30A-1P	0.09	0.84		0.09	0.75	20A-1P	2x	12	AWG	#120	EF-17	N	24	
13	to back boost (200V/240V-1.5kva) of dehumidifier 1	N	2x	12	AWG	#120	30A-2P	0.75	1.50		0.75	1.50	0.75	20A-2P	2x	12	AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 1	N	26
14	to back boost (200V/240V-1.5kva) of dehumidifier 2	N	2x	12	AWG	#120	30A-2P	0.75	1.50		0.75	1.50	0.75	20A-2P	2x	12	AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 2	N	28
15	to back boost (200V/240V-1.5kva) of dehumidifier 3	N	2x	12	AWG	#120	30A-2P	0.75	1.50		0.75	1.50	0.75	20A-2P	2x	12	AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 3	N	30
16	to back boost (200V/240V-1.5kva) of dehumidifier 4	N	2x	12	AWG	#120	30A-2P	0.75	1.50		0.75	1.50	0.75	20A-2P	2x	12	AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 4	N	32
17	to back boost (200V/240V-1.5kva) of dehumidifier 5	N	2x	12	AWG	#120	30A-2P	0.75	1.50		0.75	1.50	0.75	20A-2P	2x	12	AWG	#120	to back boost (200V/240V-1.5kva) of dehumidifier 5	N	34
18	CO2/LA/TION FAN	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	CO2/LA/TION FAN	N	36	
19	CO2/LA/TION FAN	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	CO2/LA/TION FAN	N	38	
20	CO2/LA/TION FAN	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	CO2/LA/TION FAN	N	40	
21	CO2/LA/TION FAN	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	CO2/LA/TION FAN	N	42	
22	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	44	
23	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	46	
24	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	48	
25	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	50	
26	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	52	
27	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	54	
28	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	56	
29	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	58	
30	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	60	
31	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	62	
32	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	64	
33	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	66	
34	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	68	
35	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	70	
36	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	72	
37	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	74	
38	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	76	
39	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	78	
40	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	80	
41	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	82	
42	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	84	
43	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	86	
44	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	88	
45	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	90	
46	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	92	
47	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	94	
48	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	96	
49	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	98	
50	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	100	
51	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	102	
52	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	104	
53	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	106	
54	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	108	
55	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	110	
56	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	112	
57	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	114	
58	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	116	
59	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	118	
60	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	120	
61	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	122	
62	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	124	
63	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	126	
64	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	128	
65	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	130	
66	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	132	
67	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	134	
68	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	136	
69	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	138	
70	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0.29	9.58	0.29	20A-1P	2x	12	AWG	#120	SPIRINE	N	140	
71	SPIRINE	N	2x	12	AWG	#120	20A-1P	0.29	9.58	0											

Location: BLEC												PANEL C-0											
LOAD SUMMARY												PANELLED DESCRIPTION											
CL	GF	A	B	C	D	E	F	G	H	WIRE	GRD	DESCRIPTION	CL	GF	A	B	C	D	E	F	G	H	DESCRIPTION
1	Lighting	10.42	1.25	6.28	1.66	0.69	13.13						SYSTEM VOLTAGE										200/120V, 3Ø, 4W
2	Communications Recptl	10.44		2.09	0.83	4.60	14.72						BUS SIZE										200
3	Heating (space)		1.00										CONDUCTOR TYPE										ROMAN
4	Cooling		1.00										FLEDER HP										200A-3P DB Bus Rng
5	PVAC	1.00											CONDUCTOR SIZE										50A AWG - #60
6	Process	1.00											CONDUCTOR TYPE										200A-3P DB Bus Rng
7	Other Control	1.25											CONDUCTOR SIZE										50A AWG - #60
8	Kitchen	5.00	0.65										CONDUCTOR TYPE										200A-3P DB Bus Rng
9	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
10	Water	27.77	0.80	10.16	6.50	11.31	22.32						CONDUCTOR TYPE										200A-3P DB Bus Rng
11	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
12	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
13	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
14	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
15	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
16	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
17	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
18	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
19	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
20	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
21	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
22	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
23	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
24	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
25	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
26	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
27	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
28	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
29	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
30	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
31	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
32	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
33	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
34	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
35	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
36	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
37	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
38	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
39	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
40	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
41	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
42	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
43	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
44	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
45	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
46	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
47	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
48	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
49	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
50	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
51	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
52	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
53	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
54	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
55	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
56	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
57	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
58	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
59	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
60	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
61	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
62	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
63	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
64	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
65	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
66	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
67	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
68	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
69	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
70	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
71	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
72	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
73	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
74	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
75	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
76	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
77	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
78	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
79	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
80	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
81	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
82	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
83	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
84	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
85	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
86	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
87	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
88	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
89	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
90	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
91	Water	2.00	1.00										CONDUCTOR SIZE										50A AWG - #60
92	Water	2.00	1.00										CONDUCTOR TYPE										200A-3P DB Bus Rng
93	Water	2.00	1.00										CONDUCTOR SIZE								</		

Location: BLDG

LOAD SUMMARY

DL

BF

CONNECTED LOAD

A

B

C

(DEMAND TOTAL)

Lighting

Convenience recept

Ventilation (HVAC)

Cooking

HVAC

Elevators

Other Continuous

Kitchen

Laundry/Habitus

Motor

Total Demand Load (KVA)

Total Demand Current (A)

Min. Feeder Ampacity (A)

1.25

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

[illegible]

Location: ELEC		CONNECTED LOAD			DEMAND TOTAL		PANEL MGB		PANEL DESIGNATION	
CL	DP	A	B	C						
	1.25								SYSTEM VOLTAGE	480Y/277, 3Ø, 4W
									BUS SIZE	4000
	1.50								SYSTEM TYPE	NORMAL
	1.00								FEEDER HINT	1000A-3P-CH Bus BRK
	1.00								CONNECTION SIZE	600-KWH - 4NDS, CU
	1.00								CONDUCTOR W/ARE	4
	1.25								BARNS	1000A TACB
	0.60								DOOR	3000A HATED
000.37	1.00	300.20	332.40	315.71	000.37				MOD RATING	80%
	1.00								GROUND FAULT	100
000.37		300.20	332.40	315.71	000.37				FEEDER LENGTH (FT)	
									FEEDER V. DROP (%)	
000.37									FAULT CURRENT	
(A)	1200.00								SAFETY FACTOR	30
(A)	1201.07								ENCLOSURE	TYPE 3N

ALL DRAWINGS AND WRITTEN MATERIALS
APPEARING HEREIN CONSTITUTE THE
ORIGINAL AND UNPUBLISHED WORK OF THE
DESIGNER AND THE SAME MAY NOT BE
DUPLICATED, USED OR DISCLOSED WITHOUT
CONSENT OF THE DESIGNER.

1. ALL DIMENSIONS HEREIN ARE IN IMPERIAL UNITS UNLESS STATED OTHERWISE.
2. THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH ALL RELEVANT DESIGNER, ENGINEER OR SPECIALIST DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR MUST CHECK ALL DIMENSION AT SITE BEFORE COMMENCING WORK.
4. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY TEMPORARY SUPPORT TO THE BUILDING AND ANY ADJACENT STRUCTURES.

[illegible]

IMPREIUM PROJECT - CULTIVATION

TITLE:

PANEL BOARD SCHEDULE
SHEET 2 OF 2

PROJ. NO.	PROJ. ENGR.	SCALE @ 24X36: NTS
DRAWING NO. E 8 . 0 1		REV. 0