

Infiltration Summary

ZONE NAME	Heating				Cooling			
	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²
(Rest of House Hydron	82288	0.74	1015	9.1	82288	0.38	521	1.1
AHU-Upper- ST	8136	1.24	168	9.1	8136	0.63	86	1.1
AH2	27353	0.63	286	9.1	27353	0.32	147	1.1
AHU- main Plan	28505	0.70	331	9.1	28505	0.36	170	1.1
AHU basement	18294	0.75	230	9.1	18294	0.39	118	1.1
Entire House	164576	0.37	1015	9.1	164576	0.19	521	1.1

Load and AVF Summary

ROOM NAME	Area ft²	Htg load Btuh	Clg load Btuh	Htg AVF cfm	Clg AVF cfm
Bedroom 3U	259	6023	3075	134	154
Bedroom 3	259	4617	1248	47	56
Bedroom4	180	1571	153	16	7
Kitch/ Studio APT	459	6051	1253	62	56
WIC	42	43	221	0	10
Bedroom 1	333	5619	1174	58	52
Walkway B	295	299	0	3	0
WIC 2	47	4629	812	48	36
Bedroom 2	195	3530	654	36	29
Office	271	5634	2979	96	141
Media Room	726	9441	4744	161	225
Closet	18	1237	180	21	9
Guest Bedroom	230	2055	775	35	37
Laundry	74	962	140	16	7
Mudroom	88	3120	521	53	25
Great R/Kit/Pant	1441	18917	6006	322	285
Entrance	320	5570	1530	95	73
Room U	42	90	52	2	3
Bunk Room	464	9352	3928	208	197
Open to Below U	578	6930	3192	154	160
Primary suite U	450	4559	3067	101	154
Exercice Room U	228	8500	2244	189	112
Bedroom 2 U	188	2875	1540	64	77
Walk Way	499	7091	3125	157	157
Office U	198	1487	1174	33	59
Studio U	263	6222	4021	177	217
Great /Din/Kit U	641	21973	10813	623	583
WIC U	192	2655	566	59	28
Great R/ Din/Kit	638	9080	2663	93	119
(Rest of House Hydronic)	9616	160129	59987	0	0
Great /Din/Kit U	641	21973	10813	623	583
Studio U	263	6222	4021	177	217
AHU-Upper- ST	904	28195	14833	800	800
Bedroom 3U	259	6023	3075	134	154
Open to Below U	578	6930	3192	154	160
Primary suite U	450	4559	3067	101	154
Bedroom 2 U	188	2875	1540	64	77
Exercice Room U	228	8500	2244	189	112
WIC U	192	2655	566	59	28
Office U	198	1487	1174	33	59
Room U	42	90	52	2	3
Bunk Room	464	9352	3928	208	197
Walk Way	499	7091	3125	157	157
AH2	3097	49561	21962	1100	1100
Media Room	726	9441	4744	161	225
Great R/Kit/Pant	1441	18917	6006	322	285
Entrance	320	5570	1530	95	73
Office	271	5634	2979	96	141
Guest Bedroom	230	2055	775	35	37
Laundry	74	962	140	16	7
Mudroom	88	3120	521	53	25
Closet	18	1237	180	21	9
AHU- main Plan	3167	46935	16875	800	800
Bedroom 3	259	4617	1248	47	56
Walkway B	295	299	0	3	0
Bedroom 1	333	5619	1174	58	52

Kitch/ Studio APT	459	6051	1253	62	56
Bedroom4	180	1571	153	16	7
Bedroom 2	195	3530	654	36	29
WIC 2	47	4629	812	48	36
WIC	42	43	221	0	10
Great R/ Din/Kit	638	9080	2663	93	119
AHU basement	2448	35437	8178	364	364
Entire House	9616	160129	61184	3064	3064

BCE COMPANY

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Notes:

Design Information

Weather: Logan Cache, UT, US

Winter Design Conditions

Outside db 0 °F
Inside db 68 °F
Design TD 68 °F

Summer Design Conditions

Outside db 91 °F
Inside db 75 °F
Design TD 16 °F
Daily range H
Relative humidity 50 %
Moisture difference -31 gr/lb

Heating Summary

Structure 49561 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 49561 Btuh

Sensible Cooling Equipment Load Sizing

Structure 21962 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.96
Equipment sensible load 21149 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure -2608 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 0 Btuh

	Heating	Cooling
Area (ft²)	3097	3097
Volume (ft³)	27353	27353
Air changes/hour	0.63	0.32
Equiv. AVF (cfm)	286	147

Equipment Total Load (Sen+Lat) 21149 Btuh
Req. total capacity at 0.70 SHR 2.5 ton

Heating Equipment Summary

Make Carrier
Trade CARRIER
Model 25VNA837A0030
AHRI ref 9893266

Efficiency 8.5 HSPF
Heating input
Heating output 49000 Btuh @ 47°F
Temperature rise 48 °F
Actual air flow 1100 cfm
Air flow factor 0.022 cfm/Btuh
Static pressure 0.60 in H2O
Space thermostat
Capacity balance point = 15 °F

Backup:
Input = 15 kW, Output = 49561 Btuh, 100 AFUE

Cooling Equipment Summary

Make Carrier
Trade CARRIER
Cond 25VNA837A0030
Coil CNPVP3617ALA+59TP6A060E17-14+UI
AHRI ref 9893266
Efficiency 11.5 EER, 17 SEER
Sensible cooling 21980 Btuh
Latent cooling 9420 Btuh
Total cooling 31400 Btuh
Actual air flow 1100 cfm
Air flow factor 0.050 cfm/Btuh
Static pressure 0.60 in H2O
Load sensible heat ratio 1.00

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Notes:

Design Information

Weather: Logan Cache, UT, US

Winter Design Conditions

Outside db 0 °F
Inside db 68 °F
Design TD 68 °F

Summer Design Conditions

Outside db 91 °F
Inside db 75 °F
Design TD 16 °F
Daily range H
Relative humidity 50 %
Moisture difference -31 gr/lb

Heating Summary

Structure 35437 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 35437 Btuh

Sensible Cooling Equipment Load Sizing

Structure 8178 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.96
Equipment sensible load 7875 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure -1896 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 0 Btuh

	Heating	Cooling
Area (ft²)	2448	2448
Volume (ft³)	18294	18294
Air changes/hour	0.75	0.39
Equiv. AVF (cfm)	230	118

Equipment Total Load (Sen+Lat) 7875 Btuh
Req. total capacity at 0.70 SHR 0.9 ton

Heating Equipment Summary

Make Generic
Trade
Model SEER 14.0, HSPF 8.1
AHRI ref
Efficiency 8.1 HSPF
Heating input
Heating output 10880 Btuh @ 47°F
Temperature rise 32 °F
Actual air flow 364 cfm
Air flow factor 0.010 cfm/Btuh
Static pressure 0.60 in H2O
Space thermostat
Capacity balance point = 43 °F

Cooling Equipment Summary

Make Generic
Trade
Cond SEER 14.0, HSPF 8.1
Coil
AHRI ref
Efficiency 12.2 EER, 14 SEER
Sensible cooling 7654 Btuh
Latent cooling 3280 Btuh
Total cooling 10934 Btuh
Actual air flow 364 cfm
Air flow factor 0.045 cfm/Btuh
Static pressure 0.60 in H2O
Load sensible heat ratio 1.00

Backup:
Input = 10 kW, Output = 35437 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Notes:

Design Information

Weather: Logan Cache, UT, US

Winter Design Conditions

Outside db 0 °F
Inside db 68 °F
Design TD 68 °F

Summer Design Conditions

Outside db 91 °F
Inside db 75 °F
Design TD 16 °F
Daily range H
Relative humidity 50 %
Moisture difference -31 gr/lb

Heating Summary

Structure 46935 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 46935 Btuh

Sensible Cooling Equipment Load Sizing

Structure 16875 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.96
Equipment sensible load 16250 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure -3013 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 0 Btuh

	Heating	Cooling
Area (ft²)	3167	3167
Volume (ft³)	28505	28505
Air changes/hour	0.70	0.36
Equiv. AVF (cfm)	331	170

Equipment Total Load (Sen+Lat) 16250 Btuh
Req. total capacity at 0.70 SHR 1.9 ton

Heating Equipment Summary

Make Carrier
Trade CARRIER
Model 25HNB624C00320
AHRI ref 9637497
Efficiency 8.2 HSPF
Heating input 25200 Btuh @ 47°F
Heating output 34 °F
Temperature rise 800 cfm
Actual air flow 0.017 cfm/Btuh
Air flow factor 0.60 in H2O
Static pressure
Space thermostat
Capacity balance point = 31 °F

Cooling Equipment Summary

Make Carrier
Trade CARRIER
Cond 25HNB624C00320
Coil CNPVT3617ALA+59SP5A040E17-12
AHRI ref 9637497
Efficiency 16.0 EER, 12 SEER
Sensible cooling 16380 Btuh
Latent cooling 7020 Btuh
Total cooling 23400 Btuh
Actual air flow 800 cfm
Air flow factor 0.047 cfm/Btuh
Static pressure 0.60 in H2O
Load sensible heat ratio 1.00

Backup:
Input = 14 kW, Output = 46935 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Notes:

Design Information

Weather: Logan Cache, UT, US

Winter Design Conditions

Outside db 0 °F
Inside db 68 °F
Design TD 68 °F

Summer Design Conditions

Outside db 91 °F
Inside db 75 °F
Design TD 16 °F
Daily range H
Relative humidity 50 %
Moisture difference -31 gr/lb

Heating Summary

Structure 28195 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 28195 Btuh

Sensible Cooling Equipment Load Sizing

Structure 14833 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.96
Equipment sensible load 14285 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure -1527 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 0 Btuh

	Heating	Cooling
Area (ft²)	904	904
Volume (ft³)	8136	8136
Air changes/hour	1.24	0.63
Equiv. AVF (cfm)	168	86

Equipment Total Load (Sen+Lat) 14285 Btuh
Req. total capacity at 0.70 SHR 1.7 ton

Heating Equipment Summary

Make Trane
Trade TRANE
Model 4TWR4024G1
AHRI ref 203504726
Efficiency 8.2 HSPF
Heating input 22600 Btuh @ 47°F
Heating output 30 °F
Temperature rise 800 cfm
Actual air flow 0.028 cfm/Btuh
Air flow factor 0.75 in H2O
Static pressure
Space thermostat
Capacity balance point = 20 °F

Cooling Equipment Summary

Make Trane
Trade TRANE
Cond 4TWR4024G1
Coil A(A,B)W254++TDR
AHRI ref 203504726
Efficiency 11.1 EER, 14 SEER
Sensible cooling 14840 Btuh
Latent cooling 6360 Btuh
Total cooling 21200 Btuh
Actual air flow 800 cfm
Air flow factor 0.054 cfm/Btuh
Static pressure 0.75 in H2O
Load sensible heat ratio 1.00

Backup:
Input = 8 kW, Output = 28195 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Design Conditions

Location:

Logan Cache, UT, US
Elevation: 4455 ft
Latitude: 42°N

Outdoor:

Dry bulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

0
-
-
15.0

Cooling

91
36 (H)
61
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

68
68
50
54.9


Cooling

75
16
50
-30.7

Infiltration:

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 30.7%.

Zone does not have adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 90 Btuh (PFG - 1.3*AFG)

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Design Conditions

Location:

Logan Cache, UT, US
Elevation: 4455 ft
Latitude: 42°N

Outdoor:

Dry bulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

0
-
-
15.0

Cooling

91
36 (H)
61
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

68
68
50
54.9


Cooling

75
16
50
-30.7

Infiltration:

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 32.1%.

Zone does not have adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 96 Btuh (PFG - 1.3*AFG)

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Design Conditions

Location:

Logan Cache, UT, US
Elevation: 4455 ft
Latitude: 42°N

Outdoor:

Dry bulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

0
-
-
15.0

Cooling

91
36 (H)
61
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

68
68
50
54.9


Cooling

75
16
50
-30.7

Infiltration:

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 27.9%.

Zone has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

Design Conditions

Location:

Logan Cache, UT, US
Elevation: 4455 ft
Latitude: 42°N

Outdoor:

Dry bulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

0
-
-
15.0

Cooling

91
36 (H)
61
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

68
68
50
54.9


Cooling

75
16
50
-30.7

Infiltration:

Test for Adequate Exposure Diversity


Hourly Glazing Load



Maximum hourly glazing load exceeds average by 50.2%.

Zone does not have adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 1675 Btuh (PFG - 1.3*AFG)




Job #: 19
Performed for:
Butler Residence
LOT 130
LEHI - UT, UT

Scale: 1 : 135
Page 1
Right-Suite® Universal 2022
22.0.02 RSU63584
2022-May-27 21:38:33
...\\Project 08\\Butler Residence.rup



Main floor plan




Job #: 19
Performed for:
Butler Residence
LOT 130
LEHI - UT, UT

Scale: 1 : 135
Page 2
Right-Suite® Universal 2022
22.0.02 RSU63584
2022-May-27 21:38:33
...\\Project 08\\Butler Residence.rup



Upper floor Plan



Job #: 19
Performed for:
Butler Residence
LOT 130
LEHI - UT, UT

Scale: 1 : 135

Page 3
Right-Suite® Universal 2022
22.0.02 RSU63584
2022-May-27 21:38:33
...\\Project 08\\Butler Residence.rup

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

	Heating	Cooling
External static pressure	0.60 in H2O	0.60 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.60 in H2O	0.60 in H2O
Supply / return available pressure	0.300 / 0.300 in H2O	0.300 / 0.300 in H2O
Lowest friction rate	0.220 in/100ft	0.220 in/100ft
Actual air flow	1100 cfm	1100 cfm
Total effective length (TEL)	273 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bedroom 2 U	c 1540	64	77	0.220	5.0	0x0	ShMt	38.0	235.0	st21
Bedroom 3U	c 3075	134	154	0.351	6.0	0x0	ShMt	56.0	115.0	st23
Bunk Room	h 4676	104	98	0.317	5.0	0x0	ShMt	59.0	130.0	st22
Bunk Room-A	h 4676	104	98	0.336	5.0	0x0	ShMt	48.5	130.0	st22
Exercise Room U	h 4250	94	56	0.360	5.0	0x0	ShMt	46.5	120.0	st20
Exercise Room U-A	h 4250	94	56	0.314	5.0	0x0	ShMt	36.0	155.0	st20
Office U	c 1174	33	59	0.269	4.0	0x0	ShMt	33.0	190.0	st21
Open to Below U	c 3192	154	160	0.350	6.0	0x0	ShMt	21.5	150.0	st7
Primary suite U	c 3067	101	154	0.312	6.0	0x0	ShMt	27.5	165.0	st20
Room U	c 52	2	3	0.359	4.0	0x0	ShMt	37.0	130.0	st22
WIC U	h 2655	59	28	0.233	5.0	0x0	ShMt	33.0	225.0	st21
Walk Way	h 7091	157	157	0.323	6.0	0x0	ShMt	35.5	150.0	st23

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st20	Peak AVF	290	266	0.312	830	8.0	0 x 0	ShtMetl	st6
st6	Peak AVF	446	430	0.220	817	10.0	0 x 0	ShtMetl	
st21	Peak AVF	156	164	0.220	837	6.0	0 x 0	ShtMetl	st6
st22	Peak AVF	210	199	0.317	784	7.0	0 x 0	ShtMetl	st7
st23	Peak AVF	291	311	0.323	890	8.0	0 x 0	ShtMetl	st7
st7	Peak AVF	654	670	0.317	853	12.0	0 x 0	ShtMetl	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x 0	94	56	0	0	0	0	0x 0		ShMt	
rb28	0x 0	104	98	0	0	0	0	0x 0		ShMt	
rb31	0x 0	29	14	0	0	0	0	0x 0		ShMt	
rb32	0x 0	29	14	0	0	0	0	0x 0		ShMt	
rb35	0x 0	33	59	0	0	0	0	0x 0		ShMt	
rb34	0x 0	157	157	0	0	0	0	0x 0		ShMt	
rb33	0x 0	64	77	0	0	0	0	0x 0		ShMt	
rb36	0x 0	94	56	0	0	0	0	0x 0		ShMt	
rb30	0x 0	101	154	0	0	0	0	0x 0		ShMt	
rb27	0x 0	154	160	0	0	0	0	0x 0		ShMt	
rb26	0x 0	104	98	0	0	0	0	0x 0		ShMt	
rb37	0x 0	2	3	0	0	0	0	0x 0		ShMt	
rb29	0x 0	134	154	0	0	0	0	0x 0		ShMt	

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

	Heating	Cooling
External static pressure	0.60 in H ₂ O	0.60 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.60 in H ₂ O	0.60 in H ₂ O
Supply / return available pressure	0.300 / 0.300 in H ₂ O	0.300 / 0.300 in H ₂ O
Lowest friction rate	0.230 in/100ft	0.230 in/100ft
Actual air flow	364 cfm	364 cfm
Total effective length (TEL)	261 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bedroom 1	h 2809	29	26	0.262	4.0	0x0	ShMt	34.0	195.0	st12
Bedroom 1-A	h 587	29	26	0	0	0x0	ShMt	0	0	
Bedroom 2	h 3530	36	29	0.230	4.0	0x0	ShMt	35.5	225.0	st13
Bedroom 3	c 1248	47	56	0.359	4.0	0x0	ShMt	47.0	120.0	st12
Bedroom4	h 1571	16	7	0.441	4.0	0x0	ShMt	31.0	105.0	st1
Great R/ Din/Kit	c 1332	47	59	0.277	4.0	0x0	ShMt	26.5	190.0	st12
Great R/ Din/Kit-A	c 1332	47	59	0.312	4.0	0x0	ShMt	37.5	155.0	st12
Kitch/ Studio/APT	h 6051	62	56	0.351	4.0	0x0	ShMt	31.0	140.0	st1
WIC	c 221	0	10	0.314	4.0	0x0	ShMt	31.0	160.0	st1
WIC 2	h 4629	48	36	0.241	4.0	0x0	ShMt	33.5	215.0	st13
Walkway B	h 149	2	0	0.237	4.0	0x0	ShMt	18.5	235.0	st13
Walkway BA	h 0	2	0	0	0	0x0	ShMt	0	0	

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st13	Peak AVF	85	65	0.230	626	5.0	0 x 0	ShtMetl	st2
st1	Peak AVF	79	72	0.314	577	5.0	0 x 0	ShtMetl	
st12	Peak AVF	170	200	0.262	749	7.0	0 x 0	ShtMetl	st2
st2	Peak AVF	255	265	0.230	761	8.0	0 x 0	ShtMetl	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb8	0x 0	49	56	0	0	0	0	0x 0		ShMt	
rb5	0x 0	58	52	0	0	0	0	0x 0		ShMt	
rb7	0x 0	93	119	0	0	0	0	0x 0		ShMt	
rb11	0x 0	36	29	0	0	0	0	0x 0		ShMt	
rb6	0x 0	49	36	0	0	0	0	0x 0		ShMt	
rb9	0x 0	0	10	0	0	0	0	0x 0		ShMt	
rb10	0x 0	62	56	0	0	0	0	0x 0		ShMt	
rb13	0x 0	16	7	0	0	0	0	0x 0		ShMt	

BCE COMPANY

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

	Heating	Cooling
External static pressure	0.60 in H ₂ O	0.60 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.60 in H ₂ O	0.60 in H ₂ O
Supply / return available pressure	0.300 / 0.300 in H ₂ O	0.300 / 0.300 in H ₂ O
Lowest friction rate	0.248 in/100ft	0.248 in/100ft
Actual air flow	800 cfm	800 cfm
Total effective length (TEL)	242 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Closet	h 1237	21	9	0.364	4.0	0x0	ShMt	35.0	130.0	st16
Entrance	h 5570	95	73	0.317	5.0	0x0	ShMt	24.5	165.0	st3
Great R/Klt/Pant	h 6306	107	95	0.248	5.0	0x0	ShMt	27.0	215.0	st3
Great R/Klt/Pant-A	h 6305	107	95	0.361	5.0	0x0	ShMt	36.0	130.0	st17
Great R/Klt/Pant-B	h 6305	107	95	0.379	5.0	0x0	ShMt	18.5	140.0	st17
Guest Bedroom	c 775	35	37	0.342	4.0	0x0	ShMt	35.5	140.0	st16
Laundry	h 962	16	7	0.344	4.0	0x0	ShMt	44.5	130.0	st16
Media Room	c 2372	80	112	0.405	5.0	0x0	ShMt	38.0	110.0	st3
Media Room-A	c 2372	80	112	0.313	5.0	0x0	ShMt	36.5	155.0	st3
Mudroom	h 3120	53	25	0.335	4.0	0x0	ShMt	49.0	130.0	st16
Office	c 2979	96	141	0.323	6.0	0x0	ShMt	41.0	145.0	st3

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	459	534	0.248	809	11.0	0 x 0	ShtMetl	st4
st16	Peak AVF	126	77	0.335	640	6.0	0 x 0	ShtMetl	
st4	Peak AVF	341	266	0.335	771	9.0	0 x 0	ShtMetl	
st17	Peak AVF	215	190	0.361	804	7.0	0 x 0	ShtMetl	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	0x 0	107	95	0	0	0	0	0x 0		ShMt	
rb23	0x 0	161	225	0	0	0	0	0x 0		ShMt	
rb18	0x 0	95	73	0	0	0	0	0x 0		ShMt	
rb25	0x 0	107	95	0	0	0	0	0x 0		ShMt	
rb19	0x 0	204	236	0	0	0	0	0x 0		ShMt	
rb20	0x 0	53	25	0	0	0	0	0x 0		ShMt	
rb21	0x 0	16	7	0	0	0	0	0x 0		ShMt	
rb17	0x 0	35	37	0	0	0	0	0x 0		ShMt	
rb15	0x 0	21	9	0	0	0	0	0x 0		ShMt	

BCE COMPANY

Project Information

For: Buter Residence, Twoleaf Design Group
LOT 130, LEHI - UT, UT

	Heating	Cooling
External static pressure	0.75 in H ₂ O	0.75 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.75 in H ₂ O	0.75 in H ₂ O
Supply / return available pressure	0.375 / 0.375 in H ₂ O	0.375 / 0.375 in H ₂ O
Lowest friction rate	0.300 in/100ft	0.300 in/100ft
Actual air flow	800 cfm	800 cfm
Total effective length (TEL)	250 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Great /Din/Kit U	h 7325	208	194	0.509	7.0	0x0	ShMt	12.3	135.0	st19
Great /Din/Kit U-A	h 7324	208	194	0.353	7.0	0x0	ShMt	22.3	190.0	st18
Great /Din/Kit U-B	h 7324	208	194	0.300	7.0	0x0	ShMt	24.8	225.0	st18
Studio U	c 2010	88	108	0.457	5.0	0x0	ShMt	29.3	135.0	st19
Studio U-A	c 2010	88	108	0.439	5.0	0x0	ShMt	25.8	145.0	st19

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st18	Peak AVF	416	389	0.300	762	10.0	0 x 0	ShtMetl	st5
st5	Peak AVF	800	800	0.300	868	13.0	0 x 0	ShtMetl	
st19	Peak AVF	384	411	0.439	754	10.0	0 x 0	ShtMetl	st5

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb40	0x 0	88	108	0	0	0	0	0x 0		ShMt	
rb41	0x 0	208	194	0	0	0	0	0x 0		ShMt	
rb42	0x 0	208	194	0	0	0	0	0x 0		ShMt	
rb38	0x 0	208	194	0	0	0	0	0x 0		ShMt	
rb39	0x 0	88	108	0	0	0	0	0x 0		ShMt	

BCE COMPANY