

## Infiltration Summary

ZONE NAME	Heating				Cooling			
	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²	Volume ft³	ACH	AVF cfm	HTM Btuh/ft²
AHU-01	36693	0.24	145	1.7	36693	0.13	78	0.8
AHU-02	11213	0.42	79	1.7	11213	0.23	42	0.8
Entire House	47906	0.28	224	1.7	47906	0.15	120	0.8

## Load and AVF Summary

ROOMNAME	Area ft²	Htg load Btuh	Clg load Btuh	HtgAVF cfm	ClgAVF cfm
G. bath	69	479	769	50	46
G. bedroom	239	2116	3712	219	222
Great Room	656	3897	6742	404	403
Toilet	20	170	173	18	10
Guest Bath	62	386	449	40	27
Guest BR	256	2249	3905	233	233
hallway	177	0	0	0	0
Entry/Dining	719	4349	7564	450	452
kitchen	553	3089	5551	320	331
Bath 2	72	550	675	57	40
B. Bedroom	237	2023	3948	210	236
AHU-01	3058	19308	33489	2000	2000
M. Bedroom	372	3885	6958	860	907
M. Closet	151	1416	2284	313	298
Office	74	948	1961	210	256
M. Bath	116	679	807	150	105
Activity RM	222	2109	3330	467	434
AHU-02	934	9037	15340	2000	2000
Entire House	3992	28344	48828	4000	4000

**Project Information**

For: Kasraee Residence  
6804 E Gold Dus Ave, Paradise Valley, AZ 85253

Notes:

**Design Information**

Weather: Phoenix Co, AZ, US

**Winter Design Conditions**

Outside db 35 °F  
Inside db 68 °F  
Design TD 33 °F

**Summer Design Conditions**

Outside db 106 °F  
Inside db 75 °F  
Design TD 31 °F  
Daily range H  
Relative humidity 50 %  
Moisture difference 1 gr/lb

**Heating Summary**

Structure 28344 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 28344 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 48828 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Blower 0 Btuh  
  
Use manufacturer's data n  
Rate/swing multiplier 1.11  
Equipment sensible load 54200 Btuh

**Infiltration**

Method Simplified  
Construction quality Average  
Fireplaces 0

	Heating	Cooling
Area (ft²)	3992	3992
Volume (ft³)	47906	47906
Air changes/hour	0.28	0.15
Equiv. AVF (cfm)	224	120

**Latent Cooling Equipment Load Sizing**

Structure 2860 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
  
Equipment latent load 2860 Btuh  
  
**Equipment Total Load (Sen+Lat)** 57060 Btuh  
Req. total capacity at 0.70 SHR 6.5 ton

**Heating Equipment Summary**

Make n/a  
Trade n/a  
Model n/a  
AHRI ref. n/a  
  
Efficiency n/a  
Heating input  
Heating output 0 Btuh  
Temperature rise 0 °F  
Actual air flow 0 cfm  
Air flow factor 0 cfm/Btuh  
Static pressure 0 in H2O  
Space thermostat n/a

**Cooling Equipment Summary**

Make n/a  
Trade n/a  
Cond n/a  
Coil n/a  
AHRI ref. n/a  
  
Efficiency n/a  
Sensible cooling 0 Btuh  
Latent cooling 0 Btuh  
Total cooling 0 Btuh  
Actual air flow 0 cfm  
Air flow factor 0 cfm/Btuh  
Static pressure 0 in H2O  
Load sensible heat ratio 0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

**Project Information**

For: Kasraee Residence  
6804 E Gold Dus Ave, Paradise Valley, AZ 85253

Notes:

**Design Information**

Weather: Phoenix Co, AZ, US

**Winter Design Conditions**

Outside db 35 °F  
Inside db 68 °F  
Design TD 33 °F

**Summer Design Conditions**

Outside db 106 °F  
Inside db 75 °F  
Design TD 31 °F  
Daily range H  
Relative humidity 50 %  
Moisture difference 1 gr/lb

**Heating Summary**

Structure 19308 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 19308 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 33489 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Blower 0 Btuh  
Use manufacturer's data n  
Rate/swing multiplier 1.11  
Equipment sensible load 37172 Btuh

**Infiltration**

Method Simplified  
Construction quality Average  
Fireplaces 0

**Latent Cooling Equipment Load Sizing**

Structure 2239 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Equipment latent load 2239 Btuh

	Heating	Cooling
Area (ft²)	3058	3058
Volume (ft³)	36693	36693
Air changes/hour	0.24	0.13
Equiv. AVF (cfm)	145	78

**Equipment Total Load (Sen+Lat)** 39411 Btuh  
Req. total capacity at 0.70 SHR 4.4 ton

**Heating Equipment Summary**

Make Trane  
Trade TRANE  
Model 4TVH0060C1000CA  
AHRI ref 202181203  
Efficiency 9.9 HSPF  
Heating input  
Heating output 66000 Btuh @ 47°F  
Temperature rise 31 °F  
Actual air flow 2000 cfm  
Air flow factor 0.104 cfm/Btuh  
Static pressure 0.30 in H2O  
Space thermostat  
Capacity balance point = 3 °F

**Cooling Equipment Summary**

Make Trane  
Trade TRANE  
Cond 4TVH0060C1000CA  
Coil  
AHRI ref 202181203  
Efficiency 9.5 EER, 17.2 SEER  
Sensible cooling 42000 Btuh  
Latent cooling 18000 Btuh  
Total cooling 60000 Btuh  
Actual air flow 2000 cfm  
Air flow factor 0.060 cfm/Btuh  
Static pressure 0.30 in H2O  
Load sensible heat ratio 0.94

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

**Project Information**

For: Kasraee Residence  
6804 E Gold Dus Ave, Paradise Valley, AZ 85253

Notes:

**Design Information**

Weather: Phoenix Co, AZ, US

**Winter Design Conditions**

Outside db 35 °F  
Inside db 68 °F  
Design TD 33 °F

**Summer Design Conditions**

Outside db 106 °F  
Inside db 75 °F  
Design TD 31 °F  
Daily range H  
Relative humidity 50 %  
Moisture difference 1 gr/lb

**Heating Summary**

Structure 9037 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 9037 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 15340 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Blower 0 Btuh  
Use manufacturer's data n  
Rate/swing multiplier 1.11  
Equipment sensible load 17027 Btuh

**Infiltration**

Method Simplified  
Construction quality Average  
Fireplaces 0

**Latent Cooling Equipment Load Sizing**

Structure 621 Btuh  
Ducts 0 Btuh  
Central vent (0 cfm) 0 Btuh  
(none)  
Equipment latent load 621 Btuh

	Heating	Cooling
Area (ft <sup>2</sup> )	934	934
Volume (ft <sup>3</sup> )	11213	11213
Air changes/hour	0.42	0.23
Equiv. AVF (cfm)	79	42

**Equipment Total Load (Sen+Lat)** 17648 Btuh  
Req. total capacity at 0.70 SHR 2.0 ton

**Heating Equipment Summary**

Make Trane  
Trade TRANE  
Model 4TVH0060C1000CA  
AHRI ref 202181203  
Efficiency 9.9 HSPF  
Heating input  
Heating output 66000 Btuh @ 47°F  
Temperature rise 31 °F  
Actual air flow 2000 cfm  
Air flow factor 0.221 cfm/Btuh  
Static pressure 0.30 in H2O  
Space thermostat  
Capacity balance point = -13 °F

**Cooling Equipment Summary**

Make Trane  
Trade TRANE  
Cond 4TVH0060C1000CA  
Coil  
AHRI ref 202181203  
Efficiency 9.5 EER, 17.2 SEER  
Sensible cooling 42000 Btuh  
Latent cooling 18000 Btuh  
Total cooling 60000 Btuh  
Actual air flow 2000 cfm  
Air flow factor 0.130 cfm/Btuh  
Static pressure 0.30 in H2O  
Load sensible heat ratio 0.96

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.


**Project Information**

For: Kasraee Residence  
 6804 E Gold Dus Ave, Paradise Valley, AZ 85253

**Design Conditions**

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Phoenix Co, AZ, US		Indoor temperature (°F)		68	75
Elevation: 1083 ft		Design TD (°F)		33	31
Latitude: 33°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		28.1	0.8
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	35	106			
Daily range (°F)	-	26 ( H )			
Wet bulb (°F)	-	72			
Wind speed (mph)	15.0	7.5			

**Test for Adequate Exposure Diversity**



**Maximum hourly glazing load exceeds average by 17.4%.**

**House has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**


### Project Information

For: Kasraee Residence  
 6804 E Gold Dus Ave, Paradise Valley, AZ 85253

### Design Conditions

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Phoenix Co, AZ, US		Indoor temperature (°F)		68	75
Elevation: 1083 ft		Design TD (°F)		33	31
Latitude: 33°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		28.1	0.8
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	35	106			
Daily range (°F)	-	26 ( H )			
Wet bulb (°F)	-	72			
Wind speed (mph)	15.0	7.5			

### Test for Adequate Exposure Diversity



**Maximum hourly glazing load exceeds average by 24.5%.**

**Zone has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**


### Project Information

For: Kasraee Residence  
 6804 E Gold Dus Ave, Paradise Valley, AZ 85253

### Design Conditions

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Phoenix Co, AZ, US		Indoor temperature (°F)		68	75
Elevation: 1083 ft		Design TD (°F)		33	31
Latitude: 33°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		28.1	0.8
<b>Outdoor:</b>	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	35	106			
Daily range (°F)	-	26 ( H )			
Wet bulb (°F)	-	72			
Wind speed (mph)	15.0	7.5			

### Test for Adequate Exposure Diversity




**Maximum hourly glazing load exceeds average by 26.2%.**

**Zone has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**



Level 1



BCHE COMPANY

**Job #:**  
**Performed for:**  
Kasraee Residence  
6804 E Gold Dus Ave  
Paradise Valley, AZ 85253

**Scale:** 1 : 220  
Page 1  
Right-Suite® Universal 2022  
22.0.07 RSU62812  
2023-May-01 15:33:57  
...s\Kasraee Residence - Rev.03.rup



### Project Information

For: Kasraee Residence  
6804 E Gold Dus Ave, Paradise Valley, AZ 85253

	Heating	Cooling
External static pressure	0.30 in H2O	0.30 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.30 in H2O	0.30 in H2O
Supply / return available pressure	0.267 / 0.033 in H2O	0.267 / 0.033 in H2O
Lowest friction rate	0.094 in/100ft	0.094 in/100ft
Actual air flow	2000 cfm	2000 cfm
Total effective length (TEL)	319 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
B. Bedroom	c 3948	210	236	0.096	9.0	0x 0	MtFx	77.0	200.0	st21
Bath2	h 550	57	40	0.094	6.0	0x 0	MtFx	84.0	200.0	st21
Entry/Dining	c 2521	150	151	0.161	7.0	0x 0	MtFx	31.0	135.0	st13
Entry/Dining-A	c 2521	150	151	0.134	7.0	0x 0	MtFx	50.0	150.0	st15
Entry/Dining-B	c 2521	150	151	0.184	7.0	0x 0	MtFx	25.5	120.0	st12
G. bath	h 479	50	46	0.112	5.0	0x 0	MtFx	59.5	180.0	st17
G. bedroom	c 3712	219	222	0.101	9.0	0x 0	MtFx	74.5	190.0	st17
Great Room	h 1949	202	201	0.162	8.0	0x 0	MtFx	30.5	135.0	st13
Great Room-A	h 1949	202	201	0.134	8.0	0x 0	MtFx	49.0	150.0	st15
Guest BR	c 3905	233	233	0.199	9.0	0x 0	MtFx	19.5	115.0	st24
Guest Bath	h 386	40	27	0.195	4.0	0x 0	MtFx	22.0	115.0	st24
Toilet	h 170	18	10	0.250	4.0	0x 0	MtFx	7.0	100.0	st23
kitchen-A	c 2775	160	166	0.181	8.0	0x 0	MtFx	17.5	130.0	st3
kitchen-B	c 2775	160	166	0.211	8.0	0x 0	MtFx	21.5	105.0	st12

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st16	Peak AVF	535	544	0.094	509	14.0	0 x 0	MetlFlx	st15
st17	Peak AVF	269	268	0.101	493	10.0	0 x 0	MetlFlx	st16
st2	Peak AVF	1549	1564	0.094	592	22.0	0 x 0	MetlFlx	
st13	Peak AVF	1239	1248	0.094	572	20.0	0 x 0	MetlFlx	st12
st19	Peak AVF	267	276	0.094	506	10.0	0 x 0	MetlFlx	st16
st12	Peak AVF	1549	1564	0.094	592	22.0	0 x 0	MetlFlx	st11
st11	Peak AVF	1549	1564	0.094	592	22.0	0 x 0	MetlFlx	st2
st21	Peak AVF	267	276	0.094	506	10.0	0 x 0	MetlFlx	st20
st20	Peak AVF	267	276	0.094	506	10.0	0 x 0	MetlFlx	st19
st23	Peak AVF	291	270	0.195	533	10.0	0 x 0	MetlFlx	st3
st24	Peak AVF	273	260	0.195	500	10.0	0 x 0	MetlFlx	st23
st3	Peak AVF	451	436	0.181	574	12.0	0 x 0	MetlFlx	
st15	Peak AVF	887	896	0.094	507	18.0	0 x 0	MetlFlx	st13

## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	0x 0	2000	2000	34.7	0.094	542	26.0	0x 0		MtFx	

BCE COMPANY

### Project Information

For: Kasraee Residence  
6804 E Gold Dus Ave, Paradise Valley, AZ 85253

	Heating	Cooling
External static pressure	0.30 in H2O	0.30 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.30 in H2O	0.30 in H2O
Supply / return available pressure	0.241 / 0.059 in H2O	0.241 / 0.059 in H2O
Lowest friction rate	0.140 in/100ft	0.140 in/100ft
Actual air flow	2000 cfm	2000 cfm
Total effective length (TEL)	214 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Activity RM	h 2109	467	434	0.147	12.0	0x 0	MtFx	38.9	125.0	st9
M. Bath	h 679	150	105	0.183	7.0	0x 0	MtFx	16.8	115.0	st5
M. Bedroom	c 3479	430	454	0.185	12.0	0x 0	MtFx	9.9	120.0	st10
M. Bedroom-A	c 3479	430	454	0.234	12.0	0x 0	MtFx	17.8	85.0	st10
M. Closet	h 1416	314	298	0.140	10.0	0x 0	MtFx	29.6	142.0	st5
Office	c 1961	210	256	0.225	9.0	0x 0	MtFx	7.1	100.0	st4

### Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	2000	2000	0.140	542	26.0	0 x 0	MetlFlx	
st4	Peak AVF	1140	1093	0.140	523	20.0	0 x 0	MetlFlx	st1
st10	Peak AVF	860	907	0.185	513	18.0	0 x 0	MetlFlx	st1
st5	Peak AVF	931	837	0.140	527	18.0	0 x 0	MetlFlx	st4
st9	Peak AVF	467	434	0.147	594	12.0	0 x 0	MetlFlx	st5

### Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb6	0x 0	2000	2000	42.2	0.140	542	26.0	0x 0		MtFx	