

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024



Site: JasonTurnbull

Location: ONSITE				
Asset ID: TZ041547	Description: Circular Saw	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041548	Description: Circular Saw	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041549	Description: Sander	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041550	Description: Circular Saw	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041551	Description: Hammer Drill	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041552	Description: Extension Lead	User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:				

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.48	ohm	Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	28/09/2024			Pass
				Overall: Pass

Asset ID: TZ041553	Description: Extension Lead		User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.31	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
					Overall: Pass

Asset ID: TZ041554	Description: Extension Lead		User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.49	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
					Overall: Pass

Asset ID: TZ041555	Description: Extension Lead		User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.47	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
					Overall: Pass

Asset ID: TZ041556	Description: Extension Lead		User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.53	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
					Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Asset ID: TZ041557	Description: Extension Lead		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.91	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
					Overall: Pass

Asset ID: TZ041558	Description: Extension Lead		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.25	ohm	Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	28/09/2024			Pass
				Overall: Pass

Asset ID: TZ041559	Description: Extension Lead		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
IEC Lead Continuity	28/09/2024	0.49	ohm	Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
IEC Lead Polarity	28/09/2024			Pass	
				Overall: Pass	

Asset ID: TZ041560	Description: Powerboard RCD		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.12	ohm	Pass
IEC Lead Continuity	28/09/2024	0.11	ohm	Pass
Live Voltage	28/09/2024	239.6	V	Information
Load Current	28/09/2024	0.136	A	Information
PE Conductor Current	28/09/2024	0.03	mA	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
RCD Trip Time Angle (Portable)	28/09/2024	0	degrees	Information
RCD Trip Time (Portable)	28/09/2024	117	ms	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
				Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

RCD Trip Time Angle (Portable)	28/09/2024	180	degrees	Information
RCD Trip Time (Portable)	28/09/2024	117	ms	Pass
				Overall: Pass

Asset ID: TZ041561	Description: Powerboard RCD		User: TYLER	Test Instrument: SeawardPrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.13	ohm	Pass
IEC Lead Continuity	28/09/2024	0.11	ohm	Pass
Live Voltage	28/09/2024	231.9	V	Information
Load Current	28/09/2024	0.141	A	Information
PE Conductor Current	28/09/2024	0.03	mA	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
RCD Trip Time Angle (Portable)	28/09/2024	0	degrees	Information
RCD Trip Time (Portable)	28/09/2024	27	ms	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
RCD Trip Time Angle (Portable)	28/09/2024	180	degrees	Information
RCD Trip Time (Portable)	28/09/2024	37	ms	Pass
				Overall: Pass

Asset ID: TZ041562	Description: Drop Saw		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
					Overall: Pass

Asset ID: TZ041563	Description: Drop Saw		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
					Overall: Pass

Asset ID: TZ041564	Description: Drop Saw		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
				Overall: Pass	

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: TZ041565	Description: Vacuum Cleaner	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041566	Description: Compressor		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
				Overall: Pass	

Asset ID: TZ041567	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041568	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041569	Description: Battery Charger		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
				Overall: Pass	

Asset ID: TZ041570	Description: Battery Charger	User: TYLER	TestInstrument: SeawardPrimeTest Elite 06L-0279
Comments:			

Detailed Latest Test Results



Page 6
Monday, 7. October 2024 17:23

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: TZ041571		Description: Battery Charger		User: TYLER		Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:							
Test Type		Date	Result		Unit	Status	
Plugs		28/09/2024				Pass	
Flexible cord		28/09/2024				Pass	
Cover / Guards		28/09/2024				Pass	
Insulation Resistance		28/09/2024	> 19.99		MOhm	Pass	
							Overall: Pass

Asset ID: TZ041572	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041573	Description: Battery Charger		User: TYLER	TestInstrument: SeawardPrimeTest Elite 06L-0279	
Comments:					
Test Type	Date	Result	Unit	Status	
Plugs	28/09/2024			Pass	
Flexible cord	28/09/2024			Pass	
Cover / Guards	28/09/2024			Pass	
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass	
				Overall: Pass	

Asset ID: TZ041574	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041575	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Asset ID: TZ041576	Description: Battery Charger	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041577	Description: Battery Charger		User: TYLER	TestInstrument: SeawardPrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041578	Description: Battery Charger		User: TYLER	TestInstrument: SeawardPrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041579	Description: Light	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041580	Description: Powerboard	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041581	Description: Powerboard	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
				Overall: Pass

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041582	Description: Powerboard RCD		User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.11	ohm	Pass
IEC Lead Continuity	28/09/2024	0.12	ohm	Pass
Live Voltage	28/09/2024	238.5	V	Information
Load Current	28/09/2024	0.144	A	Information
PE Conductor Current	28/09/2024	0.03	mA	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
RCD Trip Time Angle (Portable)	28/09/2024	0	degrees	Information
RCD Trip Time (Portable)	28/09/2024	9	ms	Pass
RCD Trip Time Current (Portable)	28/09/2024	30	mA	Information
RCD Trip Time Angle (Portable)	28/09/2024	180	degrees	Information
RCD Trip Time (Portable)	28/09/2024	18	ms	Pass
				Overall: Pass

Asset ID: TZ041583	Description: Extension Lead	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.3	ohm	Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	28/09/2024			Pass
				Overall: Pass

Asset ID: TZ041584	Description: Extension Lead	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
IEC Lead Continuity	28/09/2024	0.41	ohm	Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
IEC Lead Polarity	28/09/2024			Pass
				Overall: Pass

Asset ID: TZ041585	Description: Microwave	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279
Comments:			

Detailed Latest Test Results



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 28/09/2024 To: 28/09/2024

Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
Insulation Resistance	28/09/2024	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: TZ041586	Description: Generator	User: TYLER	Test Instrument: Seaward PrimeTest Elite 06L-0279	
Comments:				
Test Type	Date	Result	Unit	Status
Plugs	28/09/2024			Pass
Flexible cord	28/09/2024			Pass
Cover / Guards	28/09/2024			Pass
				Overall: Pass

Total Tests: 40