


## PORTABLE APPLIANCE TESTING CERTIFICATE

 <b>Odyssey</b> Electrical Services	4 Macie Drive Corsham Wiltshire SN13 9EJ  Mobile: 07800 844349	<b>REPORT NO.:</b>	<b>25/12 - 87</b>	Pipe Dream
		<b>DATE:</b>	<b>10/12/2025</b>	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST			Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION	LEAKAGE				
					Ohms	Mohms	mAmps				
1	Yamaha MG16XUMixing Desk	Band Equipment	1	Good	0.14	19.99	0.14	Good	10/12/2026	PASS	
2	Kettle Lead 1	Band Equipment	1	Good	0.10	19.99	0.11	Good	10/12/2026	PASS	
3	RCF Evox J8 Speaker 1	Band Equipment	1	Good	0.12	19.99	0.12	Good	10/12/2026	PASS	
4	Kettle Lead 2	Band Equipment	1	Good	0.07	19.99	0.11	Good	10/12/2026	PASS	
5	RCF Evox J8 Speaker 2	Band Equipment	1	Good	0.10	19.99	0.08	Good	10/12/2026	PASS	
6	Kettle Lead 3	Band Equipment	1	Good	0.09	19.99	0.13	Good	10/12/2026	PASS	
7	Equinox Microbar Multi System 1	Band Equipment	1	Good	0.09	19.99	0.12	Good	10/12/2026	PASS	
8	Kettle Lead 4	Band Equipment	1	Good	0.11	19.99	0.11	Good	10/12/2026	PASS	
9	Equinox Microbar Multi System 2	Band Equipment	1	Good	0.08	19.99	0.12	Good	10/12/2026	PASS	
10	Kettle Lead 5	Band Equipment	1	Good	0.10	19.99	0.12	Good	10/12/2026	PASS	
11	LED 500 Fogger	Band Equipment	1	Good	0.13	19.99	0.12	Good	10/12/2026	PASS	
12	Kettle Lead 6	Band Equipment	1	Good	0.15	19.99	0.1	Good	10/12/2026	PASS	
13	Beams Spotlight	Band Equipment	1	Good	0.17	19.99	0.16	Good	10/12/2026	PASS	
14	Kettle Lead 7	Band Equipment	1	Good	0.20	19.99	0.12	Good	10/12/2026	PASS	
15	SoundCraft UI-24 Digital Mixing Desk	Band Equipment	1	Good	0.09	19.99	0.09	Good	10/12/2026	PASS	
16	Kettle Lead 8	Band Equipment	1	Good	0.10	19.99	0.09	Good	10/12/2026	PASS	
17	Mackie SR1530 Active Speaker 1	Band Equipment	1	Good	0.13	19.99	0.14	Good	10/12/2026	PASS	
18	Kettle Lead 9	Band Equipment	1	Good	0.17	19.99	0.12	Good	10/12/2026	PASS	
19	Mackie SR1530 Active Speaker 2	Band Equipment	1	Good	0.09	19.99	0.12	Good	10/12/2026	PASS	
20	Kettle Lead 10	Band Equipment	1	Good	0.11	19.99	0.14	Good	10/12/2026	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST			Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION	LEAKAGE				
					Ohms	Mohms	mAmps				
21	Laney CXP-112 Foldback Speaker 1	Band Equipment	1	Good	0.10	19.99	0.17	Good	10/12/2026	PASS	
22	Kettle Lead 11	Band Equipment	1	Good	0.15	19.99	0.14	Good	10/12/2026	PASS	
23	ABM 600	Band Equipment	1	Good	0.19	19.99	0.17	Good	10/12/2026	PASS	
24	Kettle Lead 12	Band Equipment	1	Good	0.10	19.99	0.13	Good	10/12/2026	PASS	
25	Studio 15 Amplifier	Band Equipment	1	Good	0.11	19.99	0.11	Good	10/12/2026	PASS	
26	Kettle Lead 13	Band Equipment	1	Good	0.12	19.99	0.19	Good	10/12/2026	PASS	
27	Vox Amplifier	Band Equipment	1	Good	0.09	19.99	0.11	Good	10/12/2026	PASS	
28	Kettle Lead 14	Band Equipment	1	Good	0.10	19.99	0.17	Good	10/12/2026	PASS	
29	Extension Lead 1	Band Equipment	1	Good	0.18	19.99	0.17	Good	10/12/2026	PASS	
30	Extension Lead 2	Band Equipment	1	Good	0.10	19.99	0.11	Good	10/12/2026	PASS	
31	Extension Lead 3	Band Equipment	1	Good	0.11	19.99	0.16	Good	10/12/2026	PASS	
32	RCD Extension Lead 1	Band Equipment	1	Good	0.09	19.99	0.11	Good	10/12/2026	PASS	
33	Kettle Splitter Lead 1	Band Equipment	1	Good	0.11	19.99	0.13	Good	10/12/2026	PASS	
34	Twin Split Kettle Lead	Band Equipment	1	Good	0.07	19.99	0.13	Good	10/12/2026	PASS	
35	Long Kettle Lead	Band Equipment	1	Good	0.16	19.99	0.16	Good	10/12/2026	PASS	
36	Extension Reel 1	Band Equipment	1	Good	0.09	19.99	0.19	Good	10/12/2026	PASS	
37	SHEHDS Light Bar 1	Band Equipment	1	Good	0.11	19.99	0.14	Good	10/12/2026	PASS	
38	SHEHDS Light Bar 2	Band Equipment	1	Good	0.09	19.99	0.16	Good	10/12/2026	PASS	
<b>TOTAL APPLIANCES: 38</b>											



