

**Mission:**

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



**Ron DeSantis**  
Governor

**Scott A. Rivkees, MD**  
State Surgeon General

**Vision:** To be the **Healthiest State** in the Nation

**Greater Pine Island Water Association, PWS #: 5360322**

**2020 DRINKING WATER MONITORING REQUIREMENTS**

<b>MONITORING &amp; REPORTS</b>	<b>DUE</b>	<b>COMMENTS</b>
Microbiological ("Bacte")	Monthly	Disinfectant residuals must be reported individually and averaged on bacte reports.
Disinfectant Residuals Report	Quarterly	Compliance for maximum disinfectant residual level is based on a running annual average.
Monthly Operation Reports (MORs)	Monthly	Include information about maintenance and/or abnormal occurrences & CT calcs. (if required)
Nitrate and Nitrite	2020	Sample at each POE* every year.
Primary Inorganics	2020	Sample at each POE every 3 years.
Secondaries	2020	Sample at each POE every 3 years.
Radiologicals ( <i>Gross Alpha &amp; Radium 226/228</i> )	2020	Sample at each POE every 6 years. (New 9-year cycle begins 2020)
Volatile Organic Contaminants (VOCs)	2020	Sample at each POE every 3 years.
Synthetic Organic Contaminants (SOCs)	2 Quarters 2020	Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.
Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports <i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i>	Annual	System is on <u>reduced</u> (annual) testing at 2 sites for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with Stage 2 D/DBP Monitoring Plan.
Asbestos	2020	Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.
Lead and Copper (Tap Sampling)	June-Sept. 2022	Test in accordance with the most recently approved sampling plan.
Consumer Confidence Report (CCR) & CCR Certification of Delivery	July 1, 2020 & August 10, 2020	The CCR template can be obtained at: <a href="http://www.frwa.net/CCR/CCR%20Main%20Page.htm">http://www.frwa.net/CCR/CCR%20Main%20Page.htm</a>
Finish Water Tank Inspections	On Site 2024 Central 2024 Scallop 2024	All tank inspections must be done every 5 years.

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

**Florida Department of Health**

**In Lee County** • Environmental Engineering  
60 South Danley Drive, Unit 1, Fort Myers, FL 33907  
PHONE: 239/274-2200 FAX: 239/274-2201  
<http://lee.floridahealth.gov/>



**Accredited Health Department**  
Public Health Accreditation Board

