

**Mission:**

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



**Ron DeSantis**  
Governor

**Scott A. Rivkees, MD**  
State Surgeon General

**Vision:** To be the **Healthiest State** in the Nation

## Greater Pine Island Water Association, PWS #: 5360322

### 2021 DRINKING WATER MONITORING REQUIREMENTS

| MONITORING & REPORTS   | DUE  | COMMENTS   |
|--|--|--|
| Microbiological (“Bacte”)  | Monthly                                      | Disinfectant residuals must be reported individually and averaged on bacte reports.  |
| Disinfectant Residuals Report  | Quarterly                                    | Compliance for maximum disinfectant residual level is based on a running annual average.   |
| Monthly Operation Reports (MORs)   | Monthly                                      | Include information about maintenance and/or abnormal occurrences & CT calcs. (if required)  |
| Nitrate and Nitrite  | 2021   | Sample at each POE* every year.  |
| Primary Inorganics   | 2023   | Sample at each POE every 3 years.  |
| Secondaries  | 2023   | Sample at each POE every 3 years.  |
| Radiologicals ( <i>Gross Alpha &amp; Radium 226/228</i> )  | 2026   | Sample at each POE every 6 years.  |
| Volatile Organic Contaminants (VOCs)   | 2023   | Sample at each POE every 3 years.  |
| Synthetic Organic Contaminants (SOCs)  | 2 Quarters 2023                              | Sample at each POE for 2 quarters every 3 years; samples shall be taken at least 60 days apart.  |
| Stage 2 Disinfection Byproducts (DBPs) and Disinfection Byproduct Reports<br><i>Total Trihalomethanes &amp; Haloacetic Acids (5)</i> | Annual                                       | System is on <u>reduced</u> (annual) testing at 2 sites for both T/H (dual samples). Report disinfectant residuals. Sample in accordance with Stage 2 D/DBP Monitoring Plan. |
| Asbestos   | 2029   | Certification or results due every 9 years. Use Form 62-555.900(10), F.A.C., Asbestos Free Certification or Asbestos Sampling Plan.  |
| Lead and Copper (Tap Sampling)   | June-Sept. 2022                              | Test in accordance with the most recently approved sampling plan.  |
| Consumer Confidence Report (CCR) & CCR Certification of Delivery   | July 1, 2021 & August 10, 2021               | The CCR template can be obtained at: <a href="http://www.frwa.net/CCR/CCR%20Main%20Page.htm">http://www.frwa.net/CCR/CCR%20Main%20Page.htm</a>                               |
| Finish Water Tank Inspections  | On Site 2024<br>Central 2024<br>Scallop 2024 | All tank inspections must be done every 5 years.   |

\*POE = Point of entry to the distribution system. Sample at each POE that is representative of each source after treatment.

