

VCMR

394 Bennetts Farm Road
Ridgefield, Connecticut
Tel 475 619 1239
colin@vcmr.me
www.vcmr.me



Vibration Amplitudes for Machines		inch/sec 0-PK	mm/s RMS	inch/sec 0-PK	mm/s RMS	inch/sec 0-PK	mm/s RMS
Machine Type	Setup Type	Acceptance Testing Amplitude	Acceptance Testing Amplitude	Running Warning Amplitude	Running Warning Amplitude	Running Alarm Amplitude	Running Alarm Amplitude
Fans & Blowers	Integral Shaft	0.080	1.440	0.180	3.300	0.270	4.850
	Coupling Driven	0.100	1.800	0.250	4.500	0.325	5.850
	Belt Driven	0.110	2.000	0.275	6.700	0.370	6.650
Cooling Tower Drives	Long Shaft	0.150	2.700	0.250	4.500	0.500	9.000
	Close Coupled	0.090	1.600	0.200	3.600	0.300	5.400
	Belt Driven	0.120	2.200	0.250	4.500	0.400	7.200
Chiller Units	Coupling Driven	0.090	1.600	0.200	3.600	0.300	5.400
		0.120	2.200	0.250	4.500	0.400	7.200
Compressors	Reciprocating	0.135	2.450	0.280	5.000	0.450	8.000
	Screw type	0.117	2.100	0.240	4.300	0.390	7.000
	Centrifugal	0.090	1.600	0.200	3.600	0.300	5.400
Centrifugal Pumps	Integral Shaft	0.078	1.400	0.130	2.400	0.260	4.700
	Coupling Driven	0.087	1.600	0.150	2.700	0.290	5.200
	Belt Driven	0.090	1.610	0.175	3.200	0.300	5.400

VCMR Bank Details:

Sort Code: 221172241

Account Number: 591004643

Helping keep your rotating world running smoothly.