

Property Report

February 2026

Projects completed by Committee Members

Approved monthly bills to be paid by Finance

Called Peters Hvac to reinstall baffle for boiler exhaust that had fallen off

Painted Fellowship hall on 2/7 and 2/8

Co2 detectors installed

Meeting with peters and boiler rep. (boiler rep. says boiler is working properly burner needs to be cleaned at end of season)

Projects completed by contractors

Peters HVAC installed new baffle on exhaust for boiler

Peters reinstalled baffle on boiler because it fell off

Coady window cleaning cleaned narthex, office & library windows

Inspector inspected boiler for insurance

Peco red tagged gas line at boiler

Peters fixed leaking gas line at boiler

Peters fixed office heat pump and boiler damper 2 times