



WEST COAST CHILLERS

INSPECTION & TEST RUN REPORT

CHILLER INFORMATION

MODEL #: YLAA0135ZE46XBASXTXHXXBLXCXX44XX1XXXHXXXXAXXXX7BBXLXXB1XXXX

TYPE: AIR COOLED

BRAND: YORK

VOLTS/HZ/PH: 460/60/3

S/N: 2LXMO13922

CHILLER DIMENSIONS: L 15.5' x W 7.3' x H 7.9'

MAN. DATE: 2011

CHILLER WEIGHT: 8,205 LBS

CHILLER OPERATING DATA

TEST RUN DATE: 1/24/2024

VOLTS L1/L2: **L1/L3:** **L2/L3:**

AMPS L1: **L2:** **L3:**

ID		COMPRESSOR MAKE/ MODEL		RUNNING AMPS		OIL LEVEL		HOURS		CCH AMPS	
C1	C2	CIRCUIT 1	CIRCUIT 2	C1	C2	C1	C2	C1	C2	C1	C2
1	1	COPELAND ZP385KCE-TED-951	COPELAND ZP385KCE-TED-951	31	32	7/8	7/8	12,505	12,490		
				32	33						
				32	35						
2	2	COPELAND ZP385KCE-TED-951	COPELAND	33.5	14.8	7/8	7/8	12,316	11,986		
				35	15.2						
				34	14.4						
3		COPELAND ZP385KCE-TED-951		34.8		7/8		12,236			
				35.8							
				34.5							

REFRIGERANT TYPE: ☒ R410A ☐ R407C ☐ R717 ☐ R134A ☐ R22 ☐ R404A

REFRIGERANT LEVEL: GOOD

AMBIENT TEMP: 32 F

PUMP 1 HP/AMPS: 25 / 30.4, 30.8, 30.1

SETPOINT: 10 F

PUMP 2 HP/AMPS: 25 / NOT ONLINE

LEAVING CHILLER: 11.4 F

FLOW SWITCH: WORKING, MECHANICAL

ENTER/ RETURN: 15.2 F

HEAT EXCHANGER: SHELL & TUBE

MINIMUM SETPOINT: 8.5 F

METERING DEVICE: TXV




CONDENSER FANS

CONDENSER FIN: ☐ EXCELLENT ☒ GOOD ☐ OK

ANY CORROSION PRESENT: ☐ YES ☒ NO

NUMBER OF FANS: 8



CONDENSOR FAN RUNNING AMPS	
CIRCUIT 1	CIRCUIT 2
1.) 2.59	1.) 2.68
2.) 2.5	2.) 2.53
3.) 2.60	3.) 2.83
4.) 2.67	4.) 2.68

INSPECTION NOTES:

SYSTEM 1 - NEW COMPRESSORS (1, 2, & 3) INSTALLED 9/2022 @ 11,000 HRS

TOTAL AMPERAGE IS 190

DIMENSION OF CHILLER WITH TRAILER L 26.5' x W 8.5' x H 10.3'