

Verification Certificate

This is to certify that:

Ceasefire Industries Private Ltd
E-6 Selaqui Industrial Area
Dehradun
Uttarakhand
248011
India

Holds Certificate Number:

VC 752763

In respect of:

Ceasefire's Mini – Automatic Fire Suppression System for Small Confined Cabinets using Quartzoid Bulb Detection as Detailed in Technical File CF/TF/BSI-UK/MINI-FK/CA-01, Revision 0, Dated 04/02/2022



For and on behalf of BSI:

Shahn Barhom, Group Product Certification Director

First Issued: 2023-01-03

Latest Issue: 2023-01-03

Effective Date: 2023-01-03

Expiry Date: 2026-01-02

Page: 1 of 3

Verification Certificate

No. VC 752763

| Description | Model No. |
|--|---|
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -100 gm SS SP using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001339A CF-001339B CF-001339C |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -200 gm SS SP Red using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001341A CF-001341B CF-001341C |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -300 gm SS SP Red using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001343A CF-001343B CF-001343C |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -400 gm SS SP Red using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001345A CF-001345B CF-001345C |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -500 gm SS SP Red using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001347A CF-001347B CF-001347C |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -100 gm SS SP Red with 50mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001340AA CF-001340BA CF-001340CA |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -100 gm SS SP Red with 100mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001340AB CF-001340BB CF-001340CB |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -100 gm SS SP Red with 200mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001340AC CF-001340BC CF-001340CC |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -200 gm SS SP Red with 50mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001342AA CF-001342BA CF-001342CA |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -200 gm SS SP Red with 100mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001342AB CF-001342BB CF-001342CB |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -200 gm SS SP Red with 200mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001342AC CF-001342BC CF-001342CC |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -300 gm SS SP Red with 50mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001344AA CF-001344BA CF-001344CA |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -300 gm SS SP Red with 100mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001344AB CF-001344BB CF-001344CB |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -300 gm SS SP Red with 200mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001344AC CF-001344BC CF-001344CC |

First Issued: 2023-01-03

Latest Issue: 2023-01-03

Effective Date: 2023-01-03

Expiry Date: 2026-01-02

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Verification Certificate

No. VC 752763

| | |
|--|---|
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -400 gm SS SP Red with 50mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001346AA CF-001346BA CF-001346CA |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -400 gm SS SP Red with 100mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001346AB CF-001346BB CF-001346CB |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -400 gm SS SP Red with 200mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001346AC CF-001346BC CF-001346CC |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -500 gm SS SP Red with 50mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001348AA CF-001348BA CF-001348CA |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -500 gm SS SP Red with 100mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001348AB CF-001348BB CF-001348CB |
| Mini Intuitive 57°C/68°C/93°C Automatic Fire Ext. FK-5-1-12 -500 gm SS SP Red with 200mm barrel using quartzoid bulb detection for the suppression of small confined cabinets. | CF-001348AC CF-001348BC CF-001348CC |

Additional information can be found in Product Handbooks:

Handbook of design, installation, operation and system maintenance of CEASEFIRE – MINI-FK-5-1-12 Document Number CF/CA-MINI/MAN/002 Revision 0 dated 10/09/2021

First Issued: 2023-01-03

Latest Issue: 2023-01-03

Effective Date: 2023-01-03

Expiry Date: 2026-01-02

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.