

PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Millville Municipal Water Authority

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2024-2025 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
IOCs x 12	Triennially	0	2024	May 6, 2025 Resampled May 13, 2025
PFOA/PFOS	Quarterly	0	2nd Quarter 2024	3 rd Quarter 2024 1 st Quarter 2025 2 nd Quarter 2025
RADs	Nine Years	0	3rd Quarter 2024	May 6, 2025 Resampled May 13, 2025
Turbidity	Daily	0	4/2024, 5/2024, 7/2024, 12/2024 through 04/06/2025	April 7, 2025
Total Coliform	Monthly	0	6/2024, 8/2024, & 2/2025	March 2025
Chlorine	During Coliform Sampling and Weekly in Distribution	0	December 2024 through March 2025	March 14, 2025
Chlorine	Daily at Entry Point	0	December 2024 through 03/04/2025	March 5, 2025
Giardia Log Inactivation	Daily	0	1/2024, 6/2024, 7/2024, 12/2024-04/06/2025	April 7, 2025

What happened? What was done? When will it be resolved?

IOCs, PFOA/PFOS, RADs and Total Coliform were not sampled for on time as noted above. We have or will sample by end of May 2025 as indicated. We had monitored Turbidity, Chlorine, and Giardia Inactivation as required



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

however, the data was lost, and we are unable to report to DEP as required. The data issue has been resolved and we are now reporting to DEP.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Millville Borough at (570) 458-5709.

Certified by:

Signature: Beverly Lutcavage Date: 05/14/2025

Print Name and Title: Beverly Lutcavage, Borough Manager

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: website, postal mail

PWS ID#: 4190017

Date distributed: 05/15/2025