


Kiosk C - Thermal Inspection Part 1 Cladding and Non Insulated Bulkhead 28.4.2023



Kiosk C – Thermal Inspection
Before Zefyr Remedial Works
and No Insulated Bulkhead
Removed

1. Bulkhead removed due missing firestop and Insulation
2. Others do not Install Weatherproof Barrier as per own design/drawings

Testing Device Camera - Flir Lepton 3.5 Professional


Test will be repeat after Others and A1 complete Work

MEASUREMENTS

Spot 1	Average	26.8 °C
Spot 2	Average	12.5 °C
Spot 3	Average	24.6 °C

INFORMATION

Filename	Hot Air Leaks Via Cladding Gaps
Date	4/28/23 10:38
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	26.9 °C
Min	11.1 °C




MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Hot Air Leaks Via Cladding Gaps
Date	4/28/23 10:34
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	28.1 °C
Min	12.5 °C





MEASUREMENTS

Spot 1	Average	24.1 °C
Spot 2	Average	22.8 °C
Spot 3	Average	17.6 °C

INFORMATION

Filename	Hot Air Leaks Via Cladding Gaps
Date	4/28/23 10:31
Latitude	51.61753
Longitude	-3.94292
Palette	Rainbow
Emissivity	Matte
Max	24.6 °C
Min	13.1 °C




MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Non Insulated Cladding / Bulkhead
Date	4/28/23 10:44
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	27.2 °C
Min	14.9 °C




MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Hot Air Leaks Via Cladding Gaps
Date	4/28/23 10:38
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	24.9 °C
Min	20.5 °C




MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Non Insulated Cladding / Bulkhead
Date	4/28/23 10:44
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	28.2 °C
Min	15.2 °C




MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Non Insulated Cladding / Bulkhead
Date	4/28/23 10:38
Latitude	51.61749
Longitude	-3.94285
Palette	Rainbow
Emissivity	Matte
Max	26.3 °C
Min	3.1 °C



MEASUREMENTS

No measurements enabled

INFORMATION

Filename	Non Insulated Cladding / Bulkhead
Date	4/28/23 10:31
Latitude	51.61753
Longitude	-3.94288
Palette	Rainbow
Emissivity	Matte
Max	24.2 °C
Min	9.8 °C

