



Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Aboveground Fire Protection Systems

Model XGQT16 Grooved End Cap Model XGQT03 90 Degree Grooved Elbow Model XGQT11 Grooved Concentric Reducer Model XGQT05 22.5 Degree Grooved Elbow	Model XGQT09 Grooved Equal Cross Model XGQT04 45 Degree Grooved Elbow Model XGQT11S Threaded Concentric Reducer Model XGQT06 11.25 Degree Grooved Elbow	Model XGQT07 Equal Tee Model XGQT08S Threaded Reducing Tee Model XGQT10S Threaded Reducing Cross Model XGQT10 Grooved Reducing Cross	Model XGQT08 Grooved Reducing Tee Model XGQT08S Threaded Reducing Tee Model XGQT10S Threaded Reducing Cross Model XGQT10 Grooved Reducing Cross
---	--	---	--

Prepared for:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

Manufactured at:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

FM Approvals Class: 1920 - "Pipe Couplings and Fittings for Aboveground Fire Protection Systems"

Approval Identification: 3054543

Approval Granted: July 16, 2015

Approval Reissued: August 28, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
AVP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

Certificate Number 20180621-EX27485
Report Reference EX27485-20180620
Issue Date 2018-JUNE-21

Issued to: HEBEI JIANZHI CASTING GROUP LTD
Pangzhuangzi
Southeast Of Yutian County
Tangshan
Hebei 064000 CHINA

This is to certify that FITTINGS, RUBBER GASKETED
representative samples of See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 213, Rubber Gasketed Fittings for Fire-Protection
Service.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180621-EX27485
Report Reference EX27485-20180620
Issue Date 2018-JUNE-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Rubber Gasketed fittings Models as following table listed for use with cut, rolled or grooved steel pipe. The sizes, pipe schedules, groove types and rated working pressure are as follows:

Rigid Coupling (for use with grooved end pipe or this manufacturer's grooved end fittings)

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT01	Cut, Rolled	GB/T3091	1, 1-1/2, 2, 3OD, 3, 4, , 5-1/2OD, , 6-1/2OD, 6,	300
XGQT01	Cut, Rolled	GB/T21835	4-1/4OD, 5-1/4OD, 6-1/4OD, 8, 10, 12,	300

Split Flange (for use with grooved end pipe or this manufacturer's grooved end fittings)

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT14	Cut, Rolled	GB/T3091	3OD, 3, 4, 5-1/2OD, 6-1/2OD,	225
XGQT14	Cut, Rolled	GB/T21835	4-1/4OD, 5-1/4OD, 6-1/4OD, 8	225

(Side outlet) Mechanical Tee

Model	Outlet Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT15	Grooved	GB/T 3091	4 × 1, 1-1/2, 2, 3OD 5-1/2OD × 3OD, 3 6-1/2OD × 2, 3OD, 3, 4	300
XGQT15	Grooved	GB/T21835	8 × 2, 3OD, 3, 4	300
XGQT15S	Threaded	GB/T 3091	3OD × 1, 1-1/4, 1-1/2 3 × 1, 1-1/4, 1-1/2, 2 4 × 1, 1-1/4, 1-1/2, 2, 3OD, 3 5-1/2OD × 1, 1-1/4, 1-1/2, 2, 3OD 6-1/2OD × 1, 1-1/4, 1-1/2, 2, 3OD, 3, 4	300
XGQT15S	Threaded	GB/T21835	4-1/4OD × 1, 1-1/4, 1-1/2, 2, 3OD; 6-1/4OD × 1, 1-1/4, 1-1/2, 2, 3OD, 3 8 × 1, 1-1/4, 1-1/2, 2, 3OD, 3	300

Notes:

GB/T3091 refers to steel pipe manufactured in accordance with GB/T3091.

GB/T21835 refers to steel pipe manufactured in accordance with GB/T21835.

B. Mahlen

Bruce Mahlenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Use with Aboveground Fire Protection Systems

Model 90
Malleable Iron 90° Elbow

Model 90R
Malleable Iron 90° Reducing Elbow

Model 130
Malleable Iron Equal Tee

Model 130R
Malleable Iron Reducing Tee

Model 180
Malleable Iron Equal Cross

Model 180R
Malleable Iron Reducing Cross

Prepared for:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

Manufactured at:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”

Approval Identification: 3058846

Approval Granted: May 5, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
AVP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Use with Aboveground Fire Protection Systems

Model 291
Malleable Iron Plug

Model 241
Malleable Iron Bushing

Model 280
Malleable Iron Pipe Nipple

Model 270
Malleable Iron Straight Coupling

Model 240
Malleable Iron Concentric Reducer

Prepared for:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

Manufactured at:

Hebei Jianzhi Casting Group Co Ltd
Pang Zhuang Zi
Southeast of Yutian County
Tangshan City, Hebei Province 064100
China

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”

Approval Identification: 3058846

Approval Granted: May 5, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
AVP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group

Certificate of Compliance

Certificate Number **20080521-EX15298**
Report Reference **EX15298, 2008 April 2**
Issue Date **2008 May 21**

Page 1 of 2



Issued to: Hebei Jianzhi Casting Group Ltd

Pangzhuangzi
South East of Yutian County
Tangshan, Hebei 064000
China

*This is to certify that
representative samples of*

Tee, Elbow 90°, Socket & Nipple

In sizes from 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 and 4 inches at a rated pressure of 363 psig (25 Kg/cm²). Please see addendum on Page 2 of 2.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:


Standard Specification for Metallic Cast Iron Fittings (threaded to ISO 7-1) ISO 49, Second Edition, 1994 for Water Service.

Additional Information:

Intended for use in water supply piping systems and fire suppression system piping in accordance with National Fire Protection Association Standards.

These products have not been investigated for use in potable water systems

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Sumit Khanna*

Reviewed by: *Matthew D. Tennenbaum*

Sumit Kr Khanna, Asso Project Engineer.

Matthew D. Tennenbaum, Staff Engineer

UL India Private Limited, India

UL Inc, US

Any information and documentation involving UL mark Services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

Certificate of Compliance

Addendum to Certificate of Compliance

Certificate Number **20080402-EX15298**
Report Reference **EX15298, 2008 April 2**
Issue Date **2008 April 2**



**Underwriters
Laboratories Inc.®**

Page 2 of 2

Model	Fitting Type	Size, in.	Rated Pressure, Kg/cm2 (psig)
A1	90° Elbow	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	25 (363)
B1	Tees	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	25 (363)
M2	Socket	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	25 (363)
N8	Hexagonal Nipple	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	25 (363)

CERTIFICATE OF COMPLIANCE

Certificate Number 20161229-MH61984
Report Reference MH61984-20161228
Issue Date 2016-DECEMBER-29

Issued to: HEBEI JIANZHI CASTING GROUP LTD
PANGZHUANGZI
SOUTHEAST OF YUTIAN COUNTY
TANGSHAN
HEBEI 064000 CHINA

**This is to certify that
representative samples of**

DRINKING WATER SYSTEM COMPONENTS
Trade Designation - "ELBOW", "TEE", "CROSS",
"CROSSOVER", "BEND", "SOCKET", "M/F REDUCER",
"CAP PLUG", "UNION", "UNION ELBOW", "SIDE OUTLET
ELBOW", "DRINKING ELBOW"

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: NSF/ANSI Standard 61a - Drinking Water System
Components - Health Effects

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



SERTIFIKAT PRODUK PENGGUNAAN TANDA SNI

SNI MARKING PRODUCT CERTIFICATE

No : 001/012/01.13/1/2014

Diberikan kepada / *Issued to:*

Perusahaan / *Company* : **HEIBEI JIANZHI CASTING GROUP CO., LTD**
Alamat / *Address* : Yutian District, Heibei Province, Pang Zuangzhi Southeast, China
Lokasi pabrik / *Factory location* : Yutian District, Heibei Province, Pang Zuangzhi Southeast, China
Importir : **PT. SINAR MAS ANDHIKA**
Alamat : Vinilon Building Lt. 8, Jl. Raden Saleh Kav. 13-17, Jakarta Pusat, Indonesia 10430
Nomor SNI / *SNI Number* : SNI 0139:2008
Komoditi / *Commodity* : Penyambung Pipa Berulir Dari Besi Cor Malleabel Hitam
Tipe/Jenis / *Type / Kind* : (Terlampir/Attached)
Merek / *Trade Mark* : JZ
Sistem Mutu yang digunakan / *Quality System Applied* : SNI ISO 9001 : 2008
Masa Berlaku Sertifikat / *Certificate Validity* : 4 tahun / 4 Years
Tipe Sertifikasi / *Type of Certification* : 5

Bandung, 09 Januari 2014

Ketua Dewan Pengarah LSP_{ro} MIDC

Head of LSP_{ro} MIDC Steering Committee



Ir. Eddy Siswanto, MAM

Masa berlaku Sertifikat / *Certificate Validity*

Tanggal Terdaftar / *Registered Date* : 09 Januari 2014

Tanggal Kadaluwarsa / *Expiration Date* : 09 Januari 2018

Jl. Sangkuriang No. 12 Bandung 40135 Jawa Barat - Indonesia

Telp. (022) 2503171, Fax. (022) 2503978

Email : lspro_midc@yahoo.co.id

Website : www.bbim.go.id



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **Т С Е**

BELGE NUMARASI 14.0.30.4.34.00/TSE-64506
REFERENCE NUMBER OF LICENCE

BELGENİN İLK VERİLİŞ TARİHİ 06.05.2013
DATE OF FIRST ISSUE OF LICENCE

BELGENİN SON GEÇERLİLİK TARİHİ 06.05.2014
LICENCE VALID UNTIL

BELGE SAHİBİ KURULUŞUN ADI FERAY İNŞ.DOĞ.MAL.SAN.TİC.LTD.ŞTİ.
NAME OF THE LICENCE HOLDER

BELGE SAHİBİ KURULUŞUN ADRESİ EGE SOKAK NO: 5/147 ULUS
ADDRESS OF THE LICENCE HOLDER UÇAR TİCARET MERKEZİ ANKARA

ÜRETİM YERİ ADI HEBEI JIANZHI CASTING GROUP LTD
NAME OF THE MANUFACTURING PLACE

ÜRETİM YERİ ADRESİ PANGZHUANGZI SOUTHEAST OF YUTIAN COUNTY
ADDRESS OF THE MANUFACTURING PLACE HEBEI PROVINCE, CHINA YURTDIŞI

İPTAL EDİLEN BELGE NUMARASI (Varsa)
INDICATION OF SUPERSEDED LICENCE (if any)

TESCİLLİ TİCARİ MARKASI JIANZHI
REGISTERED TRADE MARK

İLGİLİ TÜRK STANDARDI TS 11 EN 10242 / Boru Bağlantı Parçaları- Dökme Demir Temperlenmiş,
RELATED TURKISH STANDARD Diş Açılmış / 26.04.2000

BELGE KAPSAMI
SCOPE OF LICENCE

TS 11 EN 10242/Nisan 2000 "BORU BAĞLANTI PARÇALARI - DÖKME DEMİR -TEMPERLENMİŞ, DIŞ AÇILMIŞ"
-A1 DİRSEKLER;
1/2" Fe-A (Dahil)den - 4" Fe-A (Dahil)e kadar,
1/2" Zn-A (Dahil)den - 4" Zn-A (Dahil)e kadar
-A4 DİRSEKLER (İÇ-DIŞ VİDALI);
1/2" Fe-A (Dahil)den - 2 1/2" Fe-A (Dahil)e kadar,
1/2" Zn-A (Dahil)den - 2 1/2" Zn-A (Dahil)e kadar
-B1 T-DİRSEKLER;
1/2" Fe-A (Dahil)den - 4" Fe-A (Dahil)e kadar,
1/2" Zn-A (Dahil)den - 4" Zn-A (Dahil)e kadar
-N4 REDÜKSİYON NİPELLER;
3/4" X1/2" Fe-A (Dahil)den - 4" X3" Fe-A (Dahil)e kadar,
3/4" X1/2" Zn-A (Dahil)den - 4" X3" Zn-A (Dahil)e kadar
-N8 NİPELLER;
1/2" Fe-A (Dahil)den - 4" Fe-A (Dahil)e kadar,
1/2" Zn-A (Dahil)den - 4" Zn-A (Dahil)e kadar



08.../05/2013




A.CELAL AŞKAROĞLU
TSE İSTANBUL ÜRÜN
BELGELENDİRME MÜDÜRÜ

*Enstitümüzce verilmekte olan "İmalata Yeterlilik Belgesi" 15.04.2007 tarihinden itibaren uygulamadan kaldırılmıştır.
*Bu belge, belgelendirilen ürünün, üretim yerinin Enstitümüzün belirlediği şartları karşıladığını da gösterir.

TSE Kalite Kampusu İSTANBUL* İstanbul ÜBMCAYIROVA TREN İSTASYONU YANI BAYRAMOĞLU -GEBZE / KOCAELİ * Tel: 0262 653 07 52-20 HAT* Faks: 0262 653 08 49 * web: www.kampus.tse.org.tr * e-mail: e-mail:ubm@kampus.tse.org.tr

Bu belge hiç bir surette tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kızırtı ve silinti yapılamaz.



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ EKİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS APPENDIX

BELGE KAPSAMI (14.0.30.4.34.00/TSE-64506nolu belge devamı) : FERAY İNŞ.DOĞ.MAL.SAN.TİC.LTD.ŞTİ.

İLGİLİ TÜRK STANDARDI TS 11 EN 10242 / Boru Bağlantı Parçaları- Dökme Demir Temperlenmiş, Dış Açılmış /

-U 11 KONİK REKORLAR;

1/2" Fe-A (Dahil)den - 4" Fe-A (Dahil)e kadar,

1/2" Zn-A (Dahil)den - 4" Zn-A (Dahil)e kadar



08../05/2013

A. CELAL AŞKAROĞLU
TSE İSTANBUL ÜRÜN
BELGELENDİRME MÜDÜRÜ

*Enstitümüzce verilmekte olan "İmalata Yeterlilik Belgesi" 15.04.2007 tarihinden itibaren uygulamadan kaldırılmıştır.
*Bu belge, belgelendirilen ürünün, üretim yerinin Enstitümüzün belirlediği şartları karşıladığını da gösterir.

TSE Kalite Kampusu İSTANBUL* İstanbul ÜBMÇAYIROVA TREN İSTASYONU YANI BAYRAMOĞLU -GEBZE / KOCAELİ * Tel: 0262 653 07 52-20 HAT* Faks: 0262 653 08 49 * web:
www.kampus.tse.org.tr * e-mail: e-mail:ubm@kampus.tse.org.tr

Bu belge hiç bir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.



Certificate of Compliance

No. 0P211012.HJCQS00

Test Report / Technical Construction File no. TCHB21092933970

Certificate's
Holder:

HEBEI JIANZHI CASTING GROUP CO., LTD.
Pangzhuangzi Southeast of Yutian County Tangshan
Hebei

Certification ECM
Mark:



Product:
Model(s):

Malleable steel pipe fittings
DN series

Verification to:

Standard:
BS EN 10242:1995

related to GBR Regulation:
Construction Products Regulations (Regulation (EU)
305/2011 as brought into UK law and amended)

Remark: This document has been issued on a voluntary basis and upon request of the manufacturer. It is our opinion that the technical documentation received from the manufacturer is satisfactory for the requirements of the ECM Certification Mark. The conformity mark above can be affixed on the product(s) accordingly to ECM regulation about its release and its use. The regulation can be found at www.entecerma.it.

Additional information and clarification about the Marking:



The manufacturer is responsible for the UKCA Marking process, and if necessary, must refer to a Notified Body. This document has been issued on the basis of the regulation on ECM Voluntary Mark for the certification of products. RG01_ECM available at: www.entecerma.it

Issuance date: 12 October 2021

Expiry date: 11 October 2026

Reviewer
Technical expert
Amanda Payne



Approver
ECM Service Director
Luca Bedonni



Ente Certificazione Macchine Srl

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY
☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it



CERTIFICATE

质量管理体系认证证书

证书编号: 00220Q26278R4L

兹证明

河北建支铸造集团有限公司

统一社会信用代码: 91130229105198244A

住所: 河北省玉田县城东南庞庄子

认证地址: 河北省玉田县城东南庞庄子(064100)

管理体系符合

GB/T 19001-2016/ISO 9001:2015

《质量管理体系 要求》

覆盖的产品和服务

可锻铸铁管路连接件、沟槽式管接件、给水衬塑可锻铸铁管件、悬式绝缘子铁帽的设计、生产及相关技术服务

生效日期: 2020 年 11 月 24 日


有效期至: 2023 年 11 月 24 日

注册号: CQM-99-2002-0062-0001

(本证书信息可在国家认证认可监督管理委员会官方网站 www.cnca.gov.cn 或方圆标志认证集团官方网站上查询, 也可通过验证《确认证书》确认本证书的有效性)



二零二零年十一月二十四日



GB/T 19001



中国认可
国际互认
管理体系
MANAGEMENT SYSTEM
CNAS C002-M

方圆标志认证集团

地址: 北京市海淀区增光路33号 (100048)

<http://www.cqm.com.cn>

Q 0220736

CERTIFICATE



环境管理体系认证证书

证书编号: 00220E33762R4L

兹证明

河北建支铸造集团有限公司

统一社会信用代码: 91130229105198244A

住所: 河北省玉田县城东南庞庄子

认证地址: 河北省玉田县城东南庞庄子(064100)

管理体系符合

GB/T 24001-2016/ISO 14001:2015

《环境管理体系 要求及使用指南》

覆盖的产品和服务

可锻铸铁管路连接件、沟槽式管接件、给水衬塑可锻铸铁管件、悬式绝缘子铁帽的设计、生产及相关技术服务

生效日期: 2020 年 11 月 24 日

有效期至: 2023 年 11 月 24 日

注册号: CQM-99-2002-0062-0002

(本证书信息可在国家认证认可监督管理委员会官方网站 www.cnca.gov.cn 或方圆标志认证集团官方网站上查询, 也可通过验证《确认证书》确认本证书的有效性)

Handwritten signature



二零二零年十一月二十四日



GB/T 24001



中国认可
国际互认
管理体系
MANAGEMENT SYSTEM
CNAS C002-M

E 0087289

方圆标志认证集团

地址: 北京市海淀区增光路33号 (100048)

<http://www.cqm.com.cn>

CERTIFICATE



职业健康安全管理体系 认证证书

证书编号: 00220S23380R4L

兹证明

河北建支铸造集团有限公司

统一社会信用代码: 91130229105198244A

住所: 河北省玉田县城东南庞庄子

认证地址: 河北省玉田县城东南庞庄子 (064100)

管理体系符合

GB/T 45001-2020/ISO 45001:2018

《职业健康安全管理体系 要求及使用指南》

覆盖的产品和服务

可锻铸铁管路连接件、沟槽式管接件、给水衬塑可锻铸铁管件、悬式绝
缘子铁帽的设计、生产及相关技术服务

生效日期: 2020 年 11 月 24 日

有效期至: 2023 年 11 月 24 日

注册号: CQM-99-2002-0062-0003

(本证书信息可在国家认证认可监督管理委员会官方网站 www.cnca.gov.cn 或方圆标志认证集团官方网站上查询, 也可通过验证
《确认证书》确认本证书的有效性)



二零二零年十一月二十四日



GB/T 45001



中国认可
管理体系
MANAGEMENT SYSTEM
CNAS C002-M

方圆标志认证集团

地址: 北京市海淀区增光路33号 (100048)

<http://www.cqm.com.cn>

A 0031921