

STANDARD DX SYSTEM

Vs

MINI DUCT SYSTEM


MINI DUCT SYSTEM IS POWER SAVING APPLICATION FOR

- OFFICES
- SCHOOLS
- SPORTS
- LARGE HALLS
- GYMNASIUMS
- THEATERS




12/12/2020

WOLF INTERNATIONAL



STANDARD AC SYSTEM


- TYPICAL ROOM OF 10M X 10M.
- AIR SUPPLY & RETURN FROM CEILING.
- ROOM TEMP 75 °F (23.9 °C) / 50% RH
- AMBIENT TEMP 115 °F (46 °C) / 30% RH



STANDARD AC SYSTEM – HEAT LOAD CALCULATION – AMBIENT DATA

MINI DUCT SYSTEM SAMPLE WOLFrost INTERNATIONAL		Design Temperature Profile	12/12/2020 05:59PM
---	--	----------------------------	-----------------------

Design Temperature Profiles for July



MINI DUCT SYSTEM SAMPLE WOLFrost INTERNATIONAL		Design Weather Parameters & MSHGs	12/12/2020 05:59PM
---	--	-----------------------------------	-----------------------

Design Parameters:	
City Name	Dubai
Location	United Arab Emirates
Latitude	25.2 Deg.
Longitude	55.3 Deg.
Elevation	16.0 m
Summer Design Dry-Bulb	46.0 °C
Summer Coincident Wet-Bulb	29.4 °C
Summer Daily Range	9.7 °K
Winter Design Dry-Bulb	12.2 °C
Winter Design Wet-Bulb	7.4 °C
Atmospheric Clearness Number	1.00
Average Ground Reflectance	0.20
Soil Conductivity	1.385 W/(m·°K)
Local Time Zone (GMT +/- N hours)	-4.0 hours
Consider Daylight Savings Time	No
Simulation Weather Data	noneN/A
Current Data is	User Modified
Design Cooling Months	January to December

Design Day Maximum Solar Heat Gains

(The MSHG values are expressed in W/m²)

Month	N	NNE	NE	ENE	E	ESE	SE	SSE	S
January	83.3	83.3	133.2	372.2	613.4	753.3	795.4	760.0	724.5
February	93.6	93.6	261.5	493.0	686.2	783.7	759.5	678.5	616.1
March	104.9	121.0	398.8	607.3	719.6	752.9	681.8	543.3	449.5
April	115.5	266.1	501.3	659.0	717.2	665.7	544.3	356.3	252.8
May	133.5	361.1	561.4	676.1	690.0	600.2	432.2	227.3	155.0
June	170.9	398.7	581.4	675.8	669.3	563.3	384.2	185.0	138.2
July	137.2	366.6	558.6	664.5	671.2	577.3	422.5	221.2	153.0
August	120.5	262.5	492.2	637.4	687.4	639.5	524.6	343.4	244.7
September	108.7	126.7	370.0	579.0	696.4	710.9	657.4	528.5	442.8
October	96.7	96.7	235.2	495.3	664.5	742.1	745.7	663.7	603.5
November	84.8	84.8	123.8	389.0	581.8	740.8	785.2	754.7	717.6
December	78.8	78.8	90.9	326.4	569.5	732.5	790.0	779.8	756.0
Month	SSW	SW	WSW	W	WNW	NW	NNW	HOR	Mult
January	765.2	801.4	738.3	614.3	390.7	120.8	83.3	654.8	1.00
February	677.8	763.0	781.9	692.7	495.7	258.1	93.6	765.0	1.00
March	536.7	672.6	759.2	731.7	592.3	393.8	135.5	855.5	1.00
April	350.8	535.7	676.0	716.5	648.2	491.0	278.1	887.4	1.00
May	223.8	430.0	604.6	687.3	667.6	551.0	372.5	887.8	1.00
June	181.7	384.7	569.0	664.5	662.5	573.6	406.6	878.9	1.00
July	218.8	420.8	589.0	667.9	648.6	551.3	373.4	872.8	1.00
August	338.4	514.5	650.9	691.0	627.6	478.2	276.3	866.9	1.00
September	527.6	656.5	714.6	699.8	577.8	363.3	130.6	830.8	1.00
October	663.5	744.4	750.1	653.8	494.0	245.2	96.7	756.1	1.00
November	753.8	782.7	742.5	587.2	386.3	126.9	84.8	654.8	1.00
December	785.6	797.3	728.3	555.8	345.8	80.4	78.8	608.3	1.00

Mult. = User-defined solar multiplier factor.



Standard DX Unit System Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 07:53AM

1. General Details:

Air System NameSTANDARD FCU
Equipment TypeTerminal Units
Air System TypeSplit DX Fan Coil
Number of zones1
VentilationDirect Ventilation

2. Ventilation System Components:

(Common Ventilation System not used: no inputs)

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
STANDARD AC	x1

Thermostats and Zone Data:

ZoneAll
Cooling T-stat: Occ.23.9 °C
Cooling T-stat: Unocc.29.4 °C
Heating T-stat: Occ.21.1 °C
Heating T-stat: Unocc.15.6 °C
T-stat Throttling Range0.83 °K

Thermostat ScheduleSchedule 4
Unoccupied Cooling isAvailable

Common Terminal Unit Data:

Cooling Coil:
Design Supply Temperature14.4 °C
Coil Bypass Factor0.100
Cooling SourceAir-Cooled DX
ScheduleJFMAMJJASOND

Fan ControlFan On
Ventilation Sizing MethodSum of Space OA Airflows

Terminal Units Data:

ZoneAll
Terminal TypeFan Coil
Minimum Airflow0.00 L/s/person
Fan Performance0 Pa
Fan Overall Efficiency50 %

4. Sizing Data (Computer-Generated):

System Sizing Data:
Cooling Supply Temperature14.4 °C

Hydronic Sizing Specifications:

Chilled Water Delta-T5.6 °K
Hot Water Delta-T11.1 °K

Safety Factors:

Cooling Sensible10 %
Cooling Latent5 %
Heating0 %

Zone Sizing Data:

Zone Airflow Sizing MethodSum of space airflow rates
Space Airflow Sizing MethodIndividual peak space loads

Zone	Supply Airflow (L/s)	Zone Htg Unit (kW)	Reheat Coil (kW)	Ventilation (L/s)
1	1003.2	-	-	55.0

5. Equipment Data Terminal Cooling Units - Air-Cooled DX

Zone	Estimated Maximum Load (kW)	Design OAT (°C)	Equipment Sizing	Gross Cooling Capacity (kW)	Capacity Oversizing Factor (%)	Compressor + OD Fan Power (kW)	ARI Performance Rating (EER)	Conventional Cutoff OAT (°C)
All	14.7	35.0	Auto-Sized	-	0	7.96	13.8	23.8

Standard DX Unit Space Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 07:53AM

STANDARD DX UNIT

1. General Details:

Floor Area100.0 m²
Avg. Ceiling Height3.0 m
Building Weight498.0 kg/m²

1.1. OA Ventilation Requirements:

Space UsageOFFICE: Office space
OA Requirement 12.5 L/s/person
OA Requirement 20.30 L/(s·m²)
Space Usage DefaultsASHRAE Std 62.1-2004

2. Internals:

2.1. Overhead Lighting:
Fixture TypeRecessed (Unvented)
Wattage10.00 W/m²
Ballast Multiplier1.00
ScheduleLIGHTING SCHEDULE

2.2. Task Lighting:
Wattage0.00 W/m²
ScheduleNone

2.3. Electrical Equipment:
Wattage25.00 W/m²
ScheduleEQUIP.SCHEDULE

2.4. People:
Occupancy10.0 People
Activity LevelSedentary Work
Sensible82.1 W/person
Latent79.1 W/person
ScheduleEQUIP.SCHEDULE

2.5. Miscellaneous Loads:
Sensible0 W
ScheduleNone
Latent0 W
ScheduleNone

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	30.0	1	0	0
E	30.0	1	0	0
S	30.0	1	0	0
W	30.0	1	0	0

3.1. Construction Types for Exposure N

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.2. Construction Types for Exposure E

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.3. Construction Types for Exposure S

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.4. Construction Types for Exposure W

Wall TypeDefault Wall Assembly
1st Window TypeW1

4. Roofs, Skylights:

Exp.	Roof Gross Area (m²)	Roof Slope (deg.)	Skylight Qty.
H	100.0	0	0

4.1. Construction Types for Exposure H

Roof TypeLight Weight Roof

5. Infiltration:


Design Cooling1.00 L/s
Design Heating0.00 L/s
Energy Analysis0.00 L/s
Infiltration occurs only when the fan is off.

6. Floors:


TypeFloor Above Unconditioned Space
Floor Area100.0 m²
Total Floor U-Value0.568 W/(m²·°K)
Unconditioned Space Max Temp.23.9 °C
Ambient at Space Max Temp.35.0 °C
Unconditioned Space Min Temp.23.9 °C
Ambient at Space Min Temp.12.8 °C

STANDARD DX SYSTEM - ISSUES

- UNEVEN AIR DISTRIBUTION
- UNEVEN TEMPERATURE IN ROOM
- CONTAMINATION OF AIR LINGERS IN ROOM
- HIGHER POWER CONSUMPTION



SOLUTION – AIR SUPPLY AT OCCUPIED LEVEL



APPLICATION


- SPLIT TOTAL AREA IN 2 PARTS.
 - OCCUPIED AREA.
 - UNOCCUPIED PLENUM AREA.
- AIR SUPPLIED AT FLOOR LEVEL.
 - COLLECTS HEAT AT OCCUPIED LEVEL.
- QUICKLY MOVES TO UNOCCUPIED AREA.
 - REMOVES AIR CONTAMINATION FAST.
- SEPARATE HEAT LOAD CALCULATION
 - OCCUPIED AREA
 - UNOCCUPIED PLENUM AREA
- CALCULATE
 - AIR QUANTITY REQUIRED
 - TEMPERTURES
 - GRILLES
 - PLENUM
 - RETURN AIR
- EFFECT ON UNIT SELECTION & NET POWER CONSUMPTION



1M HEIGHT OF
UNOCCUPIED AREA

UNOCCUPIED AREA HEAT GAINS FROM ROOF, WALLS, OVERHEAD LIGHTS, VENTILATION LOAD.

OCCUPIED AREA HEAT GAINS FROM FLOOR, WALLS, EQUIPMENT, PEOPLE LOAD.



2M HEIGHT OF
OCCUPIED AREA



12/12/2020

Occupied Area Space Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 07:54AM

MINI DUCT SYSTEM-OCCUPIE

1. General Details:

Floor Area100.0 m²
Avg. Ceiling Height2.0 m
Building Weight498.0 kg/m²

1.1. OA Ventilation Requirements:

Space UsageOFFICE: Office space
OA Requirement 12.5 L/s/person
OA Requirement 20.30 L/(s·m²)
Space Usage DefaultsASHRAE Std 62.1-2004

2. Internals:

2.1. Overhead Lighting:

Fixture TypeRecessed (Unvented)
Wattage0.00 W/m²
Ballast Multiplier1.00
ScheduleNone

2.2. Task Lighting:

Wattage0.00 W/m²
ScheduleNone

2.3. Electrical Equipment:

Wattage25.00 W/m²
ScheduleEQUIP.SCHEDULE

2.4. People:

Occupancy10.0 People
Activity LevelSedentary Work
Sensible82.1 W/person
Latent79.1 W/person
ScheduleEQUIP.SCHEDULE

2.5. Miscellaneous Loads:

Sensible0 W
ScheduleNone
Latent0 W
ScheduleNone

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	20.0	1	0	0
E	20.0	1	0	0
S	20.0	1	0	0
W	20.0	1	0	0

3.1. Construction Types for Exposure N

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.2. Construction Types for Exposure E

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.3. Construction Types for Exposure S

Wall TypeDefault Wall Assembly
1st Window TypeW1

3.4. Construction Types for Exposure W

Wall TypeDefault Wall Assembly
1st Window TypeW1

4. Roofs, Skylights:

(No Roof or Skylight data).

5. Infiltration:

Design Cooling1.00 L/s
Design Heating0.00 L/s
Energy Analysis0.00 L/s
Infiltration occurs only when the fan is off.

6. Floors:

TypeFloor Above Unconditioned Space
Floor Area100.0 m²
Total Floor U-Value0.568 W/(m²·°K)
Unconditioned Space Max Temp.35.0 °C
Ambient at Space Max Temp.35.0 °C
Unconditioned Space Min Temp.35.0 °C
Ambient at Space Min Temp.12.8 °C

7. Partitions:

(No partition data).

Hourly Analysis Program v.4.4

WOLF INTERNATIONAL

Page 1 of 1

Occupied area System Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 08:00AM

1. General Details:

Air System NameMINI DUCT SYSTEM OCCUPIED
Equipment TypeTerminal Units
Air System TypeSplit DX Fan Coil
Number of zones1
VentilationDirect Ventilation

2. Ventilation System Components:

(Common Ventilation System not used: no inputs)

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
MINI DUCT SYSTEM-OCCUPIE	x1

Thermostats and Zone Data:

ZoneAll
Cooling T-stat: Occ.23.9 °C
Cooling T-stat: Unocc.29.4 °C
Heating T-stat: Occ.21.1 °C
Heating T-stat: Unocc.15.6 °C
T-stat Throttling Range0.83 °K

Thermostat ScheduleSchedule 4
Unoccupied Cooling isAvailable

Common Terminal Unit Data:

Cooling Coil:

Design Supply Temperature16.7 °C
Coil Bypass Factor0.100
Cooling SourceAir-Cooled DX
ScheduleJFMAMJJASOND

Fan ControlFan On
Ventilation Sizing MethodSum of Space OA Airflows

Terminal Units Data:

ZoneAll
Terminal TypeFan Coil
Minimum Airflow0.00 L/s/person
Fan Performance0 Pa
Fan Overall Efficiency50 %

4. Sizing Data (User-Modified):

System Sizing Data:

Cooling Supply Temperature16.7 °C

Hydronic Sizing Specifications:

Chilled Water Delta-T5.6 °K
Hot Water Delta-T11.1 °K

Safety Factors:

Cooling Sensible10 %
Cooling Latent5 %
Heating0 %

Zone Sizing Data:

Zone Airflow Sizing MethodSum of space airflow rates
Space Airflow Sizing MethodIndividual peak space loads

Zone	Supply Airflow (L/s)	Zone Htg Unit (kW)	Reheat Coil (kW)	Ventilation (L/s)
1	698.0	-	-	55.0

Hourly Analysis Program v.4.4

9

Page 1 of 1

Occupied Area - Air System Design Load Summary

Project : Standard DX Unit Vs Mini Duct System

12/14/2020
07:59AM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600			HEATING DATA AT DES HTG		
	COOLING OA DB / WB	45.7 °C / 29.3 °C		HEATING OA DB / WB	12.2 °C / 7.4 °C	
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	12 m²	310	-	12 m²	-	-
Wall Transmission	68 m²	722	-	68 m²	322	-
Roof Transmission	0 m²	0	-	0 m²	0	-
Window Transmission	12 m²	461	-	12 m²	203	-
Skylight Transmission	0 m²	0	-	0 m²	0	-
Door Loads	0 m²	0	-	0 m²	0	-
Floor Transmission	100 m²	0	-	100 m²	0	-
Partitions	0 m²	0	-	0 m²	0	-
Ceiling	0 m²	0	-	0 m²	0	-
Overhead Lighting	0 W	0	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	2500 W	2500	-	0	0	-
People	10	821	791	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 5%	481	40	0%	0	0
>> Total Zone Loads	-	5295	831	-	524	0
Zone Conditioning	-	5295	831	-	-292	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Exhaust Fan Load	0 L/s	0	-	0 L/s	0	-
Ventilation Load	0 L/s	0	-	0 L/s	0	0
Ventilation Fan Load	0 L/s	0	-	0 L/s	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	5295	831	-	12	0
Terminal Unit Cooling	-	5295	831	-	0	0
Terminal Unit Heating	-	0	-	-	0	-
>> Total Conditioning	-	6023	831	-	0	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Occupied Area Zone Sizing Summary

Project : Standard DX Unit Vs Mini Duct System

12/14/2020
07:59AM

Air System Information

Air System Name MINI DUCT SYSTEM OCCUPIED
Equipment Class TERM
Air System Type SPLT-FCNumber of zones 1
Floor Area 100.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Zone and Space Sizing Method:

Zone L/s Sum of space airflow rates
Space L/s Individual peak space loadsCalculation Months Jan to Dec
Sizing Data User-Modified

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (kW)	Design Air Flow (L/s)	Minimum Air Flow (L/s)	Time of Peak Load	Maximum Heating Load (kW)	Zone Floor Area (m²)	Zone L/(s-m²)
Zone 1	5.3	698	698	Jul 0000	0.5	100.0	6.98

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Area Leaving DB / WB (°C)	Area Entering DB / WB (°C)	Water Flow @ 5.6 °K (L/s)	Time of Peak Load
Zone 1	6.1	5.3	23.9 / 17.0	17.3 / 14.7	-	Jul 1600

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s-m²)
Zone 1							
MINI DUCT SYSTEM-OCCUPIED	1	6.0	Jul 0000	696	-	100.0	6.96





Unoccupied area Space Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 07:56AM

MINI DUCT SYSTEM-UNOCCUP

1. General Details:

Floor Area100.0 m²
Avg. Ceiling Height1.0 m
Building Weight498.0 kg/m²

1.1. OA Ventilation Requirements:

Space UsageOFFICE: Office space
OA Requirement 12.5 L/s/person
OA Requirement 20.30 L/s-m²
Space Usage DefaultsASHRAE Std 62.1-2004

2. Internals:

2.1. Overhead Lighting:

Fixture TypeRecessed (Unvented)
Wattage1.00 W/m²
Ballast Multiplier1.00
ScheduleLIGHTING SCHEDULE

2.2. Task Lighting:

Wattage0.00 W/m²
ScheduleNone

2.3. Electrical Equipment:

Wattage0.00 W/m²
ScheduleNone

2.4. People:

Occupancy0.0 Person
Activity LevelSedentary Work
Sensible82.1 W/person
Latent79.1 W/person
ScheduleNone

2.5. Miscellaneous Loads:

Sensible0 W
ScheduleNone
Latent0 W
ScheduleNone

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
N	10.0	0	0	0
E	10.0	0	0	0
S	10.0	0	0	0
W	10.0	0	0	0

3.1. Construction Types for Exposure N

Wall TypeDefault Wall Assembly

3.2. Construction Types for Exposure E

Wall TypeDefault Wall Assembly

3.3. Construction Types for Exposure S

Wall TypeDefault Wall Assembly

3.4. Construction Types for Exposure W

Wall TypeDefault Wall Assembly

4. Roofs, Skylights:

Exp.	Roof Gross Area (m²)	Roof Slope (deg.)	Skylight Qty.
H	100.0	0	0

4.1. Construction Types for Exposure H

Roof TypeLight Weight Roof

5. Infiltration:

Design Cooling1.00 L/s
Design Heating0.00 L/s
Energy Analysis0.00 L/s
Infiltration occurs only when the fan is off.

6. Floors:

TypeFloor Above Conditioned Space
(No additional input required for this floor type).

7. Partitions:

(No partition data).

12/12/2020

Hourly Analysis Program v.4.4

Unoccupied Area System Input Data

Project : Standard DX Unit Vs Mini Duct System12/14/2020 07:56AM

1. General Details:

Air System NameMINI DUCT SYSTEM UNOCCUPIED
Equipment TypeTerminal Units
Air System TypeSplit DX Fan Coil
Number of zones1
VentilationDirect Ventilation

2. Ventilation System Components:

(Common Ventilation System not used: no inputs)

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
MINI DUCT SYSTEM-UNOCCUP	x1

Thermostats and Zone Data:

ZoneAll
Cooling T-stat: Occ29.4 °C
Cooling T-stat: Unocc29.4 °C
Heating T-stat: Occ21.1 °C
Heating T-stat: Unocc15.6 °C
T-stat Throttling Range0.83 °K

Thermostat ScheduleSchedule 4
Unoccupied Cooling isAvailable

Common Terminal Unit Data:

Cooling Coil:
Design Supply Temperature23.9 °C
Coil Bypass Factor0.100
Cooling SourceAir-Cooled DX
ScheduleJFMAMJJASOND

Fan ControlFan On
Ventilation Sizing MethodSum of Space OA Airflows

Terminal Units Data:

ZoneAll
Terminal TypeFan Coil
Minimum Airflow0.00 L/s/person
Fan Performance0 Pa
Fan Overall Efficiency50 %

4. Sizing Data (User-Modified):

System Sizing Data:

Cooling Supply Temperature23.9 °C

Hydronic Sizing Specifications:

Chilled Water Delta-T5.6 °K
Hot Water Delta-T11.1 °K

Safety Factors:

Cooling Sensible10 %
Cooling Latent5 %
Heating0 %

Zone Sizing Data:

Zone Airflow Sizing MethodSum of space airflow rates
Space Airflow Sizing MethodIndividual peak space loads

Zone	Supply Airflow (L/s)	Zone Htg Unit (kW)	Reheat Coil (kW)	Ventilation (L/s)
1	698.0	-	-	30.0

11

Hourly Analysis Program v.4.4Page 1 of 2



Unoccupied Air System Design Load Summary		
Project : Standard DX Unit Vs Mini Duct System		12/14/2020 07:57AM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 2000			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 41.4 °C / 28.4 °C			HEATING OA DB / WB 12.2 °C / 7.4 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	0 m²	0	-	0 m²	-	-
Wall Transmission	40 m²	444	-	40 m²	189	-
Roof Transmission	100 m²	4071	-	100 m²	675	-
Window Transmission	0 m²	0	-	0 m²	0	-
Skylight Transmission	0 m²	0	-	0 m²	0	-
Door Loads	0 m²	0	-	0 m²	0	-
Floor Transmission	0 m²	0	-	0 m²	0	-
Partitions	0 m²	0	-	0 m²	0	-
Ceiling	0 m²	0	-	0 m²	0	-
Overhead Lighting	1000 W	1000	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	0 W	0	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 5%	552	0	0%	0	0
>> Total Zone Loads	-	6067	0	-	865	0
Zone Conditioning	-	6067	0	-	-110	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Exhaust Fan Load	0 L/s	0	-	0 L/s	0	-
Ventilation Load	55 L/s	1124	1427	55 L/s	204	0
Ventilation Fan Load	0 L/s	0	-	0 L/s	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	7091	1427	-	17	0
Terminal Unit Cooling	-	7091	0	-	0	0
Terminal Unit Heating	-	0	-	-	0	-
>> Total Conditioning	-	7091	1427	-	0	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Unoccupied Area Zone Sizing Summary

Project : Standard DX Unit Vs Mini Duct System

12/14/2020
07:57AM

Air System Information

Air System Name **MINI DUCT SYSTEM UNOCCUPIED**
Equipment Class **TERM**
Air System Type **SPLT-FC**Number of zones **1**
Floor Area **100.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Zone and Space Sizing Method:

Zone L/s **Sum of space airflow rates**
Space L/s **Individual peak space loads**Calculation Months **Jan to Dec**
Sizing Data **User-Modified**

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (kW)	Design Air Flow (L/s)	Minimum Air Flow (L/s)	Time of Peak Load	Maximum Heating Load (kW)	Zone Floor Area (m²)	Zone L/(s-m²)
Zone 1	7.1	698	698	Jul 2100	0.9	100.0	6.98

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Area Entering DB / WB (°C)	Water Flow @ 5.6 °K (L/s)	Time of Peak Load
Zone 1	8.5	7.1	32.3 / 20.2	23.9 / 17.0	-	Jul 2000


Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s-m²)
Zone 1							
MINI DUCT SYSTEM-UNOCCUP	1	5.6	Jul 2100	698	-	100.0	6.90

MINI DUCT SYSTEM – UNIT SELECTION

			<u>UNIT SELECTION PARAMETERS</u>
- STANDARD HEAT LOAD CALCULATION - T kW = 14.7 - S kW = 12.4 - L/s = 1003 - External Static Pressure = 50 Pa - Design Condition - Room Db = 23.9 °C - Room Wb = 16.9 °C - Air Entering Room - Room Db = 15.1 °C - Room Wb = 14.5 °C - Air Leaving Room - Room Db = 25.4 °C - Room Wb = 18.8 °C	- OCCUPIED AREA HEAT LOAD - T kW = 6.1 - S kW = 5.3 - L/s = 698 - External Static Pressure = 1" - Design Condition - Room Db = 23.9 - Room Wb = 16.9 - Air Entering Room $Db = \text{Room Db} - (SkW \times 1000 / 1.006 \times 1.202 \times L/s)$ $Db = 23.9 - (5.3 \times 1000 / 1.006 \times 1.202 \times 698)$ Db = 17.62 °C - Air Entering Room $\text{Enthalpy} = \text{Room E} - (TkW / 1.202 \times \text{Air Volume})$ $= 47.8 - (6.1 \times 1000 / 1.202 \times 0.698)$ $= 40.5 \text{ KJ/kg d.a}$ Wb = 14.7 °C	- UNOCCUPIED AREA HEAT LOAD - T kW = 8.52 - S kW = 7.1 - L/s = 698 - External Static Pressure = 1" - Design Condition - Room Db = 23.9 - Room Wb = 16.9 - Air Leaving Room $Db = \text{Room Db} + (SkW \times 1000 / 1.006 \times 1.202 \times L/s)$ $Db = 23.9 + (7.1 \times 1000 / 1.006 \times 1.202 \times 698)$ Db = 32.3 °C - Air Leaving Room $\text{Enthalpy} = \text{Room E} + (TkW \times 1000 / 1.202 \times L/s)$ $= 47.8 + (8.52 \times 1000 / 1.202 \times 698)$ $= 57.96 \text{ KJ/kg d.a}$ Wb = 20.2 °C	- T kW = 14.62 - S kW = 12.4 - L/s = 698 - External Static Pressure = 1" - Design Condition - Room Db = 23.9 °C - Room Wb = 16.9 °C - Air Entering Room - Room Db = 17.62 °C - Room Wb = 14.7 °C - Air Leaving Room - Room Db = 32.2 °C - Room Wb = 20.2 °C







12/12/2020

© Copyright 2010 Unico, Inc.

M SERIES BLOWER MODULE



ENGINEERING SPECIFICATIONS

Blower Module Specifications – 60 Hz

Model No.		M2430B-	M3642BL	M4860BL
Electrical Characteristics		208 – 230 Volts / 60 / 1 phase		
Motor Size, HP (kW)		1/2 (0.37)	1 (0.75)	
Motor Type	-STD, -ACB	PSC		
	-SCB	EC (variable speed)		
Motor Capacitor, mfd.	-STD, -ACB	10		
Motor Capacitor, mfd.	-SCB	none		
Motor Full Load Amps	-STD	3.0	6.2	6.2
	-ACB	3.3	4.8	4.8
	-SCB	3.2	6.1	6.1
Motor Speed, RPM	-STD	1700		
	-ACB	1700/800		
	-SCB	400-1800		
Blower Wheel Nom. Diameter, in. (mm)		9.5 (241)		
Blower Wheel Width, inch (mm)		3.75 (95)	5.0 (127)	7.75 (197)
*Nominal Air Flow Rate, CFM (L/s)		600 (283)	900 (425)	1250 (590)
*Plenum Static Pressure, in. water (Pa)		1.5 (373)	1.5 (373)	1.5 (373)
Minimum Plenum Size, ID, inch (mm)		7 (178)	9 (229)	10 (254)
Sound Pressure Level	dB(A)	56	56	58
	NC	50	47	50
Shipping Weight, lb (kg)		62 (28)	72 (33)	72 (33)

* based on full open restrictor and minimum plenum size at 230V.

Measuring airflow.

To determine the airflow when using the single or two-speed motors (-STD, -ACB models), measure the amperage and look up the airflow in the following table. This is not necessary for the variable speed motors because they are programmed to deliver the airflow that you need.


Blower Performance (with cooling module installed) –STD and –ACB models

External Static Pressure, in. water (Pa)	1.0 (250)		1.25 (310)		1.5 (370)		1.75 (435)		2.0 (500)		
	Model	CFM (L/s)	Amps	CFM (L/s)	Amps	CFM (L/s)	Amps	CFM (L/s)	Amps	CFM (L/s)	Amps
60 Hz – 230V											
STD models											
	M2430LB	870 (410)	3.1	810 (383)	2.9	740 (351)	2.7	660 (310)	2.4	510 (240)	2.0
	M3642LB	1240 (585)	4.8	1170 (552)	4.5	1070 (505)	4.1	925 (437)	3.6	745 (352)	3.1
	M4860LB	1472 (695)	4.7	1400 (660)	4.5	1300 (610)	4.2	1162 (548)	3.9	953 (450)	3.4
ACB models											
	M2430LB+ACB	760 (360)	2.3	700 (330)	2.1	640 (302)	2.0	550 (260)	1.7	450 (212)	1.5
	M3642LB+ACB	1380 (617)	5.2	1300 (613)	4.9	1200 (566)	4.5	1090 (514)	4.0	950 (448)	3.6
	M4860LB+ACB	1480 (698)	5.0	1430 (674)	4.4	1360 (642)	4.5	1220 (575)	4.0	930 (439)	3.1



ENGINEERING SPECIFICATIONS

MB4860L



WOLF INTERNATIONAL




12/12/2020


TheUnicoSystem®

M SERIES COOLING MODULE
REFRIGERANT COILS for R-22, R-407C, R-410A
ENGINEERING SPECIFICATIONS

UNIT PERFORMANCE AT REQUIRED PARAMETERS - BLOWER MB4860L+ COIL MC4860C



Dimensional Data




MC4860x Specifications

Type of System	Cooling Only	Heat Pump
Model No.	MC4860C	MC4860H
Compatible Condenser Size, Ton (kW)	4-5 (14-17.6)	
Evaporator Coil	Net Face Area, ft ² (m ²)	7.44 (0.69)
	Tube diameter, in. (mm)	3/8 (9.5)
	Number of rows	3
	Fin Type	sinewave
	Number of Circuits	10
	Valve, R-22, Part No.	A00805-005
	Valve, R-410A, Part No.	A00805-015
	Design Pressure, psig (kPa)	500 (3447)
	Condensate Connection, in. (mm) FPT	3/4 (19)
Refrigerant	R-22, R-407C, R-410A*	
	Coil Shipping Weight, lb. (kg)	88 (40)
	Factory Installed Expansion Device	TXV

WOLF INTERNATIONAL


DETAIL OF PIPING



STANDARD DX UNITS VS MINI DUCT UNITS

• STANDARD AC UNITS – AIR DISTRIBUTION


- High Volume – Low External Static Fan.
- Air is pushed through low pressure ducting. Fan is the source of Air. Air terminal units are the Air Exit point.



- Air moves in elliptical path in Rectangular duct. It leaves corners in most condition forming fungus. Dry fungus drops in duct, get carried in AC are causing allergies to occupants.

• MINI DUCT UNITS – AIR DISTRIBUTION

- Low Volume – High External Static Fan.
- Main Duct is closed form all sides. Air is delivered under high pressure in the duct. Once desired pressure is built, air moves out through tapings into flexible duct, the delivered into conditioned area. Small Air terminal units are the exit points.



- Due to High pressure Air is filled in Duct completely leaving no space for fungus to form.

STANDARD DX UNITS VS MINI DUCT UNITS

• STANDARD AC UNITS – TERMINAL UNITS

- The conventional AC system provides similar looking grilles / diffusers taking prominent position in your room décor with identical finish in any premises.
- Any attempt to change the look proves expensive to buy and to maintain later on.




- Fungus from duct, settles on these air outlets which is very difficult to clean as construction of these air outlets are very fragile.

• MINI DUCT UNITS – TERMINAL UNITS

- Outlets are small, subtle and blend into any décor.
- For the look that best suits your needs, a variety of styles and finishes are available.
- Choose from white or black plastic, chrome, brass and several wood species or simply paint or stain the outlet to perfectly match room color scheme.



ORIGINAL
5" Outer Diameter Plastic Outlet
for Ceiling Applications
(Available in white, black, brass
or chrome finishes)



WOODEN
5" Outer Diameter Wood Outlet
for Hardwood Floor Applications
(Available in a variety of
wood species)



SLOPED
15° and 25° Angled Outlets
for Sloped Ceilings and Walls




SLOTTED
1/2" x 8" Slotted Outlet for Sidewall Applications
(Available in a variety of finishes and wood species)

STANDARD DX UNITS VS MINI DUCT UNITS


- STANDARD AC UNITS – AIR DUMPING IN CONDITIONED SPACE

- The conventional AC system is designed to dump air into the room, causing uncomfortable drafts, hot and cold spots.



- MINI DUCT UNITS – ASPIRATION WAY OF AIR MOVEMENT IN CONDITIONED SPACE

- The Unico System gently circulates air throughout each room, eliminating drafts, and thermal shocks, providing even temperatures from ceiling to floor and in each room corner.



STANDARD DX UNITS VS MINI DUCT UNITS

• STANDARD AC UNITS – AIR FILTRATION

- Limited Filtration options.
- Due to low static fans, filtration units will increase external static pressure and reduce air volume
- This will affect cooling and increase power consumption.



• MINI DUCT UNITS – AIR FILTRATION

- Due to High External Static fans its possible to add any Electrostatic or Electronic filter with out any effect on Air Volume.
- So no effect on cooling hence power consumption



STANDARD UNITS VS MINI DUCT UNITS

• STANDARD AC UNITS – OPTIONS

- ---
- ---
- ---
- NA
- Capillary expansion.
- Single module.
- Standard Filtration option
- Due to dirty ducts, in long run Unhygienic operation
- Interior design needs to be adjusted based on Air terminal unit design. No design freedom.

• MINI DUCT UNITS – OPTIONS

- DX – UNITS – R22/407C/410A
- Matching Single Split / VRV system
- CHILLED WATER COIL – Chiller / District Cooling Application.
- MOTOR with Variable speed EC Motor & SMART CONTROL BOX.
- Thermostatic Expansion valve for precise control.
- Modular Construction.
- Multiple Filtration Options
- Hygienic operation due to pressurized duct
- Aesthetically pleasant Air terminal units. Interior design freedom get preference
- Reduced power consumption.

