

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: \_\_\_\_\_

Work Phone: \_\_\_\_\_

706-745-6013

Water System Name: \_\_\_\_\_

Email Address: \_\_\_\_\_

clerk@coosawater.com

County: \_\_\_\_\_

Union

- Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.  
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1	2	3	4	5	6	7	8	9	0
---	---	---	---	---	---	---	---	---	---

Shade Circles Like This: ●

Not Like This: ⊗ ⊕

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

**G A**

PWS ID Number

**2 9 1 0 0 0 6**

Sample Date (mm / dd / yyyy)

**0 1**

**0 6**

**2 0 2 5**

#### Sample Type

- ☒ Routine  
☐ Replacement

#### Fluoride Analysis Method

- ☐ ISE Electrode  
☒ SPADNS  
☐ Complexone  
☐ Ion Chromatography

#### Fluoride Concentration – Operator

**0 . 7 2**

#### Chemical Use to Fluoridate Water

- ☒ Sodium Fluoride  
☐ Sodium Fluorosilicate  
☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

**0 . 8 0**

Date Received: \_\_\_\_\_

1 / 8 / 25

Date Tested: \_\_\_\_\_

1 / 8 / 25

Date Reported: \_\_\_\_\_

1 / 10 / 25 kw

Tested By: \_\_\_\_\_

Kal Murree

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Cocoa Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Adam Lance

Work Phone: 706-795-1003

Water System Name: \_\_\_\_\_

Email Address: clan@coawater.com

County: Union

- Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.  
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●  
Not Like This: ⊗ ⊙

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

**G A**

PWS ID Number

**2 9 1 0 0 0 6**

Sample Date (mm / dd / yyyy)

**07 05 2025**

#### Sample Type

- ☒ Routine  
☐ Replacement

#### Fluoride Analysis Method

- ☐ ISE Electrode  
☒ SPADNS  
☐ Complexone  
☐ Ion Chromatography

0.25  
Fluoride Concentration – Operator

called  
2-25-25  
-KW

**0 . 68**

#### Chemical Use to Fluoridate Water

- ☒ Sodium Fluoride  
☐ Sodium Fluorosilicate  
☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

**0 . 36**

Date Received: 2, 7, 25

Date Tested: 2, 20, 25

Date Reported: 2, 25, 25

Tested By: Kal Murchee

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Cole Sullivan

Work Phone: 706-745-6003

Water System Name: Coosa Water Authority

Email Address: clark@coosawater.com

County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.

2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ☒  
Not Like This: ☐ ☒

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

G A

PWS ID Number

2 9 1 0 0 0 6

Sample Date (mm / dd / yyyy)

0 3 / 0 6 / 2 0 2 5

#### Sample Type

- ☒ Routine  
☐ Replacement

#### Fluoride Analysis Method

- ☐ ISE Electrode  
☒ SPADNS  
☐ Complexone  
☐ Ion Chromatography

#### Fluoride Concentration – Operator

0 . 7 5

#### Chemical Use to Fluoridate Water

- ☒ Sodium Fluoride  
☐ Sodium Fluorosilicate  
☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 7 8

Tested By: Kal Murree

Date Received: 3, 10, 25

Date Tested: 3, 11, 25

Date Reported: 3, 14, 25 km

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Cocoa Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Adam Lance

Work Phone: 706-745-6003

Water System Name: \_\_\_\_\_

Email Address: clara@cocoa-water.com

County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.  
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●  
Not Like This: ⊗ ⊙

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

G A

PWS ID Number

2 9 1 0 0 0 6

Sample Date (mm / dd / yyyy)

04 / 04 / 2025

#### Sample Type

- ☒ Routine  
☐ Replacement

#### Fluoride Analysis Method

- ☐ ISE Electrode  
☒ SPADNS  
☐ Complexone  
☐ Ion Chromatography

#### Fluoride Concentration – Operator

0 . 68

#### Chemical Use to Fluoridate Water

- ☒ Sodium Fluoride  
☐ Sodium Fluorosilicate  
☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 50

Date Received: 4, 9, 25

Date Tested: 4, 14, 25

Date Reported: 4, 15, 25 kw

Tested By: Kelsi Murrell

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Copco Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Cidan Lance

Work Phone: 706-745-1013

Water System Name: \_\_\_\_\_

Email Address: cidan@copcowater.com

County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.  
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●  
Not Like This: ⊗ ⊙

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

**G A**

PWS ID Number

**2 9 1 0 0 0 6**

Sample Date (mm / dd / yyyy)

**0 5 0 7 2 0 2 5**

#### Sample Type

- ☒ Routine  
☐ Replacement

#### Fluoride Analysis Method

- ☐ ISE Electrode  
☒ SPADNS  
☐ Complexone  
☐ Ion Chromatography

#### Fluoride Concentration – Operator

**0 . 6 1**

#### Chemical Use to Fluoridate Water

- ☒ Sodium Fluoride  
☐ Sodium Fluorosilicate  
☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

**0 . 5 5**

Tested By: Kal Murree

Date Received: 5, 12, 25

Date Tested: 5, 19, 25

Date Reported: 5, 21, 25 km

# Waycross Public Health Laboratory

Fluoride Monitoring

1751 Gus Karle Parkway • Waycross, GA 31503

(912) 338-7050



2 0 2 5

## Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Cosco Water Authority  
4707 Blue Ridge Hwy  
Blairsville, GA 30512

### Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Adam Lance

Work Phone:

706-745-6013

Water System Name: Cosco Water Auth.

Email Address:

clace@coscowater.com

Union County

County:

Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.  
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●

Not Like This: ⊗ ⊙

### THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

PWS ID Number

Sample Date (mm / dd / yyyy)

G A

2 9 1 0 0 0 6

0 6

0 3

2 0 2 5

#### Sample Type

☒ Routine

☐ Replacement

#### Fluoride Analysis Method

☐ ISE Electrode

☒ SPADNS

☐ Complexone

☐ Ion Chromatography

#### Fluoride Concentration – Operator

0 . 8 8

#### Chemical Use to Fluoridate Water

☒ Sodium Fluoride

☐ Sodium Fluorosilicate

☐ Sodium Fluorosilicic Acid

### THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

1 . 0

Date Received: 6/6/25

Date Tested: 6/12/25

Date Reported: 6/13/25 kw

Tested By:

Kate Munnher