

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: Cole Sullivan

Work Phone: 706-745-1673

Water System Name: Coosa Water

Email Address: cwa@coosawater.com

County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1	2	3	4	5	6	7	8	9	0
---	---	---	---	---	---	---	---	---	---

Shade Circles Like This: ●
Not Like This: ⊗

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

PWS ID Number

Sample Date (mm / dd / yyyy)

G A

2 9 1 0 0 0 6

0 1

0 9

2 0 2 4

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0 . 9 0

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

. 8 1

Date Received: 1, 10, 24

Date Tested: 1, 12, 24

Date Reported: 1, 16, 24 kw

Tested By: M. [Signature]

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-245-1673
Water System Name: Coosa Water Email Address: cwa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗ ⊙

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 02 / 07 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0 . 75

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 69

Date Received: 2/9/24

Date Tested: 2/9/24

Date Reported: 2/12/24 *low*

Tested By: M. Miller

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-745-1673
Water System Name: Coosa Water Email Address: cwa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗ ⊙

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 03 / 04 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0 . 99

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

 . 91

Date Received: 3/6/24

Date Tested: 3/6/24

Date Reported: 3/7/24 kw

Tested By: Miller

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____

Work Phone: 706-745-1673

Water System Name: Coosa Water

Email Address: cwa@coosawater.com

County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗ ⊙

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

PWS ID Number

Sample Date (mm / dd / yyyy)

G A

2 9 1 0 0 0 6

0 4

0 2

2 0 2 4

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0 . 9 0

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 1 . 1

Date Received: 4, 4, 24

Date Tested: 4, 9, 24

Date Reported: 4, 10, 24 kw

Tested By: [Signature]

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Cousa Water Authority
4700 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-745-1673
Water System Name: Cousa Water Email Address: cwa@cousawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗ ⊙

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 05 / 06 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0.79

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0.81

Date Received: 5/8/24

Date Tested: 5/8/24

Date Reported: 5/8/24 kw

Tested By: [Signature]

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____

Work Phone: 706-745-1673

Water System Name: Coosa Water

Email Address: cwa@coosawater.com

County: Union

- Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●

Not Like This: ⊗

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

G A

PWS ID Number

2 9 1 0 0 0 6

Sample Date (mm / dd / yyyy)

0 6 / 0 5 / 2 0 2 4

Sample Type

- Routine
 Replacement

Fluoride Analysis Method

- ISE Electrode
 SPADNS
 Complexone
 Ion Chromatography

Fluoride Concentration – Operator

0 . 7 7

Chemical Use to Fluoridate Water

- Sodium Fluoride
 Sodium Fluorosilicate
 Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 7 2

Tested By: Nicole Brunner

Date Received: 6/7/24

Date Tested: 6/7/24

Date Reported: 6/7/24 kw

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Cross Water Authority
4700 Blue Ridge Road
Blacksville, GA 30520

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____

Work Phone: 478-745-16773

Water System Name: Cross Water

Email Address: cwaa@crosswater.com

County: Union

- Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗ ⊙

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State

PWS ID Number

Sample Date (mm / dd / yyyy)

G A

2 9 1 0 0 0 6

0 7

0 3

2 0 2 4

Sample Type

- Routine
 Replacement

Fluoride Analysis Method

- ISE Electrode
 SPADNS
 Complexone
 Ion Chromatography

Fluoride Concentration – Operator

0 . 6 8

Chemical Use to Fluoridate Water

- Sodium Fluoride
 Sodium Fluorosilicate
 Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 6 9

Date Received: 7/8/24

Date Tested: 7/8/24

Date Reported: 7/9/24 ken

Tested By: Null Garner

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 781-745-1677
Water System Name: Coosa Water Email Address: coosa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ○

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 351010000 Sample Date (mm / dd / yyyy): 08 / 05 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

5.70

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0.69

Date Received: 8/7/24

Date Tested: 8/7/24

Date Reported: 8/7/24 K

Tested By: Nicole Brannen

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Road
Blairsville GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-745-16773
Water System Name: Coosa Water Email Address: cwa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This: ●
Not Like This: ⊗

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: **G A** PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 09 / 09 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0 . 70

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0 . 85

Date Received: 9, 11, 24

Date Tested: 9, 13, 24

Date Reported: 9, 13, 24 kw

Tested By: Michelle Bravere

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville, GA 30512

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-745-1673
Water System Name: Coosa Water Email Address: cwa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This:
Not Like This:

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 10 / 07 / 2024

Sample Type

- Routine
- Replacement

Fluoride Analysis Method

- ISE Electrode
- SPADNS
- Complexone
- Ion Chromatography

Fluoride Concentration – Operator

0.70

Chemical Use to Fluoridate Water

- Sodium Fluoride
- Sodium Fluorosilicate
- Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0.79

Tested By: Nick Bruner

Date Received: 10 / 9 / 24

Date Tested: 10 / 9 / 24

Date Reported: 10 / 10 / 24 KBW

Waycross Public Health Laboratory

Fluoride Monitoring
1751 Gus Karle Parkway • Waycross, GA 31503
(912) 338-7050



2 0 2 4

Water Fluoridation Split-Sample Reporting Form

Print or type return address:

Coosa Water Authority
4707 Blue Ridge Hwy
Blairsville GA 30729

Public Water Systems:

Complete all portions of this section and return form with sample bottle to the address above.

Sample Collected By: _____ Work Phone: 706-745-1673
Water System Name: Coosa Water Email Address: cwa@coosawater.com
County: Union

Notes: 1. Use the original forms distributed with the sample bottles only – DO NOT USE PHOTOCOPIES.
2. Please print CLEARLY and within the lines (see samples below). The information below will be read by computer and automatically entered into the fluoridation database.

1 2 3 4 5 6 7 8 9 0

Shade Circles Like This:
Not Like This:

THIS SECTION TO BE COMPLETED BY WATER SYSTEM SUBMITTING SPLIT SAMPLE

State: GA PWS ID Number: 2910006 Sample Date (mm / dd / yyyy): 11 / 05 / 2024

Sample Type

- Routine
 Replacement

Fluoride Analysis Method

- ISE Electrode
 SPADNS
 Complexone
 Ion Chromatography

Fluoride Concentration – Operator

0.72

Chemical Use to Fluoridate Water

- Sodium Fluoride
 Sodium Fluorosilicate
 Sodium Fluorosilicic Acid

THIS SECTION FOR STATE LAB USE ONLY

Fluoride Concentration – State Lab

0.84

Tested By: Neill Bannan

Date Received: 11/12/24

Date Tested: 11/18/24

Date Reported: 11/19/24 kw