PRODUCTS

Version 1.1 Revision Date 09/20/2004 MSDS Number 30000003826 Print Date 02/18/2012

1. PRODUCT AND COMPANY IDENTIFICATION

Product name	: Helium
Chemical formula	: He
Synonyms	: Helium, Helium gas, Gaseous helium, Balloon gas
Product Use Description	: Medical Applications
Company	: Air Products and Chemicals,Inc 7201 Hamilton Blvd. Allentown, PA 18195-1501
Telephone	: 1-800-345-3148 Chemicals 1-800-752-1597 Gases and Electronic Chemicals
Emergency telephone number	: 800-523-9374 USA +1 610 481 7711 International

2. COMPOSITION/INFORMATION ON INGREDIENTS

Components	CAS Number	Concentration (Volume)
Helium	7440-59-7	100 %

Concentration is nominal. For the exact product composition, please refer to Air Products technical specifications.

3. HAZARDS IDENTIFICATION

Emergency Overview

High pressure gas. Can cause rapid suffocation. Self contained breathing apparatus (SCBA) may be required.

Potential Health Effects

Inhalation	: In high concentrations may cause asphyxiation. Asphyxiation may bring about unconsciousness without warning and so rapidly that victim may be unable to protect themselves.
Eye contact	: No adverse effect.
Skin contact	: No adverse effect.
Ingestion	: Ingestion is not considered a potential route of exposure.
Chronic Health Hazard	: Not applicable.

Version	1.1
Revision	Date 09/20/2004

Exposure Guidelines

Primary Routes of Entry	: Innalation
Target Organs	: None known.
Symptoms	: Exposure to oxygen deficient atmosphere may cause the following symptoms: Dizziness. Salivation. Nausea. Vomiting. Loss of mobility/consciousness.

Aggravated Medical Condition

None.

Environmental Effects

Not harmful.

4. FIRST AID MEASURES

General advice	Remove victim to uncontaminated area wearing self contained bre pparatus. Keep victim warm and rested. Call a doctor. Apply artif espiration if breathing stopped.	U U
Eye contact	lot applicable.	
Skin contact	lot applicable.	
Ingestion	ngestion is not considered a potential route of exposure.	
Inhalation	Remove to fresh air. If breathing has stopped or is labored, give a espirations. Supplemental oxygen may be indicated. If the heart rained personnel should begin cardiopulmonary resuscitation imn ase of shortness of breath, give oxygen.	has stopped,

5. FIRE-FIGHTING MEASURES

Suitable extinguishing media	All known extinguishing media can be used.	
Specific hazards	Upon exposure to intense heat or flame, cylinder will vent rapidly violently. Product is nonflammable and does not support combust away from container and cool with water from a protected position containers and surroundings cool with water spray.	tion. Move
Special protective equipment for fire-fighters	Wear self contained breathing apparatus for fire fighting if necess	ary.

6. ACCIDENTAL RELEASE MEASURES

Personal precautions	: Evacuate personnel to safe areas. Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe. Monitor oxygen
	level. Ventilate the area.

Version	1.1
Revisior	Date 09/20/2004

Environmental precautions	Do not discharge into any place where its accumulation could be dang Prevent further leakage or spillage if safe to do so.	erous.
Methods for cleaning up	Ventilate the area.	
Additional advice	If possible, stop flow of product. Increase ventilation to the release are monitor oxygen level. If leak is from cylinder or cylinder valve, call the Products emergency telephone number. If the leak is in the user's sys close the cylinder valve, safely vent the pressure, and purge with an in before attempting repairs.	Air tem,

7. HANDLING AND STORAGE

Handling

Protect cylinders from physical damage; do not drag, roll, slide or drop. Do not allow storage area temperature to exceed 50°C (122°F). Only experienced and proper ly instructed persons should handle compressed gases. Before using the product, determine its identity by reading the label. Know and understand the properties and hazards of the product before use. When doubt exists as to the correct handling procedure for a particular gas, contact the supplier. Do not remove or deface labels provided by the supplier for the identification of the cylinder contents. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use. Use an adjustable strap wrench to remove over-tight or rusted caps. Before connecting the container, check the complete gas system for suitability, particularly for pressure rating and materials. Before connecting the container for use, ensure that back feed from the system into the container is prevented. Ensure the complete gas system is compatible for pressure rating and materials of construction. Ensure the complete gas system has been checked for leaks before use. Employ suitable pressure regulating devices on all containers when the gas is being emitted to systems with lower pressure rating than that of the container. Never insert an object (e.g. wrench, screwdriver, pry bar, etc.) into valve cap openings. Doing so may damage valve, causing a leak to occur. Open valve slowly. If user experiences any difficulty operating cylinder valve discontinue use and contact supplier. Close container valve after each use and when empty, even if still connected to equipment. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Close valve after each use and when empty. Replace outlet caps or plugs and container caps as soon as container is disconnected from equipment. Do not subject containers to abnormal mechanical shocks which may cause damage to their valve or safety devices. Never attempt to lift a cylinder by its valve protection cap or guard. Do not use containers as rollers or supports or for any other purpose than to contain the gas as supplied. Never strike an arc on a compressed gas cylinder or make a cylinder a part of an electrical circuit. Do not smoke while handling product or cylinders. Never re-compress a gas or a gas mixture without first consulting the supplier. Never attempt to transfer gases from one cylinder/container to another. Always use backflow protective device in piping. When returning cylinder install valve outlet cap or plug leak tight. Never use direct flame or electrical heating devices to raise the pressure of a container. Containers should not be subjected to temperatures above 50℃ (122年). Prolonged periods of cold temperature below -30℃ (-20年) should be avoided.

Storage

Full containers should be stored so that oldest stock is used first. Containers should be stored in a purpose build compound which should be well ventilated, preferably in the open air. Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Protect containers stored in the open against rusting and extremes of weather. Containers should not be stored in conditions likely to encourage corrosion. Containers should be stored in the vertical position and properly secured to prevent toppling. The container valves should be tightly closed and where appropriate valve outlets should be capped or plugged. Container valve guards or caps should be in place. Keep containers tightly closed in a cool, well-ventilated place. Store containers in location free from fire risk and away from sources of

Version	1.1	
Revision	Date 09/20/2004	

heat and ignition. Full and empty cylinders should be segregated. Do not allow storage temperature to exceed 50°C (122°F). Return empty containers in a timely m anner.

Technical measures/Precautions

Containers should be segregated in the storage area according to the various categories (e.g. flammable, toxic, etc.) and in accordance with local regulations. Keep away from combustible material.

8. EXPOSURE CONTROLS / PERSONAL PROTECTION

Engineering measures

Provide natural or mechanical ventilation to prevent oxygen deficient atmospheres below 19.5% oxygen.

Personal protective equipment

Respiratory protection	: Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be used in oxygen-deficient atmosphere. Air purifying respirators will not provide protection. Users of breathing apparatus must be trained.
Hand protection	: Sturdy work gloves are recommended for handling cylinders. The breakthrough time of the selected glove(s) must be greater than the intended use period.
Eye protection	: Safety glasses recommended when handling cylinders.
Skin and body protection	: Safety shoes are recommended when handling cylinders.
Special instructions for protection and hygiene	: Ensure adequate ventilation, especially in confined areas.
Remarks	: Simple asphyxiant.

9. PHYSICAL AND CHEMICAL PROPERTIES

Form	: Compressed gas.
Color	: Colorless gas
Odor	: No odor warning properties.
Molecular Weight	: 4 g/mol
Relative vapor density	: 0.138 (air = 1)
Density	: 0.012 lb/ft3 (0.0002 g/cm3) at 70 F (21 C)
Specific Volume	: 96.68 ft3/lb (6.0349 m3/kg) at 70 ℉ (21 ℃)
Boiling point/range	: -452 F (-268.9 C)
Critical temperature	: -450 ℉ (-267.9 ℃)

Version 1.1 Revision Date 09/20/2004

Revision Date 09/20/2004		Print Date 02/18/2012		
Water solubility	: 0.0015 g/l			
10. STABILITY AND REACTIV	ÎTY			
Stability	: Stable under normal conditions.			
Hazardous decomposition products	: None.			
11. TOXICOLOGICAL INFOR	MATION			
Acute Health Hazard				
Ingestion	: No data is available on the product itself.			
Inhalation	: No data is available on the product itself.			
Skin.	: No data is available on the product itself.			
12. ECOLOGICAL INFORMA	10N			
Ecotoxicity effects				
Aquatic toxicity	: No data is available on the product itself.			
Toxicity to other organisms	: No data available.			
Persistence and degradab	ity			
Mobility	: No data available.			
Bioaccumulation	: No data is available on the product itself.			
Further information				
This product has no known e	co-toxicological effects.			
13. DISPOSAL CONSIDERAT	IONS			
Waste from residues / unused products	: Contact supplier if guidance is required. Return unused cylinder to supplier.	d product in orginal		
Contaminated packaging	: Return cylinder to supplier.			
14. TRANSPORT INFORMAT	ON			
CFR				
Proper shipping name	: Helium, compressed			

Version 1.1 Revision Date 09/20/2004

IATA

Proper shipping name	: Helium, compressed
Class	: 2.2
UN/ID No.	: UN1046

IMDG

Class :	HELIUM, COMPRESSED 2.2 UN1046
---------	-------------------------------------

CTC

Proper shipping name	: HELIUM, COMPRESSED
Class	: 2.2
UN/ID No.	: UN1046

Further Information

Avoid transport on vehicles where the load space is not separated from the driver's compartment. Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

15. REGULATORY INFORMATION

OSHA Hazard Communication Standard (29 CFR 1910.1200) Hazard Class(es) Compressed Gas.

Country	Regulatory list	Notification
USA	TSCA	Included on Inventory.
EU	EINECS	Included on Inventory.
Canada	DSL	Included on Inventory.
Australia	AICS	Included on Inventory.
Japan	ENCS	Included on Inventory.
South Korea	ECL	Included on Inventory.
China	SEPA	Included on Inventory.
Philippines	PICCS	Included on Inventory.
USA	TSCA	Included on Inventory.
EU	EINECS	Included on Inventory.
Canada	DSL	Included on Inventory.
Australia	AICS	Included on Inventory.
Japan	ENCS	Included on Inventory.
South Korea	ECL	Included on Inventory.
China	SEPA	Included on Inventory.
Philippines	PICCS	Included on Inventory.

EPA SARA Title III Section 312 (40 CFR 370) Hazard Classification: No SARA Hazards

Sudden Release of Pressure Hazard.

US. California Safe Drinking Water & Toxic Enforcement Act (Proposition 65) This product does not contain any chemicals known to State of California to cause cancer, birth defects or any other harm.

This product does not contain any chemicals known to State of California to cause cancer, birth defects or any other harm.

16. OTHER INFORMATION

Prepared by : Air Products and Chemicals, Inc. Global EH&S Product Safety Department

For additional information, please visit our Product Stewardship web site at http://www.airproducts.com/productstewardship/