

RE:
700 Mitchell Bridge Road
Athens, GA 30606

1/17/22

After our site assessment it was determined that (1) CT4000 Charge Point Dual port charger can be installed. Using the existing 120/208 house panel on building #8 power will be provided to charger via a 200' bore. Please note that underground Utility markings may require the location to change.

