

2024 Sampling Data	Contaminant=	PFOA	PFOS	PFNA	PFHxS	PFBS	HFPO-DA	PFBA	PFPeA	PFHpA	PFHxA
	EPA Final MCL=	4ppt	4ppt	10ppt	10ppt	Hazard Index	10ppt				
	Analysis Method=	533	533	533	533	533	533	533	533	533	533
Sample Date	Entry Point										
7/2/2024	Joint Water Purification Plant	3.1ppt	<1.9ppt	<1.9ppt	1.9ppt	4.4ppt	<1.9ppt	3.4ppt	4.9ppt	<1.9ppt	4.2ppt
6/13/2024	Joint Water Purification Plant	3.2ppt	<1.9ppt	<1.9ppt	1.9ppt	4.3ppt	<1.9ppt	3.3ppt	4.6ppt	<1.9ppt	4.1ppt
5/9/2024	Joint Water Purification Plant	3.2ppt	<1.9ppt	<1.9ppt	<1.9ppt	4ppt	<1.9ppt	3ppt	4.4ppt	<1.9ppt	3.9ppt
4/3/2024	Joint Water Purification Plant	3.4ppt	<1.9ppt	<1.9ppt	<1.9ppt	4ppt	<1.9ppt	3.2ppt	4.6ppt	<1.9ppt	4.3ppt
3/7/2024	Joint Water Purification Plant	3.2ppt	<1.9ppt	<1.9ppt	<1.9ppt	3.9ppt	<1.9ppt	3.2ppt	4.8ppt	<1.9ppt	4.3ppt
2/22/2024	Joint Water Purification Plant	2.8ppt	<2.0ppt	<2.0ppt	<2.0ppt	3.4ppt	<2.0ppt	3.1ppt	4.3ppt	<2.0ppt	3.8ppt
1/25/2024	Joint Water Purification Plant	3ppt	<1.9ppt	<1.9ppt	<1.9ppt	4.9ppt	<1.9ppt	3.2ppt	4.7ppt	<1.9ppt	4.3ppt

2023 Sampling Data	Contaminant=	PFOA		PFOS		PFNA		PFHxS		PFBS		HFPO-DA		Hazard Index
	EPA Proposed MCL=	4ppt		4ppt		Hazard Index		Hazard Index		Hazard Index		Hazard Index		1.0
	Analysis Method=	533	537.1	533	537.1	533	537.1	533	537.1	533	537.1	533	537.1	533
Sample Date	Entry Point													
11/16/2023	Joint Water Purification Plant	3.3ppt	3.3ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	4ppt	3.9ppt	<2ppt	<1.9ppt	
9/11/2023	Joint Water Purification Plant	4ppt		<4ppt		<4ppt		<3ppt		4.7ppt		<5ppt		
8/2/2023	Joint Water Purification Plant	<4ppt		<4ppt		<4ppt		<3ppt		4.5ppt		<5ppt		
5/23/2023	Joint Water Purification Plant	2.3ppt	2.3ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	3ppt	2.4ppt	<2ppt	<1.9ppt	
3/7/2023	Joint Water Purification Plant	<4ppt		<4ppt		<4ppt		<3ppt		4.5ppt		<5ppt		
3/1/2023	Joint Water Purification Plant	2.8ppt	2.7ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	<2ppt	<1.9ppt	3.7ppt	3.3ppt	<2ppt	<1.9ppt	
2/8/2023-5/10/2023	Joint Water Purification Plant	4.6ppt		<4ppt		<4ppt		<3ppt		6.1ppt		<5ppt		

2022 Sampling Data	Contaminant=	PFOA	PFOS		PFHxA		PFHxS		PFBS		PFPeA	PFBA
	EPA Interim Health Advisory Limit=	0.004ppt	0.02ppt						2000ppt (final)			
	Analysis Method=	537.1	533	537.1	533	537.1	533	537.1	533	537.1	533	533
Sample Date	Entry Point											
7/15/2022	Joint Water Purification Plant	-	Non-Detect		2.2ppt		Non-Detect		Non-Detect		2.6ppt	3.2ppt
7/25/2022	Joint Water Purification Plant	3.8ppt		Non-Detect		4.7ppt		Non-Detect		4.6ppt		