



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: T OVERBY

FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN ST STE 714
FAYETTEVILLE, NC 28301

Name of System

Hamlet

1813 McDonald Ave

Division of Water Resources
FRO-Public Water Supply

EIN: 562033116M

Delivery: NC Courier

StarLiMS ID: ES250930-0064

Date Collected: 09/26/2025

Time Collected: 12:15

By: T Overby

Date Received: 09/30/2025

Time Received: 08:10

Sample Type:

Sampling Point:

Well Permit No.

Sample Source: Municipal

Receipt Temp. :

GPS Number:

Comment: Water system I.D.# 03-77-010

Profile: Public + Metals I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Antimony	<0.001	0.006	mg/L	
Arsenic	<0.001	0.010	mg/L	
Barium	<0.1	2.0	mg/L	
Beryllium	<0.001	0.004	mg/L	
Cadmium	<0.0005	0.005	mg/L	
Calcium	3		mg/L	
Chloride	10.5	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	0.031	1.3	mg/L	
Fluoride	0.947	4.00	mg/L	
Iron	0.214	0.300	mg/L	
Lead	<0.003	0.015	mg/L	
Magnesium	<1		mg/L	
Manganese	0.013	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
pH	7.1		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	23.7		mg/L	
Sulfate	21.4	250	mg/L	
Thallium	<0.0001	0.002	mg/L	
Total Alkalinity	15		mg/L	
Total Hardness	7		mg/L	
Zinc	0.15	5.0	mg/L	

Report Date: 10/15/2025

Reported By:

Marc Komlos



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611
FINAL REPORT

Report to: T OVERBY

FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN ST STE 714
FAYETTEVILLE, NC 28301

Name of System:

Hamlet
Main St

RECEIVED

OCT 24 2025

Division of Water Resources
FRO-Public Water Supply

EIN: 562033116M

Delivery: NC Courier

StarLiMS ID: ES250930-0065

Date Collected: 09/26/2025

Time Collected: 12:30

By: T Overby

Date Received: 09/30/2025

Time Received: 08:10

Sample Type:

Sampling Point: Laundromat

Well Permit No.

Sample Source: Municipal

Receipt Temp. :

GPS Number:

Comment: Water system I.D.# 03-77-010

Profile: Public + Metals I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Antimony	<0.001	0.006	mg/L	
Arsenic	<0.001	0.010	mg/L	
Barium	<0.1	2.0	mg/L	
Beryllium	<0.001	0.004	mg/L	
Cadmium	<0.0005	0.005	mg/L	
Calcium	<1		mg/L	
Chloride	10.1	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	0.028	1.3	mg/L	
Fluoride	0.965	4.00	mg/L	
Iron	0.094	0.300	mg/L	
Lead	<0.003	0.015	mg/L	
Magnesium	<1		mg/L	
Manganese	0.010	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
pH	7.0		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	24.2		mg/L	
Sulfate	23.8	250	mg/L	
Thallium	<0.0001	0.002	mg/L	
Total Alkalinity	13		mg/L	
Total Hardness	<7		mg/L	
Zinc	0.22	5.0	mg/L	

Report Date: 10/15/2025

Reported By:

Marc Komlos